


Root Cause Analysis Report

Failure in Quality Assurance Oversight to Prevent Significant Degradation of Reactor Pressure Vessel Head

CR 2002-02578, dated 6-13-2002

REPORT DATE: 9-10-2002

Prepared by: Mark H. Levering 
for R. J. Tadych
Per Telecon
Root Cause Lead

Reviewed by: 
D. C. Poole
Investigative Team Leader

Approved by: S.A. Lockman for
L. W. Pearce PER TELECON
Vice President, Oversight

TABLE OF CONTENTS

TABLE OF CONTENTS.....	ii
EXECUTIVE SUMMARY	1
PROBLEM STATEMENT.....	4
DESCRIPTION OF REASON FOR INVESTIGATION.....	4
CONSEQUENCES OF EVENT/CONDITION INVESTIGATED	4
IMMEDIATE ACTIONS TAKEN	4
REMEDIAL ACTIONS TAKEN	4
EVENT NARRATIVE	5
TEAM CHARTER.....	5
EVENT DESCRIPTION.....	5
BACKGROUND DESCRIPTION.....	6
KEY EVENTS.....	6
DATA ANALYSIS	10
METHODOLOGY	10
ANALYSIS MODEL	11
ASSUMPTIONS	12
DATA COLLECTION.....	13
FUNCTIONAL TOOL ANALYSIS CHARTS.....	13
DATA REVIEW.....	15
FACT LIST	19
CAUSAL FACTORS	20
CONCLUSION.....	21
EXPERIENCE REVIEW.....	23
DAVIS-BESSE CATS.....	23
DAVIS-BESSE CREST	23
NUCLEAR INDUSTRY.....	24
CONCLUSIONS	25
ROOT CAUSE DETERMINATION	26
ROOT CAUSE.....	26
CONTRIBUTING CAUSES	26

EXTENT OF CONDITION	28
RECOMMENDED CORRECTIVE ACTIONS.....	29
Preventive and Remedial Actions	29
Enhancement Actions	33
REFERENCES	34
Documents reviewed.....	34
Personnel contacted	34
Methodologies employed.....	34
REVIEW METHODOLOGY OF AUDITS AND SURVEILLANCES	34
REVIEW METHODOLOGY OF QA TREND SUMMARY REPORTS AND ISEG REPORTS	35
REVIEW METHODOLOGY OF TIMELINE	35
REVIEW METHODOLOGY OF PERSONNEL INTERVIEWS	36
REVIEW METHODOLOGY OF NRC DOCUMENTS	36
Team Members	37
ATTACHMENTS	38
Attachment 1 – Feedback Model Diagram.....	39
Attachment 2 – Event & Causal Factor Chart.....	40
Attachment 3 – Functional Tool Analysis Chart, Prior to 10RFO	41
Attachment 4 – Functional Tool Analysis Chart, End of 10RFO through End of 11RFO	42
Attachment 5 – Functional Tool Analysis Chart, End of 11RFO through End of Mid-Cycle Outage of 1999.....	43
Attachment 6 – Functional Tool Analysis Chart, End of Mid-Cycle Outage of 1999 through End of 12RFO	44
Attachment 7 – Functional Tool Analysis Chart, Post 12RFO	45
Attachment 8 – Standard Interview Questions for Oversight Personnel.....	46
Attachment 9 – List of Oversight Personnel Interviewed	48
Attachment 10 – Standard Interview Questions for Selected Line Management	49
Attachment 11 – List of Selected Line Management Personnel Interviewed	51
Attachment 12 – List of Personnel Interviewed by the NQA Team	52

EXECUTIVE SUMMARY

Davis-Besse (D-B) Condition Report (CR) 02-02578 identified the failure in Quality Assurance Oversight to prevent significant degradation of the reactor pressure vessel (RPV) head. The essence of this issue and the resulting root cause analysis was to understand the key aspects of the operation of the oversight function at D-B and why they did not cause positive change in the site line organization such that the head degradation would have been found at a much earlier stage. The investigation assumed that the oversight organization had both the opportunity to influence the line organization such that they would detect the degradation and also an opportunity to directly detect the degradation during oversight activities.

The team concluded that the Oversight function did miss opportunities to cause earlier identification and mitigation of the RPV head degradation. The analysis further indicates that standards within the oversight function were insufficiently differentiated from the standards of the station. It was determined that the root cause was that D-B's nuclear safety values, behaviors and expectations were such that oversight was not set apart, in terms of expectations and performance standards, from the balance of the station. This affected the ability of the oversight organizations to identify problems and effect needed positive change in station operations. This was particularly applicable to the implementation of the Corrective Action Program and resulted in the station tolerating conditions that were potentially detrimental to safety for long periods of time.

The team began with a model of an oversight organization likened to a signal processor feedback loop and developed over 400 facts/observations gathered from the following sources:

- QA Audit and Surveillance Reports
- QA Summary Reports
- ISEG Reports and Correspondence
- NRC Inspection Reports and Correspondence
- Personnel Interviews
- Miscellaneous Documents developed from other sources

The investigation spanned the timeframe from late 1986 until the discovery of the degradation in early 2002. The analysis was broken down into five time periods. This was done to facilitate the investigation due to the extensive time involved and in recognition of changes that occurred in the oversight organization over time, the type and nature of information available about the ongoing head degradation, and in the opportunities available to detect the degradation. The five time periods were:

- Prior to 10RFO
- Beginning of 10RFO to the end of 11RFO
- End of 11RFO to the end of the 1999 Mid-Cycle Outage
- End of the 1999 Mid-Cycle Outage to the end of 12RFO

- After 12RFO

The investigation performed Event & Causal Factor (E&CF) analyses for the following six management “functional tools”:

- Corrective Action Program
- Root Cause Analysis
- Operating Experience
- Trend/Analysis
- Culture/Values
- Audits/Surveillances/Evaluations

“Functional Tools” as used in this context refers to those cross functional processes used by either line management or oversight functions to identify and resolve problems at nuclear power plants.

Using the principles of E&CF charting, the team identified 27 initial causal factors that were consolidated into seven formal causal factors. From these formal causal factors the team identified one root cause and three contributing causes as follow:

Root Cause:

- Since the mid-1990s, D-B’s nuclear safety values, behaviors and expectations were such that oversight was not set apart, in terms of expectations and performance standards, from the balance of the station. This affected the ability of the oversight organizations to identify problems and effect needed positive change in station operations.

Contributing Causes:

- The training for the RC-2 event was ineffective. It failed to improve the ability of both the oversight and line organizations to recognize corrosive conditions and their significance. This contributed to the failure of the auditing team to raise a concern when auditing the Boric Acid Corrosion Control Program during 12RFO.
- Oversight did not establish an effective method for assessing the oversight function. The process for providing oversight of the oversight function was less than adequate, feedback provided was mixed, and corrective actions were sometimes ineffective.
- For a period of time, the management of the audit/evaluation process was not independent from the management of the corrective action process. This lack of independence allowed the oversight director to soften the thrust of an audit critical of the corrective action process during 2000.

Key corrective actions:

- Establish, document, communicate and hold Oversight and Process Improvement Department (OPID) personnel accountable to expectations that support the ability of OPID to detect adverse conditions, process information, and escalate issues in a manner that ensures they are resolved in a timely fashion. The goal of this corrective action is to elevate the ability of OPID to cause positive change to occur at FENOC stations when warranted. The corrective action section of this report contains details relative to appropriate expectations.
- Modify the values of the oversight organization to set itself apart from the culture of the station, assure that it always maintains the highest standards with regards to a questioning

attitude, and continually drive the site organization to a higher level of excellence. The oversight organization must maintain sufficient independence in their thought processes that they do not inherit an unhealthy station culture but rather maintain a strong questioning attitude about station activities affecting safety.

- Provide organization, staffing, tools, training, office location, etc. for the oversight function appropriate to revised expectations; match all elements of resources and expectations.
- Develop an improved method for oversight of the oversight function.

A total of 17 corrective actions are recommended in this report. Details of remaining actions are in the corrective action section of the report.

PROBLEM STATEMENT

DESCRIPTION OF REASON FOR INVESTIGATION

Station oversight functions were not successful in identifying or effecting resolution of issues related to corrosion of the Reactor Pressure Vessel (RPV) head. In this context, station oversight functions include Quality Assessment/Quality Control (QA/QC) audits, QA/QC surveillances, and Independent Safety Engineering Group (ISEG) activities. The investigation evaluated the interface with other station groups like the Station Review Board (SRB), the Corrective Action Review Board (CARB), and the Company Nuclear Review Board (CNRB). Oversight's assessment of the Corrective Action Program (CAP) and Management Review Process were also evaluated.

CONSEQUENCES OF EVENT/CONDITION INVESTIGATED

The organizational consequences were a lack of timely identification of various significant conditions adverse to quality, and a failure to assure that the operating organization had taken necessary and sufficient actions to preclude degradation of the Reactor Pressure Vessel head. The nuclear safety consequences were a challenge to a principal fission product barrier and extensive boric acid corrosion of other equipment inside the containment building. In addition, the station suffered a loss of regulatory confidence, and is undergoing a costly outage to restore systems to an acceptable configuration and reestablish confidence in the operating organization.

IMMEDIATE ACTIONS TAKEN

This Root Cause Team took no immediate actions. This Team was chartered to perform the Root Cause Investigation, beginning June 24, 2002.

REMEDIAL ACTIONS TAKEN

This Root Cause Team took no remedial actions. This Team was chartered to perform the Root Cause Investigation, beginning June 24, 2002.

EVENT NARRATIVE

TEAM CHARTER

On February 27, 2002, the D-B staff issued Condition Report (CR) CR 2002-0891 reporting indications of through wall axial flaws in the weld region of #3 Control Rod Drive Mechanism (CRDM) nozzle. During the course of repair efforts on the penetration nozzle, the boring machine and the nozzle unexpectedly rotated approximately 15 degrees. Investigation of this condition under CR 2002-01053 identified significant corrosion around nozzle #3. As a result, a Root Cause Team was assigned to "Determine the root and contributing causes for Reactor Pressure Vessel closure head (RPV head) damage experienced at nozzle 3 and minor corrosion at nozzle 2, to support the operability determination for the station's as-found condition and the future repair plan." This Team was known as the "Technical Root Cause Team"; their report was completed on April 15, 2002.

During the performance of the technical issue analysis of the root cause evaluation for the degradation of the RPV head, five previous issues within the site's Corrective Action Program (CAP) were identified as related issues to this event. A Nuclear Quality Assessment (NQA) Team was charged with performing a review of these five issues to provide a better understanding of the contributing management issues related to past corrective actions. Additionally, the NQA Team performed comparisons to the 1998 root cause evaluation of the RC-2 boric acid degradation of body to bonnet fasteners to determine if corrective actions from that event were effective. The NQA Team identified several common factors that contributed to past issues and the current degradation to the RPV head. These were identified in six additional CRs, including CR 02-02578, Oversight Effectiveness, which is the subject of this investigation. The remaining five CRs are being addressed separately.

Condition Report CR 02-02578, Oversight Effectiveness, documented the NQA Team's observation that periodically ISEG and QA were associated with past corrective actions, however they did not effect positive change to aid in the proper resolution of those issues. In addition to citing specific examples, CR 02-02578 indicated that a review of oversight activities should be conducted to validate that current methodologies will not result in the same weaknesses identified in their review. This assessment is being conducted by a second NQA Root Cause Team through an investigation of why the oversight function was not successful in identifying or effecting resolution of issues related to corrosion of the RPV head.

This Root Cause Team was convened under the sponsorship of the Vice President, OPID, on June 24, 2002, to conduct this investigation of oversight activities.

EVENT DESCRIPTION

The station event of concern is the level of degradation of the reactor vessel head that occurred before it was detected. The subject or "event" associated with this investigation is why the oversight function was not successful in identifying or effecting resolution of issues related to corrosion of the RPV head. In this respect, the investigation is focusing on why something did *not* occur. The investigation focuses on the characteristics of a well functioning oversight

organization and evaluates their effectiveness during precursor events and activities. Changes that occurred in key aspects of an effective oversight organization were included in the assessment to determine their impact, if any, on the event.

BACKGROUND DESCRIPTION

D-B is a raised loop pressurized water reactor (PWR) manufactured by Babcock & Wilcox (B&W). The RPV head has 69 control rod drive mechanism (CRDM) nozzles welded to the RPV head. Each CRDM nozzle is constructed of Alloy 600 and is attached to the RPV head by an Alloy 182 J-groove weld. The RPV head is constructed of low-alloy steel and is internally clad with stainless steel. There is a service structure surrounding the RPV head. The bottom of the service structure support skirt has openings called "mouse holes" to permit visual inspections through the use of a pole-mounted camera.

During performance of inspections of the CRDM nozzles during 13RFO, significant degradation of the RPV top head base metal was discovered. The Technical Root Cause Analysis Report concluded that corrosion of the RPV head was caused by boric acid corrosion resulting from CRDM nozzle leakage. The CRDM leakage resulted from through-wall cracking of the CRDM nozzles caused by primary water stress corrosion cracking (PWSCC). That Report also concluded that a reasonable estimate of the time-frame for the appearance of leakage on the RPV head from the CRDM nozzle cracking is approximately 1994-1996, and that the corrosion rate began to increase significantly starting at about 11RFO in 1998 and acted for a four-year period of time. During this period, boric acid accumulated sufficiently and provided the necessary environment to begin significant RPV head corrosion. The pre-existence of accumulation of boric acid from other sources, such as CRDM flange leaks, may have accelerated the corrosion and increased its severity.

Additionally, the Technical Root Cause Analysis Report concluded that the accumulation of boric acid on the RPV head allowed the nozzle leaks to go undetected and uncorrected in time to prevent damage to the head. Boric acid that accumulated on the top of the RPV head over a period of years inhibited the station's ability to confirm visually that neither nozzle leakage nor RPV corrosion was occurring. The Report also noted that other evidence of the boric acid leakage existed in the containment building but its association with possible nozzle leaks was not recognized at the time. This evidence consisted of 1) iron oxide, boric acid and moisture found in containment atmosphere radiation monitor filters, 2) boric acid accumulations in the containment air coolers (CACs), and 3) boric acid accumulations on the RPV flange. While these conditions were all identified at the time, their collective significance was not recognized.

KEY EVENTS

A summary of the key events relative to this specific investigation follows.

QA Summary Trend Reports - These reports were issued periodically, often quarterly, throughout most of the period of interest. The Reports contained assessments and conclusions of station performance as evaluated by the oversight organization.

Audit Reports of Corrective Action Program - These reports were issued periodically throughout the period of interest. These reports contained assessments and conclusions of effectiveness of the Corrective Action Program.

Industry Experience with Boric Acid Corrosion Prior to 1988 - Several incidents of boric acid corrosion (including one event involving corrosion of the Turkey Point RPV head) occurred between the late 1970s and the mid-1980s. These events led to the Nuclear Regulatory Commission (NRC) to issue Generic Letter (GL) 88-05 in 1988. GL 88-05 required each license holder for a PWR to have a boric acid control program. In response to this Generic Letter, D-B issued a boric acid corrosion control procedure in 1989.

Leaking CRDM Flanges in the 1990s - D-B and other B&W plants experienced leakage from the CRDM flange gaskets. As a result, D-B replaced its gaskets over several outages from 6RFO in 1990 through 10RFO in 1996. However, D-B also experienced leaks with the new gaskets in 8RFO (1993), 11RFO (1998), and 12RFO (2000). Thus, in every outage from 7RFO through 12RFO, CRDM flange leakage was identified (either from the original gaskets or the replaced gaskets).

Station commitment to perform head inspections (4/94) - Station investigation concluded that inspections of RPV head were not a commitment; this decision resulted in a change of categorization of the condition to one of "not a significant condition adverse to quality." This change was approved by the QA Director.

10RFO (1996) – One peripheral CRDM flange exhibited signs of leakage during 10RFO. This nozzle exhibited rust/brown stained boron at bottom of nozzle where it meets the RPV head; the head area in this vicinity also has rust/brown accumulation. The boric acid on other parts of the RPV head was powdery and white. The boric acid was very thin at the front edge with powder and small clumps of boric acid on top. Based upon a justification that the boric acid would not impact the RPV head given its high temperature, boric acid was left on the RPV head.

11RFO (1998) – CRDM nozzle 31 was identified as having a minor flange leak, and it was not repaired. Boric acid deposits were identified flowing out of the mouse holes in the southeast quadrant of the RPV head flange. The boric acid was a reddish rusty color. During the removal of boric acid from the RPV head, the boric acid was noted to be brittle and porous. Other than these areas of accumulated boric acid, the RPV head was judged to be basically clean. Based on the 1996 assessment that the boric acid would not impact the RPV head given its high temperature, boric acid was left on the RPV head.

Boric Acid Wastage of Body-to-Bonnet Nuts for RC-2 Pressurizer Spray Valve (1998) - In 1998, two body-to-bonnet flange nuts on RC-2 Pressurizer Spray Valve at D-B were identified as missing. The root cause analysis report for this event concluded that the nuts were missing as a result of boric acid corrosion. The NRC took escalated enforcement action against D-B for this event.

RC-2 Evaluation (1/99): QA concluded, in a Surveillance, that Corrective Actions from RC-2 event were inadequate.

RC-2 Investigation (3/99): RC-2 investigation concluded that QA was not proactive in getting involved with RC-2 issues.

Modification to Service Structure (3/99) - The oversight organization (ISEG) concurred with the planned deferral of a modification which would have facilitated inspection and cleaning of the RPV head.

Performance Based Audit Process (1/00) - During this timeframe, the oversight function began a transition from compliance-based assessments to a mix of compliance-based and performance-based assessments. Performance-based assessments are intended to add increased value to the station by observing the in process performance of activities and may include areas which are outside the requirements of Appendix B.

OA Functional Alignment (2/00) - This refers to a change in organizational structure within the oversight group. This change allowed oversight to dedicate individuals to primary functional areas (e.g., engineering, maintenance, etc.) for a sustained period of time.

12RFO (2000) - Steam cutting occurred on CRDM flange nozzle 31, resulting in boric acid leakage. A pile of boron was identified on top of the insulation. The boron on the RPV head was a red, rusty color and hard. Additionally, boric acid had accumulated on the RPV head flange behind the studs flowing out of the mouse holes in the southeast quadrant. The boric acid had a red, rusty appearance. The cleaning of the RPV head during the outage was not fully successful, and some boric acid deposits were left behind on the RPV head. In interviews, the engineer stated that he was running out of time to continue cleaning the RPV head (the RPV head was scheduled to return to the RPV during the next shift). No written evaluation was performed to allow the boric acid to remain on the RPV head.

Audit of Outage activities, 12RFO (2000) - QA conducted a formal audit of outage activities; the scope of this audit included the Boric Acid Corrosion Control Program. The Audit Report (improperly) recognized thorough cleaning of RPV head.'

Fouling of the Radiation Monitor Filters in 1998-2001 - In 1998, fouling of the containment atmosphere radiation monitor filters occurred. There were boric acid and iron oxide deposits on the filters. The deposits had a "yellow" or "brown" appearance. From May of 1999 until April 2001, filter changes were required on an irregular 1 to 3-week interval (and sometimes once every 1 to 3 days). Accumulation of boric acid on the radiation monitor filters was recognized to be symptomatic of an RCS leak as soon as it occurred. Efforts were made, especially during the cycle 12 mid-cycle outage in 1999 and later during 12RFO in 2000, to locate the source of leakage, but without success. By November of 2001, filter replacements were required approximately every other day.

Containment Air Cooler (CAC) Cleaning in 1998-2001 - In 1998 and 1999, cleaning of boric acid from the CACs was needed nineteen times. Although the boric acid was generally reported to be white, a written post-job critique indicated a "rust color" was noticed "on and in the boron being cleaned away" from CAC 1. In June 2000, CAC plenum pressure again began to decrease, requiring resumption of cleaning. This was followed by five total cleanings in June, August, October and December of 2000. Cleanings continued in 2001, with four more (total) in January, February, March, and May.

FENOC-wide Oversight Organization (1/01) - In January 2001, a FENOC-wide oversight organization was put in place. This organization continued the assignment of oversight

personnel to each station, but brought all management of oversight activities under one Director. This Director reported to the FENOC President, outside the station organizations.

13RFO (2002) – The boric acid degradation of the RPV head was discovered.

Continuous Assessment Process (5/02) - Conversion from assessments which were conducted during well defined, although infrequent, short time periods to a mode of making frequent performance based assessments in numerous areas. This approach was specifically designed to meet the commitments of the internal audit program, while providing flexibility for real-time evaluation of site programs and processes. Effective and timely communication with the line organization was emphasized through frequent periodic debriefs as well as quarterly audit reports. Any identified performance issues were documented and addressed promptly using the site-wide corrective action program.

DATA ANALYSIS

METHODOLOGY

In evaluating available root cause methodologies, the team determined that Event and Causal Factor (E&CF) charting was the most appropriate method for this analysis. This analysis is unusual in that it is establishing the cause of why oversight functions were not successful, i.e., why various activities did *not* occur. Also, the large number of elements of an effective oversight organization combined with the extended time period over which station events occurred led to modifications to the traditional E&CF method. The method used was based on the TapRoot® process, and performed root cause analyses on various opportunities which were present for the oversight function to detect and effect earlier resolution of the degradation of the RPV head. This resulted in some unconventional aspects of the E&CF charting as discussed below.

The steps in the methodology were:

1. Develop Problem Statement and Mission
2. Plan Investigation
3. Collect information (including interviews)
4. Analyze data consistent with the analysis model described below (Detector, Signal Processor, Output, Alarm, Values, Environment) (iterative)
5. Determine sequence of events that occurred within six major functional areas
 - construction of Functional Tool Analysis charts for the five identified time periods
 - develop E&CF Summary Sheets and Detail Sheets for various time periods
6. Identify Causal Factors for the various E&CF sheets
7. Evaluate Causal Factors to identify Root and Contributing Causes
8. Combine the Causal Factors and Causes to eliminate redundancy
9. Develop an integrated E&CF chart for the entire period of interest
10. Identify Generic Causes
11. Develop Corrective Actions
12. Prepare Report (ongoing during earlier activities)
13. Obtain independent peer check of results
14. Resolve comments from peer check process

ANALYSIS MODEL

To facilitate the collection and analysis of appropriate data, a model of the oversight function was defined (See Attachment 1). The oversight function was viewed as being analogous to the feedback circuit for a process controller. A brief discussion of the model is provided to facilitate an understanding of the data collection and analysis process. The model is applied to the overall oversight function as it acts to oversee the management control systems and management organization in the conduct of day-to-day plant operation. The oversight function is the collection of activities taken by the Quality Assurance, Quality Control, and Independent Safety Engineering organizations (with the exception of critical characteristic verification by QC personnel) to ensure station activities are conducted consistent with regulatory requirements and commitments in a safe and reliable manner. The model also captures the influence of management expectations on the oversight functions, to the extent that station management established expectations for performance monitoring above and beyond regulatory minimums.

Process Controller: The management organization and the attendant set of management control systems applied to operating and maintaining the nuclear plant in accordance with its design and licensing bases.

Process Output: The products of the Operating Organization's work activities to operate and maintain the plant consistent with its design and licensing bases. This would include, but not be limited to, maintaining the plant equipment within design limits, compliance with applicable quality programs, and implementing procedures. Typical process variations to be detected and fed back to the process controller would be failures to follow procedures or programs as prescribed, or adverse trends in organization or equipment performance.

Detector (D): As applied to this study, "Detector" was construed to mean any means or method to identify problems or issues with the "Process Output." Typical means of detection would be internal audits, inspections, evaluations, surveillances, and field observations. This would also include review of external audit or inspection results. Likely failures to "detect" would include "misplaced detectors" (e.g., not having auditors or evaluators looking at the right things) and "miscalibrated detectors" (e.g., not properly trained or qualified, or not working to the proper expectations).

Signal Processor (S): As applied to this study, "Signal Processor" applies to the collection, analysis and reporting of "Detected" information regarding the "Process Output." Typical activities conducted in this portion of the feedback model would include signal integration from various "Detector" outputs, and generation of "Output" to the "Process Controller" or, in the event predetermined conditions are exceeded, a "Controller Out of Limits Alarm." Likely failures to appropriately process detector signals would include improper or nonperformance of an analysis of trends in equipment or programs, or a program audit that identifies issues but does not address their significance.

Oversight Process Output (O): The third step in the feedback loop is for the signal processor to provide output or feedback to the control device in the main process, the line organization. This is the oversight organization's opportunity to have a positive influence on the process and must be delivered with the appropriate information in an appropriate manner and then accepted and acted on by the receiving organization. The "Outputs" would normally take the form of Audit Reports, Surveillance Reports, Summary Trend Reports, and/or Condition Reports. In the context of this analysis, failures of the Oversight Process Output are identified when the

oversight organization sends the correct feedback message to the line organization, however, the line fails to take appropriate or effective action.

Values (V): As applied to this study, "Values" applies to the individual, site, and corporate values that tend to establish the expectations for the QA oversight function, and for the line organizations' responsiveness to the QA outputs. Although "Values" do not have a specific failure mode, "Values" establish gains, bias, and set points for the "Signal Processor," "Output," and "Controller Out of Limits Alarm."

Controller Out of Limits Alarm (A): As applied to this study, if the process output signal falls outside prescribed limits and/or is not restored within prescribed time frames an "Out of Limits" alarm is sounded. Typical activities conducted in this portion of the feedback model would include comparison of the output signal (from the signal processor) to pre-established expectations. The most likely failure to "alarm" would include cases where the organization did not react sufficiently to a warning by the oversight organization(s), and the oversight organization failed to escalate the issue, e.g., repetitive shots on the same target.

Environment (E): As applied to this study, "Environment" is limited to those external, indirect influences that could cause the Feedback Circuit to drift from expected performance through mechanisms such as complacency due to good performance reviews. Like "Values," "Environment" does not have a failure mode; rather it influences gains, bias, and set points.

ASSUMPTIONS

As discussed in the Event Description above this investigation involves analysis of why something *didn't* happen, (i.e., why the oversight function was not successful in identifying or effecting resolution of issues related to corrosion of the RPV head). To facilitate the analysis, the following assumptions were made by the Team.

Assumption 1: If the "Rational Person" had knowledge of the Reactor Vessel head leak, he/she would have acted to mitigate the condition.

Assumption 2: The Oversight Functional Organization can be modeled as the "Rational Person."

Assumption 3: The Oversight Rational Person had two distinct opportunities to significantly alter the ultimate outcome:

- a. Assure through proper oversight functions that the processes used by the Line Rational Person were sufficiently robust and effectively used to detect and mitigate the condition.
- b. Direct detection and action to mitigate the condition.

Assumption 1, although appearing obvious, establishes a precept of this investigation that there was no willful or intentional attempt to allow the head to continue to degrade by any person having knowledge of the condition of the head. The second assumption simply extends assumption 1 to an organizational level within the oversight organization. Assumption 3 builds upon the first two assumptions and reflects the opportunities available to individuals within the oversight organization and hence the organization as a whole to have effected resolution of the head issue.

During the course of the investigation, conclusions are drawn for different time periods regarding the ability of the oversight organization to have effected resolution of the issue through the opportunities stated in assumptions 3a and 3b.

DATA COLLECTION

Data collection began with the development of a listing of sources with the likely potential of identifying flawed detection, signal processing, output, and alarms. This was supplemented with likely sources of information that might reveal environmental influence or values that may have impacted the design or operation of the feedback process.

Once potential sources were identified, selection criteria for choosing documents and the associated attributes to review for were developed. Team members were assigned to document groupings, to review and capture pertinent data from the documents. This included development of a brief statement to explain the relationship between the data and potential impact on the Feedback Model, if any. This included a subjective assessment on whether the data was likely to have had a direct or indirect impact on the reactor head degradation event, and which element of the Feedback Model was affected. This data was tabulated in the CR 02-2578 Integrated Database (an Excel spreadsheet) to facilitate electronic binning and sorting by codes and dates. Data was then reviewed by the Team collectively to peer check logic and coding. The data was then transferred to a working timeline consistent with the timeline developed by the NQA Team.

The Team reviewed the following data in order to gain insight as to the efficacy of the QA oversight functions. The selection criteria for documents to be reviewed and the review criteria are contained in the Methodologies Employed section of this report. The CR 02-2578 Integrated Database contains a tabulation of documents reviewed and other pertinent information developed by the Team from the following data set.

- Audit Reports: Selected Audit Reports for the period 1/1990 through 2/2002.
- Surveillance Reports: Selected Surveillance Reports for the period 1/1990 through 2/2002.
- QA Summary Reports (These reports changed titles a number of times over the period of review) for the period 1993 through 1996, 1998 through 2001. No reports could be located for 1997.
- ISEG Reports and miscellaneous ISEG correspondence for the period 1990 through 2000.
- NRC Inspection Reports for the period 1/1990 through 5/2002.
- Miscellaneous Documents – these documents were developed from sources while performing primary reviews, or from interviews conducted with QA and Line Management Personnel
- Interviews of QA Personnel and a sampling of other Station Personnel were conducted using the questions contained in Attachments 8 and 10. Attachments 9 and 11 provide a list of persons interviewed, and the CR 02-2578 Integrated Database contains a summarization of the interview results.

FUNCTIONAL TOOL ANALYSIS CHARTS

Due to the unique nature of this investigation, e.g., trying to determine why something *did not happen*, the Team chose to define two distinct types of “Events.” The first being the most significant to this Root Cause Analysis is described as a “Missed Opportunity Event,” and the second is an “Event” derived by a slight modification to a TapRoot® Event.

Missed Opportunity Event (MOE): circumstances related to oversight, which existed and had the opportunity to preclude or mitigate the reactor vessel head corrosion, but were missed. For this to be true, there needs to have been a reasonable opportunity for oversight functions to have precluded the failure of a particular barrier. Oversight organizations did have or reasonably should have had the information available to them. There needs to have been an oversight breakdown; either an oversight-type barrier was there and failed, or should have been there and wasn't.

The selected MOEs represent windows of time, during which, in the subjective opinion of the team, sufficient information was available and could or should have been recognized as indication of the impending or ongoing degradation of the RPV head. The time periods typically are tied to plant outages when significant additional information usually became available. As the MOEs move forward in time and the available information changes, the causes associated with the missed opportunity may also change. In order for the oversight function to have had a positive effect on detection of the head condition very early, different programs/processes/values would have had to been functioning effectively than at a later point in time when more definitive indications of the problems existed. The time periods chosen by the Team as MOEs are:

- The time period from the late 1980's up to the start of 10RFO
- The start of 10RFO through the end of 11RFO
- The end of 11RFO through the end of the Mid-Cycle Outage of 1999
- The end of Mid-Cycle Outage of 1999 through the end of 12RFO
- The time period after 12RFO

Event: an action or activity in the sequence of events (SOE) leading to a Missed Opportunity Event or an Incident.

The investigation considered many facts, covering a significant time frame (16 years, 1986 – 2002). In order to better assess the various influences which were dominant during the various periods, the team adapted Event & Causal Factor (E&CF) charting to allow closer assessment of the issues. To do this, the term "Functional Tool Analysis" was coined by the team. It represents a variation on traditional E&CF charting. The Team identified six major programmatic tools used by line management and/or the oversight organization that could and should have been effectively used to lead to an earlier detection of the degrading condition on the RPV head. Each of the following functional tools was represented graphically by a horizontal slice for each MOE on the Functional Tool Analysis chart:

- **Corrective Action Program (CAP)** – the procedures and processes used to identify, document, evaluate, and correct problems. While this includes procedures and computer software tools, the primary focus is its implementation for resolution of problems.
- **Root Cause Analysis (RCA)** – the procedures and processes used to perform root cause analysis, and their resultant products. Although this is a sub-set of CAP, the importance of RCA to the effectiveness of CAP caused the Team to evaluate it separately, as well as within the CAP itself.
- **Operating Experience (OE)** – the collective process of obtaining, evaluating, integrating and acting on experience from the rest of the industry, as well as D-B experience, to prevent conditions adverse to safe operation.

- **Trend / Analysis (T/A)** – the process of collecting, summarizing, analyzing various data to detect adverse trends in station performance (both process and hardware) that require further investigation and/or action to mitigate.
- **Audits / Surveillance / and Evaluations** – the traditional tools used by QA Auditors or ISEG Engineers to evaluate processes or conditions.
- **Culture / Values (C/V)** – the collective philosophy as demonstrated by actions of an individual or entity. It represents the approach to dealing with issues and affects decision-making and actions of the organization, both collectively and individually, when faced with certain conditions or situations. This especially applies to the establishment of priorities when faced with competing objectives.

Attachments 3 through 7 are the completed Functional Tool Analysis charts. Each attachment covers one of the five time periods and includes a cover/summary sheet and attached detail sheets for each of the six Functional Tool Analyses.

Event and condition data collected from the data review was organized into the individual functional tool analysis for each MOE. For each functional tool analysis a set of concluding “WHY” statements was developed and are represented by a black triangle in the upper right hand corner of the appropriate box on the chart. These “why” statements were used to develop causal factors in a manner similar to traditional Event & Causal Factor charting. Near the end of the investigation, the team developed a standard E&CF chart using the key factors identified through analysis.

DATA REVIEW

Note: during this review the team was exposed to significant amounts of information. Much of the information was intertwined between the line organization and the oversight function. During the period of this investigation, another Root Cause Team was investigating management contributors to the degraded RPV head. The two teams shared significant amounts of information. On occasion, this team developed observations and suggestions on corrective actions related to improving effectiveness of line activities. When this occurred, such observations/suggestions were provided to the other team. Several recommendations related to methods that could improve the line’s ability to manage corrective actions.

The accumulated data in the CR 02-2578 Integrated Database represents over 400 individual facts and relevant observations in support of this evaluation. The Functional Tool Analyses discussed above were used to categorize each item into the associated time period and area of the assessment. The five time periods with six functional tools in each period represent thirty separate analyses. Each analysis is in effect its own E&CF chart with identification of causal factors for that functional tool in that time period. The intent of each analysis is to ascertain the contribution of each given functional tool (e.g., CAP, Culture/Values, Trend/Analysis, etc.) to the failure of the oversight organization to identify and effect resolution of issues related to corrosion of the RPV head in the given time period.

As an example in referring to Attachment 3, under the Culture/Values Functional Tool Analysis, it can be seen that the team concluded that QA’s failure to be the station nuclear safety conscience is considered a causal factor in why the CRDM nozzle leakage was not detected prior to 10RFO.

In order to construct the Functional Tool Analysis charts, it was necessary to review each data item in the CR 02-2578 Integrated Database and assign it to the appropriate Functional Tool(s).

Each of the data items in a given Functional Tool was then evaluated and a "mini" E&CF chart prepared. Examples are shown on the detail sheets of Attachments 3 - 7. A conclusion regarding the causal factor(s) associated with each of the six Functional Tools in a given time period was then summarized in the large box to the right of each Functional Tool Analysis Detail sheet and carried forward to the summary page for the time period. The 27 "why" or causal factor boxes on the time period summary sheets are the causal factors carried forward into the causal factor analysis below.

Each time period was evaluated using the information from the Functional Tool Analysis sheets. A conclusion was drawn for each Functional Tool for each time period relative to Assumptions 3.a and 3.b discussed earlier. The intent of the individual conclusions was to answer the questions:

For Assumption 3a: "Was there sufficient information and opportunity available in this area during this time period for the oversight organization to have influenced the line organization in a way that would have allowed them to identify the head degradation."

For Assumption 3b: "Was there sufficient information and opportunity available in this area during this time period for the oversight organization to have directly identified the head degradation."

An overall conclusion for the time period was also drawn and documented in the large box in the center of the Summary sheet.

Through the data review and analysis described above, a number of causal factor themes began to emerge. As the analysis progressed from time period to time period, similar causes were seen and in some cases became more pronounced. New causal factors were also identified during later time periods when new or additional information on the head degradation became available. When the analysis of each of the five time periods was complete, an overall review of the results was performed, and the 27 initial causal factors were consolidated into the eight formal causal factors described herein. Through the data review and analysis, a number of key events and issues became apparent as significant contributors to the formal causal factors. Central to these key events and issues was the poor implementation of the corrective action program over the complete time period addressed by this analysis.

10CFR50 Appendix B, Criterion XVI specifically requires that the cause of significant conditions adverse to quality be identified and corrective action taken to preclude repetition. Two of the aspects which influence the success of an organization in meeting this requirement are the corrective action program which is in place, and the actions of those who use the program. Although the D-B program underwent substantial change during the era of concern (1986 - 2002), the team found no data that indicated that the program itself contributed to lack of success by oversight.

Rather, the actions of the station team did not accomplish the desired result. Opportunities to identify and prevent significant RPV head degradation were present for both the line organization and the oversight function. The team concluded that achieving a clear understanding of issues, making effective decisions regarding fixing abnormal conditions, effectively using industry operating experience (including D-B's own experience), and effectively analyzing station trends could have identified the issue early enough to have prevented substantial head degradation.

[SUPPORTIVE OF CAUSAL FACTORS: 1, 2, AND 7]

The failure of the oversight function to effectively challenge station theories regarding the causes and effects of boron on the RPV head (including other indications in containment) contributed

heavily to oversight's inability to cause effective resolution of issues. The inability to successfully interject was caused primarily by a culture in the oversight function that mirrored that of the station. Degradation in station standards occurred in both the line organization and the oversight organization. Use of compliance based audits during most of this period resulted in an emphasis on meeting administrative requirements, rather than ensuring station conditions were fixed. As more and more data became available, especially during refueling outages, the opportunities increased to draw the conclusion that a significant issue was not being resolved. Although, the effectiveness of the oversight function in identifying issues began to increase in 2000, several factors worked to render this improvement of modest value. Responsiveness of the line organization was less than adequate, the success of the oversight organization in escalating issues was less than adequate, and the oversight organization missed opportunities to clearly identify the issue. [SUPPORTIVE OF CAUSAL FACTORS: 1, 2, 3, and 5]

Several key opportunities existed for oversight to have used information in the corrective action program to address weaknesses in station performance as follow:

① Operating Experience: A 1987 D-B Independent Safety Engineering (ISE) memo (ISE 87-10049, dated 5-28-87) indicates that a major effort was made to become knowledgeable of both the Turkey Point-4 and the ANO-1 boric acid corrosion events in that era. The ISE memo documented that high temperature boric acid corrosion can occur up to 600°F, and that boron carries over in steam. Although the station was aware of numerous additional industry letters and NRC communications that occurred over the years, the temperature environment information was lost. It appears that much of the basis for decisions made in the 1990s was a belief that boric acid corrosion could not occur at D-B operating temperatures ($T_{AVE} \sim 580^{\circ}\text{F}$). The opportunity was present for the oversight function to resurrect this information and challenge the station.

[SUPPORTIVE OF CAUSAL FACTOR: 7]

② PCAQR 96-0551 addressed issues of boric acid on the RPV head identified in 11RFO. The investigation phase of this PCAQR was not completed until after 11RFO, more than 2½ years after it was initiated. During that time, two root cause reports were drafted but not completed and the PCAQR was eventually downgraded and closed without addressing the issue. The second of the root cause reports was prepared by ISEG indicating that they were involved in the resolution of the PCAQR. PCAQR 98-0767 documenting boric acid found on the RPV head during 11RFO was closed to PCAQR 96-0551, negating an additional opportunity to address the issue. [SUPPORTIVE OF CAUSAL FACTOR: 1]

③ RC-2: RC-2 is a pressurizer spray valve that experienced boric acid corrosion in 1998 (see CR 98-020). This event provided several opportunities for the oversight function; two examples:

- Tracking and trending: at the very time the root cause evaluation of CR 98-020 was closed (3-30-99), the station was five months into heavy cleaning of the containment air coolers. This was an opportunity for the oversight group to press the issue to get a clear understanding of what was going on in containment. Although the phenomena was complicated strongly by cultural beliefs, a high value on problem resolution at this point would likely have led to the proper understanding of the phenomena. [SUPPORTIVE OF CAUSAL FACTOR: 4]
- Corrective actions: Numerous corrective actions were identified as a result of this event; two were assigned to the oversight function. The event itself provided an opportunity for oversight to key in on boron and ensure that corrective actions were effectively implemented, and that thorough extent of condition reviews were completed. Team analysis of the actions resulting from this situation, however, concluded that the corrective actions were largely

ineffective. Even the actions assigned to oversight lost significance within 3 years. Interviews with current oversight personnel showed that although many had heard of the event, few behave differently today as a result of it. The opportunity to challenge the effectiveness of the corrective actions, and particularly the formal effectiveness review completed by Quality Programs/Quality Improvement Unit (Memo dated 10-27-00), were missed.
[SUPPORTIVE OF CAUSAL FACTOR: 1]

④ CR 98-1904 was a station wide assessment of 10 events that occurred in 1998 and indicated an overall decline in station performance. The results of the assessment should have made substantial improvement in key processes and activities such that the head degradation would have been identified sooner, however, it appears that despite the corrective actions from this CR, little overall improvement was made. [SUPPORTIVE OF CAUSAL FACTOR: 1]

⑤ CR 99-1300 addressed containment radiation monitor clogging issues. Over the course of addressing this issue, the station took a number of actions to address the symptoms of the issue but did not aggressively pursue the cause. Actions included installing temporary HEPA filter units in containment and modifications to the radiation monitor system. Actions on this issue combined with addressing the more frequent cleaning of the containment air coolers reflect an approach that addressed symptoms rather than the causes. [SUPPORTIVE OF CAUSAL FACTOR: 1]

⑥ Refueling outage audit, 2000 (AR-00-OUTAG-01, dated 6-7-00): 12RFO came only four months after key training initiatives related to the RC-2 event had been completed. Part of the scope of this audit was evaluation of the Boric Acid Corrosion Control Program and PCAQ 00-0782. (This PCAQ documented red/brown boric acid found on the RPV head at the start of 12RFO.) Had the training been fully effective, the audit team would likely have taken the initiative to make sure that the RPV head was fully cleaned prior to startup. Instead, the audit team failed to verify claims that the head was clean, and provided positive words in the report regarding the persistence shown by engineering in getting the head clean. Evidence shows that the head was not fully clean, and that some station personnel were aware of that. [SUPPORTIVE OF CAUSAL FACTOR: 6]

As a footnote regarding the 12RFO audit, the investigation team concluded that the audit team was insufficiently experienced in the Engineering functional area. Of the three personnel involved, the supervisor was conducting his first audit, one auditor was a new hire (started employment during 12RFO), and the other auditor was known to be a weak performer. The assignment of such an inexperienced team to review a condition of such significance (BACC program), in hindsight, was less than adequate. However, the team concluded that this was not a cause, in that some management personnel at the station knew of the conditions (i.e., had been to the training and seen the pictures). Given that the oversight function had been unsuccessful in improving performance over the previous years, it was the judgment of the team that a clear identification of the problem at this time in this audit would not have made a difference. Had the oversight function recognized the signs present at the station prior to this outage, they likely would have approached the oversight function differently (i.e., in a more aggressive manner), resulting in a different result from the audit.

⑦ CAP audit, 2000 (AR-00-CORAC-01, dated 6-12-00): during this period, the corrective action program and the oversight function fell under the responsibility of one individual (a director). When the audit team assessing the corrective action program in 2000 concluded that the program had serious weaknesses in construction and implementation, the director caused the message to be softened. He also convinced the Senior Management Team that the audit results exaggerated the weaknesses in the CAP. [SUPPORTIVE OF CAUSAL FACTOR: 5]

The team identified instances where both oversight personnel and management personnel chose not to enter containment during refueling outages based on ALARA considerations. The importance of personal observation as a key element of enforcing standards was not balanced against dose considerations. [SUPPORTIVE OF CAUSAL FACTOR: 8]

The team also considered the oversight methods employed to ensure that the FENOC oversight function itself is effective. As discussed below, there was a weakness at D-B in this area during this period. The checks in place on the oversight functions are external activities such as biannual audits required by external groups (D-B typically used Joint Utility Management Audits), review of station activities by the Company Nuclear Review Board (CNRB), and the Nuclear Regulatory Commission (NRC). [Note that INPO does not currently include the oversight function as part of its scope.] The message from this collective group was inconsistent. NRC and JUMA typically provided a positive message, particularly as it related to the effectiveness of the CAP; CNRB was sometimes more critical. Nonetheless, the effectiveness of this arrangement in ensuring the oversight function was effectively implemented was itself ineffective; it failed to cause the necessary changes at D-B to ensure that the D-B oversight function was executed effectively. [SUPPORTIVE OF CAUSAL FACTORS: 5 AND 6]

An additional consideration that was identified during the investigation was the level of PWR and more specifically B&W experience within the station senior management. The relationship to this investigation is the level to which the oversight organization alters its oversight activity when the level of experience changes. There were key times during the events of this investigation when three of the five site senior managers had little or no PWR experience and a fourth had no B&W experience. During these times there is an increased risk that issues specific to a NSSS vendor may not be completely understood or appreciated. [SUPPORTIVE OF CAUSAL FACTOR 1]

An important activity for the oversight function is the ability to recognize adverse trends in station performance when the line organization does not (i.e., connect the dots). Once an adverse trend is identified, it is equally important to cause the line to recognize and act on the trend. An overview of the events between 10RFO and 13RFO indicates that there were sufficient "dots" to have recognized the head degradation much sooner than occurred. Examples include: PCAQR 96-0551, containment air cooler cleaning frequency, containment radiation monitor filter clogging, CR 00-0782, lessons learned from the RC-2 event, the health of the CAP, NRC Generic Letter 97-01, NRC Information Notice 2001-05, and NRC Bulletin 2001-01. The oversight role relative to trending/analysis should include both oversight of the station's trending/analysis program and performance of independent trending/analysis. It is recognized that oversight does not have the resources to perform the same level of trending/analysis as the station and should therefore perform oversight of that process. However, oversight should also perform independent high level trending/analysis of key issues as a check of the station's trending/analysis. The trending/analysis performed by oversight should be based on a healthy skepticism of station activities, it should be based on oversight's role as the nuclear safety conscience of the organization, and should be structured to identify station issues that need to be addressed at the station/department management level. [SUPPORTIVE OF CAUSAL FACTOR 4]

FACT LIST

The CR 02-2578 Integrated Database provides a compilation of the facts selected by the team for analysis in this investigation. Also, refer to the Five Non-Conformances Integrated Timeline and related information prepared by the NQA Team.

CAUSAL FACTORS

Collectively over the five time periods involved in the analysis, a total of 27 initial causal factors (ICF) were identified. Many of them apply to several periods or are reshaped over time; therefore, the initial 27 were combined as appropriate resulting in a total of eight formal causal factors (FCF). These eight causal factors are:

1. Low standards existed within the oversight function related to management of Corrective Actions. Examples: acceptance of weak cause evaluations by the oversight function; failure of line management to address CAP weaknesses identified by oversight; lack of clear expectations for classification of PCAQRs that address equipment issues on critical safety equipment; ineffective use of CAP data by line and oversight. [This theme developed in CAP/Root Cause Analysis: ICFs 1.1, 2.1, 2.2, 3.2, 4.1, 4.2, 5.2] [FCF 1 contributed to Cause 1]
2. Oversight standards were not set apart from those of the station. As the station increased its tolerance for substandard equipment performance, the oversight function increasingly missed opportunities to influence positive changes in conditions detrimental to safety. Included in this cause is the failure of oversight to recognize the risk of management change and the need to adjust oversight or the environment surrounding problem identification and resolution. The lack of organizational independence between the CAP and the Audit / Evaluation functions also contributed to this cause. [This theme developed over Culture / Values: ICFs 1.6, 2.6, 3.6, 4.6, 5.6] [FCF 2 contributed to Causes 1 and 4]
3. The oversight function was unable to effect change. Examples: Oversight was not sufficiently critical to resolve underlying problems, including the CAP; Oversight failed to escalate issues sufficiently. [This theme developed in CAP: ICFs 3.1, 4.1, 5.1] [FCF 3 contributed to Cause 1]
4. Oversight did not require that a consistent and effective trending and analysis program be defined and documented in terms of content, degree of analysis, format, responsibility, etc. Guidance was not provided on the expected use of information. Clear ownership of trending and analysis was not evident from station behaviors. [This theme developed over Trending / Analysis: ICFs 2.4, 3.4, 4.4, 5.4] [FCF 4 contributed to Cause 1]
5. The oversight process / audit program was not structured for intrusive and aggressive assessment of technical issues. Messages from external oversight were mixed. [This theme developed over Audits/Surveillances/Evaluations: ICFs 2.5, 3.5] [FCF 5 led to Cause 3]
6. The audit program was restructured in terms of organization, however, the expectations of oversight were still not sufficiently defined and/or communicated. The auditor did not raise a concern when reviewing CR 00-0782, despite the training from RC-2. [This theme developed over Audits/Surveillances/Evaluations: ICFs 4.5, 5.5] [FCF 6 led to Cause 2]
7. Expectations for Operating Experience Assessment Program (OEAP) in terms of oversight requirement and responsibilities were not being met. Oversight was not sufficiently critical of the OE program. [This theme expressed in OE Reviews: ICFs 1.3, 2.3, 3.3, 4.3, 5.3] [FCF 7 contributed to Cause 1]
8. ALARA concerns created a reluctance to observe or verify certain field activities; this reluctance affected both oversight and management personnel. [This theme developed in ICF 4.6 and 5.6] [FCF 8 led to Cause 1]

CONCLUSION

The team concluded that the Oversight function did miss opportunities to cause earlier identification and mitigation of the RPV head degradation. The analysis further indicates that standards within the oversight function were insufficiently differentiated from the standards of the station. The root cause was determined to be that D-B's nuclear safety values, behaviors and expectations were such that oversight was not set apart, in terms of expectations and performance standards, from the balance of the station. This affected the ability of the oversight organizations to identify problems and effect needed positive change in station operations. This was particularly applicable to the implementation of the Corrective Action Program and resulted in the station tolerating conditions that were detrimental to safety (boric acid on RPV head and other RCS components, containment air cooler degradation, containment radiation monitor fouling, unexplained RCS leakage) for long periods of time. In evaluating the results of the analysis against the Feedback Model, the team concluded that the predominant problem was that the calibration of the feedback model had drifted to an out-of-tolerance condition. This means that the model was adversely influenced by slow changes in culture within both the oversight function and the line organization. For oversight, these changes included lowering of expectations, reduction in nuclear safety values, and acceptance of lack of response to output. The lack of a healthy escalation process was also noted as contributory, but closely related to inadequate expectations / values. The inadequate expectations / nuclear safety values also affected the Detection function.

The expectations for key programs such as Corrective Action Program, Operating Experience, and Trending/Analysis were not adequately defined in terms of assignment of responsibilities, results expected from the programs, and the Oversight functions' role relative to these programs. Lack of independence between the Corrective Action Program and the Audit/Evaluation function may have impeded needed management escalation of deficiencies in the CAP. Facts supporting this conclusion include the failure to identify some issues, the failure to correctly apply OE with regards to understanding and evaluating identified issues, the failure to identify relevant causes, the failure to correct issues in a timely manner, the failure to prevent recurrence of the same issues, the inappropriate timeliness of corrective actions, and the failure to properly evaluate the effectiveness of corrective actions. Since these weaknesses occurred across a substantial period of time, through evolving corrective action programs, it is further concluded that the weaknesses were not related to a specific corrective action program but rather to the implementation of the corrective action program (both by oversight and the line organization).

For a period of time, the management of the audit/evaluation process was not independent from the management of the corrective action process. This lack of independence allowed the oversight director to soften the thrust of an audit critical of the corrective action process during 2000.

Oversight did not establish an effective method for assessing the oversight function. The process for providing oversight of the oversight function was less than adequate, feedback provided was mixed, and corrective actions were sometimes ineffective. Over a period of years, assessments from JUMA, CNRB, and NRC were ineffective (did not identify existing issues) and sometimes inconsistent. Follow-up response to identified weaknesses was sometimes less than adequate.

The training for the RC-2 event was ineffective. It failed to improve the ability of both the oversight and line organizations to recognize corrosive conditions and their significance. This

contributed to the failure of the auditing team to raise a concern when auditing the Boric Acid Corrosion Control Program during 12RFO.

Although recent corporate and organizational changes have corrected some of the conditions fundamental to the cause, additional preventive and remedial actions are required. The most significant of these is to take aggressive action to ensure that the nuclear safety standards held by the Oversight organization are appropriately upgraded and held separate and apart from the station to prevent collective or common mode degradation.

EXPERIENCE REVIEW

Industry Operating Experience (OE) was reviewed in an effort to determine if there have been previous instances documented where the oversight organization was not effective in identifying and achieving resolution of significant plant issues. Three groupings of OE documents reviewed were (1) D-B CATS, (2) D-B Condition Reports, and (3) the INPO Website. The D-B and Nuclear Industry searches identified related issues. The results of the review were used to determine if there is a generic, broader scope issue that needs to be addressed and to evaluate the corrective actions taken in response to past occurrences to assure any new corrective actions will be effective.

DAVIS-BESSE CATS

A keyword search on "QA" was performed in Corrective Action Tracking System (CATS) resulting in 141 hits. The subject descriptions were reviewed and hard copies obtained for those that appeared to be related to the issue of oversight's failure to identify and effect resolution of significant plant issues. Most of the CATS items were QA's identification of issues in an audit, surveillance, or self-assessment, and CATS was tracking it to completion. Some other issues were administrative in nature and included documents that were missing signatures, timeliness, and procedure interpretations. Three items were selected for additional review: PCAQR 97-1019 that involved inconsistencies in implementation of QA procedures; CR 99-1889 that addressed INPO's questions regarding the adequacy of a QA surveillance; and CR 00-3108 regarding a reevaluation of a QA Audit closeout review on periodic housekeeping inspections not being performed.

Of these three, only CR 99-1889 is considered relevant to the issues of this investigation. It "questions the adequacy of a QA surveillance completed in May 1999 that evaluated the site's effectiveness in resolving INPO/WANO issues from 1996 and 1998." The CR was categorized as "Important" and investigation identified several management factors that contributed to the inadequate surveillance. Corrective Actions To Prevent Recurrence (CATPRs) included a clearer definition of the surveillance scope, a critique before issuance, a lower threshold for using Condition Reports (CRs), including team members with expertise in INPO assessment techniques, ensuring that there is adequate time given for the surveillance, and using direct communication techniques. These corrective actions likely had some effect on the oversight organization as evidenced by more critical audits beginning in 2000 (e.g., AR-00-CORAC-01); however, other factors identified by this investigation continued to hinder the overall effectiveness of oversight. The issues identified in CR 99-1889 are supportive of the causal factor 1 in this investigation. Associated Recommended Corrective Action 1 amplifies on and expands the management actions taken by CR 99-1889 in a manner that will effectively address the identified issues. No additional action is required as a result of this experience review information.

DAVIS-BESSE CREST

The Condition Report Evaluation and Status Tracking (CREST) system at D-B was implemented in December of 2000. A keyword search was performed in CREST using "QA in the "Title" field. The following five CRs were selected for further review based on a subjective review of the title of the CR.

- CR 01-0426, SA 2000-0126 1999 JUMA QA Audit CA
 - CR 01-2226, SA 314NQAP-2001 Results
 - CR 02-0485, NQA SA 2001-0120 Areas for Improvement
 - CR 02-1136, Lack of timely review of CR Corrective Actions by QA
 - CR 02-2694, NRC indicating that the QA Boric Acid Inspection Plan was not timely
- Review of these five CRs did not identify any additional considerations that need to be addressed by this investigation.

D-B Condition Reports were also searched using keywords: "NQA ineffective," "QA ineffective," and "QA failure to identify." One additional CR, 01-0427 regarding "Required audit element not performed" was identified for further review. CR 01-0427 was written as a result of self-assessment 2000-0126 and identified that previous corrective actions to address audit scheduling have not been fully effective. The specific issue addressed by the CR was that equipment qualification had not been audited as required since 1994. An extent of condition was performed to evaluate whether other required audits had been missed. The extent of condition review identified nine programmatic elements "which do not appear to have been assessed at an appropriate level or frequency commensurate with their importance to overall program effectiveness." One of these elements was oversight of the Operating Experience Program, which was also identified as weak by this investigation. The extent of condition evaluation indicates recognition by the oversight organization that they should have been more active in the oversight of OE; however, it was not completed until May 2001, and therefore had little effect on the opportunity to affect the RPV head event. It does represent an additional missed opportunity by oversight to have recognized weakness in the OE program sooner when it may have had an impact. The current FENOC continuous assessment process for performing audits and assessments includes comprehensive Master Assessment Plans (MAPs) to control the scope of activities assessed. Assessment of the OE program is included in current MAPs and is also the subject of Recommended Corrective Action 14. Therefore, no additional action is necessary based on this information from the experience review.

NUCLEAR INDUSTRY

The final piece of Operating Experience reviewed with regards to the issue of the "QA inability to identify and prevent" was the INPO Website. A search of the "Just-in-Time" operating experience for "QA" indicated 85 hits but nothing significant with regards to this issue.

Additional searches of the INPO Operating Experience Web Page were performed using keywords: "QA failure," "QA breakdown," "oversight breakdown," "Corrective Action breakdown," "OE Program breakdown," "insufficient QA oversight," and "insufficient quality oversight." No hits were obtained on these keyword searches. On "management expectations" there were 195 hits, on "management expectations and implementation" there were 65 hits, and on "insufficient oversight" there were 51 hits.

The most significant INPO Operating Experience with regards to the issue of the "QA inability to identify and prevent" was found while reviewing the hits on "insufficient oversight" on the INPO "Prevents Events" categories. Under "Quality Programs" a D-B head comparable, although far less significant event, was noted in SEN 163 (a recurring event concerning a high-pressure injection line leak). A cause category for Managerial Methods included insufficient use of operating experience. This again provides indication that earlier recognition of a weak OE

program could have helped the line and oversight organizations improve that program. As discussed elsewhere in this investigation, a stronger more effective OE program would have contributed to identifying the head degradation sooner. This aspect of the issue has been identified by the investigation, therefore no additional action is required from this experience review information.

CONCLUSIONS

In summary, Operating Experience (OE) was reviewed to ascertain if the oversight's inability to identify weaknesses in key line functions and effect positive change had been previously identified. The following examples show where there were opportunities for QA to identify and improve their own processes:

- SEN 163 (4/22/97) --- This SEN provided indication of the importance of an effective OE program. At the time of the SEN and with the information it contained, it is unlikely that a clear connection would be made to the ongoing head degradation.
- CR 99-1889 (12/2/99) --- QA self-identified weakness in their surveillance process and took action to address some management issues. Corrective actions likely had some effect; however, other issues continued to hinder oversight effectiveness.
- CR 01-0427 (2/14/01) --- QA recognized weakness in their audit scheduling process and that nine programmatic elements had not been assessed to an appropriate level. One of these nine was the OE program. Corrective actions at the time of this CR were too late to have a significant effect on detecting the RPV head degradation. Had this been identified sooner, it may have had some effect.

The results of the experience review, while identifying some issues that could have been used in the past to identify and implement earlier corrective actions, determined that there is not a generic, broader scope issue that needs to be addressed. The corrective actions taken in response to past occurrences are complemented and built upon by the corrective actions in this investigation to assure that they will be effective.

ROOT CAUSE DETERMINATION

The following are the root cause and contributing causes addressing the issue presented in the Problem Statement.

ROOT CAUSE

1. Since the mid-1990s, D-B's nuclear safety values, behaviors and expectations were such that oversight was not set apart, in terms of expectations and performance standards, from the balance of the station. This affected the ability of the oversight organizations to identify problems and effect needed positive change in station operations. Examples:
 - Oversight was not set apart in terms of performance standards. This affected their ability to influence station behaviors that tolerated conditions that may have been detrimental to safety.
 - Oversight did not influence the station to manage Corrective Actions so that problems were effectively identified and fixed so as to prevent recurrence.
 - The oversight program was not structured for aggressive and intrusive oversight of emergent technical issues; it was insufficiently challenging of the line organization.
 - Oversight behaviors reflected that ALARA was of higher concern than oversight of field activities.
 - Oversight did not evaluate the risk involved with changes (including management changes) and the potential need to adjust oversight or the environment surrounding problem identification
 - Use of both internal and external operating experience by oversight was not sufficient to result in effective application of this information to identify and prevent problems. Oversight did not effectively oversee the station use of OE nor did oversight adequately incorporate OE into oversight activities.
 - The Trending and Analysis program failed to provide consistency regarding the content, degree of analysis, format, responsibility, expected use of information, and documentation. Failure (of the line organization) to perform effective trending / analysis inhibited the oversight function from using trend/analysis information to prompt the line organization to identify the deficient condition of the RPV head, and from identifying the condition themselves.

CREST Cause Code: H04 Management expectations were not well defined or understood.

TapRoot® Basic Cause Category: Standards, Policies, and Admin Controls (SPAC) confusing or incomplete. The SPAC governing the oversight functions were inadequate to enable oversight to effectively accomplish its objectives.

CONTRIBUTING CAUSES

2. The training for the RC-2 event was ineffective. It failed to improve the ability of both the oversight and line organizations to recognize corrosive conditions and their significance. This contributed to the failure of the auditing team to raise a concern when auditing the Boric Acid Corrosion Control Program during 12RFO.

CREST Cause Code: Q02 Corrective action for previously identified problem or previous event cause was not adequate to prevent recurrence.

TapRoot® Basic Cause Category: Training – Understanding needs improvement.

3. Oversight did not establish an effective method for assessing the oversight function. The process for providing oversight of the oversight function was less than adequate, feedback provided was mixed, and corrective actions were sometimes ineffective. Over a period of years, assessments from JUMA, CNRB, and NRC were ineffective (did not identify existing issues) and sometimes inconsistent. Follow-up response to identified weaknesses was less than adequate.

CREST Cause Code: H04 Management monitoring of activities did not identify problems.

TapRoot® Basic Cause Category: Analysis and Evaluation lacked depth.

4. For a period of time, the management of the audit/evaluation process was not independent from the management of the corrective action process. This lack of independence allowed the oversight director to soften the thrust of an audit critical of the corrective action process during 2000.

CREST Cause Code: H02 Supervisory Methods.

TapRoot® Basic Cause Category: Analysis and Evaluation not independent.

EXTENT OF CONDITION

Although the specific driver of this investigation was boric acid corrosion of the RPV head, the investigation itself was on the efficacy of the D-B oversight functions as they related to that condition. The investigation examined the causes for missed opportunities for oversight functions to prevent or mitigate degraded equipment or components. As part of its Building Block plans, FENOC has established program, system, and functional area (organizational) reviews to determine the extent of condition. Specifically:

- The System Health Assurance Plan provides for reviews of systems.
- The Program Compliance Plan provides for reviews of programs.
- The Management and Human Performance Excellence Plan provides for review of functions and organizations.

These reviews will be sufficient to determine the extent of condition of problems in systems, programs, and organizations and, by implication, any significant adverse conditions missed by oversight.

From a FENOC perspective, the extent of condition might extend to the oversight functions at both Beaver Valley and Perry. Therefore, an assessment is recommended (see Corrective Action 17) to determine whether similar problems exist at those plants. The assessment should focus on the evaluating whether those plants have problems similar to the root causes identified in this report and the Root Cause Analysis Report for the failure to identify the significant degradation of the RPV head.

Finally, FENOC is performing an assessment of the adequacy of the CNRB, which will be sufficient to determine whether CNRB has been similarly affected.

RECOMMENDED CORRECTIVE ACTIONS

Note: Considering that this CR documents a situation where a function was unsuccessful in identifying or effecting resolution of a significant issue, any corrective actions will be geared to successful identification or resolution of issues within some time period. The Team felt that a significant issue (such as corrosion of the RPV head) should be identified and resolved as early as reasonably possible. In this particular case, the Team felt that identification and resolution during time Period 2 (extending from start of 10RFO to end of 11RFO) should be expected. The Recommended Corrective Actions, then, are geared toward ensuring that, in the future, the oversight function will successfully identify and effect resolution of significant issues based on the type and nature of information which was available during Period 2.

Note: Since the oversight function at D-B is integrated into a single department that provides oversight for the other FENOC stations, it is recommended that the corrective actions for oversight be incorporated across all three stations.

Note: The FENOC Change Management Policy should be considered in implementation

Preventive and Remedial Actions

CAUSE 1

Since the mid-1990s, D-B's nuclear safety values, behaviors and expectations were such that oversight was not set apart, in terms of expectations and performance standards, from the balance of the station. This affected the ability of the oversight organizations to identify problems and effect needed positive change in station operations.

ASSOCIATED CORRECTIVE ACTIONS:

1. Preventive Action (PR). **Complete**

Create a new position of Vice President, OPID, reporting outside the station organization. Staff this position with an individual who has demonstrated high standards for safety and rigor, and is capable of providing leadership to enhance the values, behaviors, and expectations of OPID.

2. Preventive Action (PR). Owner = OPID / LWPearce

Establish, document, communicate and hold OPID personnel accountable to expectations that support the ability of OPID to detect adverse conditions, process information, and escalate issues in a manner that ensures they are resolved in a timely fashion. The elements of this action include:

- benchmarking of the industry for corresponding expectations
- revision of the OPID Business Plan and appropriate implementing documents to address these expectations
- face-to-face meetings on expectations by the OPID management team with OPID personnel using lessons learned from the D-B RPV head degradation event, and this root cause analysis to demonstrate the values by management
- continued frequent reinforcement of the expectations by OPID management.

The goal of this corrective action is to elevate the ability of OPID to cause positive change to occur at FENOC stations when warranted. The expected changes include:

- emphasis on the importance of 10CFR50 Appendix B Criterion XVI regarding management of corrective actions; this expectation should highlight that the goal is to identify and fix problems (both equipment and process) to prevent recurrence, as opposed to emphasizing programmatic processing and tracking
- emphasis on the importance of operating experience (both external and internal) in developing a full understanding of a condition
- defining the role of the oversight organization relative to trending and analysis of station conditions. An expectation should be provided regarding how the oversight function will utilize trend and analysis to accomplish its role. The oversight function should provide oversight of trending performed by the station, and also perform independent high-level trending of key issues as a check on the effectiveness of the station's trending. Although it is recommended that the station line organization remain responsible for performance of trending and analysis, development of this expectation should review this arrangement for compatibility and achievement of the oversight function.
- modification of OPID values to emphasize the importance of problem identification and resolution; adopt an OPID policy of zero tolerance for indication that problem identification and resolution is being discouraged by management behaviors
- expectations for performance based assessment to critically assess activities and issues beyond Appendix B compliance, including emergent issues and effective use of OE, and accountability for same when information is available
- emphasis on the importance of intrusive oversight and aggressively (yet professionally) challenging the organization to resolve issues
- expectations for the process for escalating issues, emphasizing raising controversial issues to management in reasonable and timely manner; and for dealing with differing professional opinions
- expectations for adjusting the amount and method of oversight when changed conditions produce a change in station risk
- an expectation regarding when to assess in-process activities; examples include critical evaluations of station components, decision-making meetings affecting safety, restart readiness decisions, decisions to fund or defer modifications, interface between the Company and the NRC, etc.
- emphasis on the potential for complacency within OPID based on positive feedback from external sources. The expectation should reflect the need to balance positive feedback from external sources with the need for continual critical self-assessment. (This is also related to CAUSE 3)

3. Preventive Action (PR). Owner = OPID / LWPearce

Modify the values of the oversight organization in the OPID Business Plan to set itself apart from the culture of the station, assure that it always maintains the highest standards with regard to a questioning attitude, and continually drive the site organization to a higher level of excellence. Oversight's values should include respect for the reactor core, principal safety barriers, nuclear safety, equipment important to safety, and avoidance of "group think" and "cockpit mentality" (looking inside without considering what the outside is telling you). The oversight organization must maintain sufficient independence in their thought processes that they do not inherit an unhealthy station culture but rather maintain a strong questioning attitude about station activities affecting safety.

4. Preventive Action (PR). Owner = OPID / LWPearce

Provide organization, staffing, tools, training, office location, etc., for the oversight function appropriate to revised expectations; match all elements of resources and expectations.

5. Remedial Action (RA). Owner = OPID / LWPearce
Establish an expectation within OPID and with the FENOC stations that OPID will comply with the ALARA principles, but that these principles (i.e., dose budgets) will not be used as a basis for limiting access to areas for activities deemed important by OPID.
6. Remedial Action (RA). Owner = OPID / LWPearce
Develop and implement a systematic approach to sharing lessons learned from this investigation with both Beaver Valley and Perry organizations. This action includes a face-to-face feedback session with all OPID employees regarding lessons learned for oversight from the D-B head event including focusing on the importance of managing corrective actions, using operating experience, etc.
7. Remedial Action (RA). Owner = OPID / HWStevens
Using industry benchmarking, integrate INPO Warning Flags for declining station performance into measures for evaluating station performance.
8. Remedial Action (RA). Owner = OPID / LWPearce
Develop a plan for allocation of assessment resources during planned outages. The plan is to be tied to and approved by the outage milestone for naming of outage project managers. The plan shall reflect the need to dedicate OPID resources to oversight activities prior to committing to support of line activities.
9. Remedial Action (RA). Owner = OPID / LWPearce
Upon development of changes to expectations of the oversight function, conduct appropriate reviews with line management at each station to ensure that the oversight values and expectations are effectively communicated to the station. Work with station management to ensure that they understand, accept, and embrace the value of an effective and critical oversight organization.
10. Remedial Action (RA). Owner = OPID / LWPearce
Establish methods for formal reinforcement of OPID values on an on-going, periodic basis with OPID employees.
11. Remedial Action (RA). Owner = OPID / HWStevens
Establish a schedule for periodic effectiveness reviews relating to the corrective actions in this CR to ensure that the changes in expectations and values become rooted in the culture of OPID.

CAUSE 2

The training for the RC-2 event was ineffective. It failed to improve the ability of both the oversight and line organizations to recognize corrosive conditions and their significance. This contributed to the failure of the auditing team to raise a concern when auditing the Boric Acid Corrosion Control Program during 12RFO.

ASSOCIATED CORRECTIVE ACTIONS:

12. Remedial Action (RA). Owner = OPID / MAPavlick

Use industry benchmarking to develop performance-based methodologies for OPID to assess the effectiveness of training for both QA and the line organization resulting from emerging conditions (e.g., RC-2 or the D-B head).

CAUSE 3

Oversight did not establish an effective method for assessing the oversight function. The process for providing oversight of the oversight function was less than adequate, feedback provided was mixed, and corrective actions were sometimes ineffective. Over a period of years, assessments from JUMA, CNRB, and NRC were ineffective (did not identify existing issues) and sometimes inconsistent. Follow-up response to identified weaknesses was less than adequate.

ASSOCIATED CORRECTIVE ACTIONS:

13. Preventive Action (PR). Owner = OPID / LWPearce

Develop an improved method for oversight of the oversight function. Institute a formal requirement for findings and issues identified by the selected method to be incorporated into the CAP to ensure tracking and closure. Desired elements of the selected option would be development of performance objectives and criteria, and sharing of industry best practices. Options may include such actions as working with JUMA to develop a more rigorous process to drive oversight to excellence.

CAUSE 4

For a period of time, the management of the audit/evaluation process was not independent from the management of the corrective action process. This lack of independence allowed the oversight director to soften the thrust of an audit critical of the corrective action process during 2000.

ASSOCIATED CORRECTIVE ACTIONS:

11. Remedial Action (RA). Owner = OPID / LWPearce

Reassign responsibilities so that the audit/evaluation function is independent from the CAP. The current organization provides independence between the oversight organization and CAP. However, the assignment of responsibility for the CAP common process to an OPID Manager threatens this independence.

Enhancement Actions

Although the following items might not have prevented the incident from happening, they do have the potential benefit of adding assurance that similar types of events will not occur in the future. While there is not a direct linkage to a specific cause, a reference by the Team to the cause they were originally associated with is provided.

14. Enhancement Action (EA). Owner = OPID / MAPavlick (Refers to Cause 1)
Use industry benchmarking, and add an element to the Common Master Assessment Plan to assess the use of OE as part of the assessment of the appropriate functional areas. This action will require auditors to be familiar with existing OE prior to performing assessment activities.
15. Enhancement Action (EA). Owner = OPID / HLHegrat (Refers to Cause 1)
Benchmark the industry regarding assessment of behaviors (including management) to the scope of OPID tasks. Add assessment of behavior to the appropriate OPID Master Assessment Plans if appropriate definitive guidance is available.
16. Enhancement Action (EA). Owner = OPID / RLHansen, HLHegrat, HWStevens (Refers to Cause 1)
Each OPID NQA section review the ISE function to ensure that OE reviews are fulfilling the commitments made to NUREG-0737.
17. Enhancement Action (EA). Owner = OPID / RLHansen, HLHegrat (Refers to Extent of Condition review)
OPID NQA sections at Perry and Beaver Valley perform an assessment to determine if similar problems exist in the oversight functions at those stations; specifically, problems similar to the root causes identified in this report and the Root Cause Analysis Report for the failure to identify the significant degradation of the RPV head.

REFERENCES

1. Attachment to Nuclear Quality Assurance Examination of Five Closed Nonconformances Related to Reactor Pressure Vessel head.
2. TapRoot® incident Investigation Manual
3. FENOC Root Cause Reference Guide, Rev. 3
4. FENOC Condition Report Cause/Trend Codes

Documents reviewed

As listed in the CR 02-2578 Integrated Database

Personnel contacted

See Attachment 12

Methodologies employed

The overall analysis method was Event and Causal Factor Charting, as modified for this event; refer to Data Analysis / Methodology for details. The principles of TapRoot® were used to the extent practical. The paragraphs below describe the methodologies used for review of various types of station data.

REVIEW METHODOLOGY OF AUDITS AND SURVEILLANCES

The team approach to the review of audits and surveillances was based on provided lists, which sorted these documents as far back as 1990. The lists were reviewed for potential items associated with the identification of boric acid and (Pressurized Water Stress Corrosion Cracking) PWSCC related issues. Other typical audit and surveillance selections included those having a focus on outage activities, operating experience and corrective action. The lists were highlighted to identify desired items for team review. Hard copy of a number of more recent documents was provided by the D-B NQA staff from their file. Additional hard copies of other selected documents were obtained by the team using record searches and the microfilm files located at the D-B Records Center in the DBAB.

The selected items were reviewed by the team to identify audit/surveillance scope, ratings, and issues identified by these documents. Supporting documents such as checklists, PCAQRs, CRs and closure documents were additionally reviewed for several of these items as determined appropriate by the team. A summary of the review of the documents obtained was entered into the team's database. Each item entered went through a group team review as to how each document was related to the review model of detection, signal processing, output, etc., and appropriately coded. This information was then used as input to the overall team conclusions concerning oversight influence of processes that could have led to earlier detection of the RPV head issue as well as self-detection of this issue by oversight.

In addition to the audits and surveillances reviewed, additional keyword searches were performed to find additional information related to the issue of boric acid corrosion. This additional information consisted of various internal and external correspondence, corrective action

documentation (PCAQRs, CRs, self-assessments), procedures, and telephone call documentation. The INPO network and internal D-B information management systems were utilized to extract operation experience information related to the issue. This information was then used as input to the overall conclusion made in this report.

A search of the D-B Nuclear Records Management System (NRMS) was performed. This database contains index entries for the quality and non-quality records maintained by Nuclear Records Management. NRMS was utilized to perform inquiry and retrieval of selected documents. These indexes can be displayed on the terminal screen. The actual record can then be viewed from the specified microfilm cartridge number and frame number of the indexed record.

REVIEW METHODOLOGY OF QA TREND SUMMARY REPORTS AND ISEG REPORTS

QA Reports: Document types selected for review were all QA routine reports to station management that summarized the health of programs, processes, and plant equipment. The time period selected was 1994 through 2001.

The reports were reviewed to determine if QA was consistently reviewing programmatic indications along with the performance of plant systems, structures, and components, to evaluate the effectiveness of the managed systems in operating and maintaining the plant consistent with design and license bases. A subjective assessment of the nature and strength of message to line management was made for each report. This was compared with the factual information on plant performance depicted on the Five Non-Conformances Integrated Timeline, produced by the NQA Team.

ISEG Reports: ISEG records index was reviewed, and documents were selected for retrieval based on the following key words or phrases:

- Routine reports
- Control Rod Drive Mechanism flange leakage
- CRDM leakage issues
- Boric Acid
- Operating Experience Assessment Program
- Operating experience
- Containment fan coolers
- Reviews of engineering products
- Related to PCAQRs or CRs identified on the Timeline

The time period selected for ISEG reports was 1990 through 2000. The primary review was slanted toward the vigor of application of OE, and the ISEG messages being conveyed to line management about performance of systems, structures, and components, versus the factual events depicted on the Five Non-Conformances Integrated Timeline, produced by the NQA Team.

Miscellaneous developed source documents were identified during the review of records found under the above categories. Typically these were specifically referenced ISE correspondence, PCAQRs, QA correspondence, or reports.

REVIEW METHODOLOGY OF TIMELINE

The NQA Team provided the Five Non-Conformances Integrated Timeline, identifying key events related to RPV head degradation, covering the period 12-29-86 to 3-14-02; included was supporting documentation for the key PCAQRs/CRs. This information was

reviewed in its entirety to identify specific mention of activities related to the oversight function, as well as references to additional implications for the oversight function. Any information related to oversight was captured in the team database and evaluated by the team for implications on the oversight role.

REVIEW METHODOLOGY OF PERSONNEL INTERVIEWS

The NQA Team had interviewed 34 individuals, and provided the notes from these interviews; a list of personal interviewed is provided as Attachment 12. Much like the Timeline, this information was reviewed in its entirety to identify specific mention of activities related to the oversight function, as well as references to additional implications for the oversight function. Any information related to oversight was captured in the team database and evaluated by the team for implications on the oversight role.

REVIEW METHODOLOGY OF NRC DOCUMENTS

NRC related documents considered for this investigation included NRC Inspection Reports (IR) and correspondence between D-B and the NRC, both to and from. The initial review was of IRs from 1990 to the present (June 2002). These IR are available in the "NRC Correspondence" file of Folio Views and were identified in that database using a search criteria of "Inspection Report." Each IR was selected to ascertain the subject of the inspection. Those with subjects of: Security, Operator Licensing Exam, License Operator Requalification, Y2K Readiness, Emergency Preparedness, Station Blackout, IST – Response to GL 98-04, and Fire Protection were excluded from further review. The remaining IR were word searched using the following key words with the intent of identifying the corresponding issues:

Key Word	Corresponding Issue
Boric	Boric Acid
Vessel	Vessel Inspection
Alloy	Alloy 600
Leakage	Pressure Boundary Leakage
Reactor Coolant	Reactor Coolant Leakage, Reactor Coolant System Inspection
Head	Head Inspection
BACC	Boric Acid Corrosion Control Program
88-05	Generic Letter 88-05
97-01	Generic Letter 97-01
01-01	Bulletin 2001-01
86-108	Information Notice 86-108 and its supplements
Quality	Quality Assurance
Cooler	Containment Air Coolers
CRDM	Control Rod Drive Mechanisms
Control Rod	Control Rod Drive Mechanisms

Each “hit” on the above key words was reviewed to ascertain pertinence to this investigation. If there was pertinence the IR was flagged as a “trigger” and at least one entry was made into the CR 02-2578 Integrated Database. If appropriate, multiple entries were made. The majority of the reviews were done using the electronic version of the document in Folio Views. For some key reports such as the NRC AIT Inspection report and Resident Inspector’s report for this event, and Resident’s report covering the RC-2 issue, a hard copy was used for review. In addition, the Resident Inspectors reports for the time periods covering 10RFO, 11RFO, and 12RFO were reviewed in hard copy even if there was not a “hit” on a key word. In the cases of these key reports, entries were made into the master database, as appropriate, to denote the lack of information on issues related to corrosion of the head.

For review of correspondence to and from the NRC related to this issue, a key word search of the “NRC Correspondence” Folio Views database was performed using the following: RC-2, Alloy 600, Boric Acid Corrosion, Generic Letter 88-05, and Generic Letter 97-01. Correspondence identified from this search was reviewed primarily to determine Quality Assurance involvement in outgoing correspondence (signature on a buck slip) and distribution of incoming correspondence to Quality Assurance. The overall objective was to determine the level of knowledge and involvement that Quality Assurance had in correspondence between D-B and the NRC related to the head degradation issues. Additional selected correspondence was reviewed as identified during the course of the investigation and entries made into the master database as appropriate.

Team Members

In order to ensure adequate independence of the Root Cause Team, the Team was comprised of personnel external to D-B. However, to maximize the value to FENOC in terms of lessons learned, the Team was staffed primarily by oversight personnel from Beaver Valley and Perry. The Team composition was:

Daniel C. Poole, Senior Management Consultant, Sentco, Inc.

Ronald A. Glus, Advanced Quality Evaluator, NQA Beaver Valley, OPID

James D. Kloosterman, Supervisor Engineering Assessment, NQA Perry, OPID

Russell J. Tadych, Senior Staff Engineer, FENOC Collective Assessment, OPID

Kenneth E. Woessner, Senior Nuclear Evaluator, NQA Beaver Valley, OPID

The NQA Managers at Perry (Henry L. Hegrat) and Beaver Valley (Ralph L. Hansen) supplemented the team. These Managers were the primary interviewers, and provided review of team activities on a real-time basis through daily telephone updates and one-day or two-day visits with the team each week.


ATTACHMENTS

1. Feedback Model Diagram
2. Events and Causal Factor (E&CF) Charts
3. Functional Tool Analysis Chart - Prior to 10RFO
4. Functional Tool Analysis Chart – End of 10RFO through End of 11RFO
5. Functional Tool Analysis Chart – End of 11RFO through End of Mid-Cycle Outage of 1999
6. Functional Tool Analysis Chart – End of Mid-Cycle Outage of 1999 through End of 12RFO
7. Functional Tool Analysis Chart – After 12RFO
8. Standard Interview Questions for Oversight Personnel
9. List of Oversight Personnel Interviewed
10. Standard Interview Questions for Selected Line Management
11. List of Selected Line Management Personnel Interviewed
12. List of Personnel Interviewed by the NQA Team



Attachment 1 – Feedback Model Diagram


Attachment 1


Feedback Model, DB CR 02-2578






Attachment 2 – Event & Causal Factor Chart

































































Legend



= Incident




= Event



= Missed Opportunity Event



= a failed barrier




= Assumption




= Condition




= Deduction from facts; conclusion



= Causal Factor



= Text Symbol above block indicates Comment



= x identifies the time Period (1 through 5)
1: Prior to 10RFO (prior to 4-8-96)
2: 10RFO - 11RFO (4-8-96 through 5-17-98)
3: End 11RFO - Mid Cycle (5-17-98 to 5-10-99)
4: End Mid-Cycle - 12RFO (5-10-99 to 5-18-00)
5: Post 12RFO (after 5-18-00)
y identifies the Functional Tool
1: Corrective Action Program (CAP)
2: Root Cause Analysis (RCA)
3: Operating Experience (OE)
4: Trend / Analysis
5: Audits, Surveillance, Evaluations
6: Culture / Values

Note: some adaptations are made to traditional E&CF charting is this E&CF chart. As a result of the extensive time period involved, and the extensive amount of data collected, key alterations are:

- not every Event is sequenced in timeline order (doing so would overcomplicate the chart); some grouping with Functional Tools is retained
- the depth of the reasons "why" for the events and conditions varies, depending on information available
- use of terminology "Missed Opportunity Events" (see Report); see shaded box (light yellow)
- Use of terminology "deduction from facts (a conclusion)"; see shaded oval (light blue)

The layout of the charts are *generally*:

x.3	x.4	x.5
x.1	x.2	x.6


Note: within any shape block, codes *may* be found in parentheses at the end of information. These codes are of two types:

- numeric only codes [e.g., (87)] identify the Master Tracking Number of the item in the investigation Integrated Database
- alpha-numeric codes [e.g., (H04)] identify the Cause Codes from the Corrective Action Program. Cause Codes are found only in Causal Factors.


Functional Tool Analysis Chart - Legend

Conditions:

Fact



Deduction
(by team from facts)



Events (or Resultant Outcome):



Fact





Deduction
(by team from facts)



Shading:




Grey shading in any box represents input to the overall conclusion drawn for that Functional Tool Analysis.



Cross-hatch shading in any box represents information duplicated and brought forward from the prior period.

Functional Tool Analysis Conclusion:



Each Functional Tool Analysis includes a conclusion for that time period in the type of box shown. The triangle in the upper right-hand corner indicates that this Functional Tool Analysis is a "causal factor".

Summary Sheet Information:

The Summary Sheet for each time period includes each of the shaded boxes from the attached supporting analysis. This includes the smaller "input" boxes and the large "conclusion" box.

- a. Assure through proper oversight functions that the processes used by the Line Rational Person were sufficiently robust and effectively used to detect and mitigate the condition
- b. Direct detection and action to mitigate the condition.

- D08 - Program/Process Weaknesses
- Lack of clear expectations for classification of PCAQs that address equipment failure on critical safety equipment.
- low significance PCAQs for Critical Change redesign.
- CAP not likely to ID

**Missed
Opportun-
Event**

Evaluation of Root Cause Analysis data indicate there was little likelihood of impact during this time period

Station Oversight functions were not successful in identifying or affecting resolution of issues related to corrosion of Reactor Pressure Vessel Head prior to 10RFO


Q04, Industry Review.	Q05, In-House Experiences Expectations for OCAP in terms of oversight requirement and responsibilities are not being met.
Oversight did not connect OE with Internal Plant Events	

Overall Conclusion for this period: It is unlikely that a highly effective program in any one of the functional tools would have allowed detection of the event at this early stage. If the CAP and OE programs were both highly effective and operating in a cultural environment without the weaknesses identified in this analysis, it is possible that the issue could have been identified as early as 10RFO. It would have required knowledge going into 10RFO that the bore acid corrosion on the head was likely to occur and to have looked for it.

Evaluation of Audit, Surveillance, Evaluation data indicate there was little likelihood of impact during this time period

Metallized film frequent CAG clearing is OK	CFOEM Elanco leakage excepted condition.	Miscellaneous ITY (270M) hazard grading is not required	Hack / Worker Accountability No evidence of compliance for standards equipment performance. The oversight function increasingly misused opportunities to influence positive change in conditions detrimental to safety.
--	---	---	--


1.1 Corrective Action Process Detail - Prior to 10RFO



1.1.2 Root Cause Analysis Detail - Prior to 10RFO


Little likelihood of impact during this time period.

1.1.3 Operating Experience Process Detail - Prior to 10RFO



Functional Tool Analysis Chart - Detail Sheet - Period 1 - Prior to 10RFO (4/8/96)

1.4 Trend / Analysis Detail - Prior to 10RFO




HOI Management Expectations:
Expectations in terms of content, degree or analysis, format, responsibility etc. must be defined to achieve the desired result.
Guidance about any future expected use of information.

Causal Factor → HOI Management Expectations. Policy guidance, management expectations were not well defined or understood.
Human Perf. → Trend analysis (Relationship with CA, RCA)

1.5 Audits, Surveillance, Evaluations Detail - Prior to 10RFO

Little likelihood of impact during this time period.

1.6 Culture / Values Detail - Prior to 10RFO



HOI Worker Accountability:
As the station increased its tolerance for increased risk, it also created opportunities to influence positive change in conditions detrimental to safety.

Causal Factor → HOI Worker accountability. Personnel exhibited insufficient awareness of impact of actions on Nuclear Safety or Reliability.
Human Perf. → Roles & responsibilities. Safety philosophy. Management expectations.

1. The first part of the document is a list of names and their corresponding dates. The names are listed in a column on the left, and the dates are listed in a column on the right. The names are: John Doe, Jane Smith, and Bob Johnson. The dates are: 1990, 1991, and 1992.

2. The second part of the document is a table with two columns. The first column is labeled "Name" and the second column is labeled "Date". The table contains the following data:

Name	Date
John Doe	1990
Jane Smith	1991
Bob Johnson	1992

3. The third part of the document is a list of names and their corresponding dates. The names are listed in a column on the left, and the dates are listed in a column on the right. The names are: John Doe, Jane Smith, and Bob Johnson. The dates are: 1990, 1991, and 1992.

4. The fourth part of the document is a table with two columns. The first column is labeled "Name" and the second column is labeled "Date". The table contains the following data:

Name	Date
John Doe	1990
Jane Smith	1991
Bob Johnson	1992

5. The fifth part of the document is a list of names and their corresponding dates. The names are listed in a column on the left, and the dates are listed in a column on the right. The names are: John Doe, Jane Smith, and Bob Johnson. The dates are: 1990, 1991, and 1992.

6. The sixth part of the document is a table with two columns. The first column is labeled "Name" and the second column is labeled "Date". The table contains the following data:

Name	Date
John Doe	1990
Jane Smith	1991
Bob Johnson	1992

7. The seventh part of the document is a list of names and their corresponding dates. The names are listed in a column on the left, and the dates are listed in a column on the right. The names are: John Doe, Jane Smith, and Bob Johnson. The dates are: 1990, 1991, and 1992.

8. The eighth part of the document is a table with two columns. The first column is labeled "Name" and the second column is labeled "Date". The table contains the following data:

Name	Date
John Doe	1990
Jane Smith	1991
Bob Johnson	1992

9. The ninth part of the document is a list of names and their corresponding dates. The names are listed in a column on the left, and the dates are listed in a column on the right. The names are: John Doe, Jane Smith, and Bob Johnson. The dates are: 1990, 1991, and 1992.

10. The tenth part of the document is a table with two columns. The first column is labeled "Name" and the second column is labeled "Date". The table contains the following data:

Name	Date
John Doe	1990
Jane Smith	1991
Bob Johnson	1992

Functional Tool Analysis Chart - Summary Sheet - Period 2 - 10RFO (4/8/96) through 11RFO (5/17/98)

2.1 Corrective Action Process

<ul style="list-style-type: none"> H2: Supervisory Methods: Line Operator's classification of PCAORs had addressed equipment failure on critical safety equipment. Failure of line management to address CAP weaknesses. Line Operator's classification of PCAORs had addressed equipment failure on critical safety equipment. Failure of line management to address CAP weaknesses. Line Operator's classification of PCAORs had addressed equipment failure on critical safety equipment. Failure of line management to address CAP weaknesses. 	<ul style="list-style-type: none"> CAP Indicators Significance Timeframe RV CA Advisory
--	--

2.2 Root Cause Analysis

<ul style="list-style-type: none"> H2: Supervisory Methods Failure of line management to address CAP Weaknesses highlighted by oversight 	<ul style="list-style-type: none"> Management Information Monitoring did not allow problem
---	---

See contribution to CAP above

2.3 Operating Experience Process

<ul style="list-style-type: none"> OS: Insulin Potency OS: In-House Evidence Expectations for OEAP in terms of oversight Requirement and responsibilities are not being met. 	<ul style="list-style-type: none"> Oversight did not connect OE with Internal Plant Events
--	---

2.4 Trend / Analysis

<ul style="list-style-type: none"> OS: Program Process Weakness Oversight did not require that a consistent be defined and documented in terms of content, degree of analysis, format, responsibility, and time frame for provided on the reported use of the information. 	<ul style="list-style-type: none"> Trending Ineffective equipment issues long term trends
---	--

2.5 Audits, Surveillance, Evaluations

<ul style="list-style-type: none"> Mixed Message may have precluded a more aggressive audit program 	<ul style="list-style-type: none"> It is unlikely that AS would Identify an Engineering error of judgment re the RV Head 	<ul style="list-style-type: none"> AS is compliance based, does not include in-depth functional assessment
---	--	---

2.6 Culture / Values

<ul style="list-style-type: none"> Mindset that frequent CAC cleaning is OK 	<ul style="list-style-type: none"> CRDM Flange leakage accepted condition 	<ul style="list-style-type: none"> 76 - PCAOR 98-551 standing equip. prob ITPO Warning Flag 	<ul style="list-style-type: none"> 75 - PCAOR 98-551 tolerates long ITPO Warning Flag 	<ul style="list-style-type: none"> 98 - Deferred Mod 94-0025 RPV head insp. ports 	<ul style="list-style-type: none"> Station does not value Oversight 	<ul style="list-style-type: none"> Station does not value CAP
--	--	--	--	--	--	--

Missed Opportunity Event

Station Oversight functions were not successful in identifying or affecting change, it would have contributed to the line corrosion of Reactor Pressure Vessel Head RFO - 10 through RFO 11

Overall conclusion for this time period: In RFO-10 and RFO-11 sufficient information became available to detect the head degradation. The CAP is not supporting effective resolution of the issues as evidenced by PCAOR 98-0551. Additional OE is also available. An effective organization should have detected the head degradation in this time period. Station values detracted from the ability of the CAP and oversight to be effective.

Assumption 3: The Oversight Rational Person had two distinct opportunities to significantly alter the ultimate outcome:

- Assure through proper oversight functions that the processes used by the Line Rational Person were sufficiently robust and effectively used to detect and mitigate the condition.
- Direct detection and action to mitigate the condition.

Assumption 3.a

The oversight organization should have been able to detect and effect change to management's low value placed on the CAP.

Assumption 3.b

PCAOR 98-0551 could have led to discovery of the head issue if it had been effectively addressed in a timely manner. ISEG assumed responsibility for this investigation during this time period.

Same as for CAP above.

Had the oversight organization identified the weak OEAP and effected change, it would have contributed to the line identifying boric acid corrosion and Alloy 600 PWSCC as important to track as plant issues.


QA Summary Trend reports could have included equipment issues and accomplished meaningful trend analysis.

Had the audit/surveillance program been structured with functional areas and expectations to go beyond compliance it could have been more effective in identifying and correcting programmatic weaknesses.

When oversight is operating in an environment where neither they nor the CAP are valued, it becomes difficult to detect and effect change. Clearly, the head issue was a closely aligned with the expectations should provide oversight the opportunity to provide positive impact on the station as a whole.

Functional Tool Analysis Chart - Detail Sheet - Period 2 - 10RFO (4/8/96) through 11RFO (5/17/98)

2.1 Corrective Action Process Detail - 10RFO through 11RFO




2.2 Root Cause Analysis - Detail - 10RFO through 11RFO




Functional Tool Analysis Chart - Detail Sheet - Period 2 - 10RFO (4/8/96) through 11RFO (5/17/98)

2.3 Operating Experience Process Detail - 10RFO through 11RFO




Functional Tool Analysis Chart - Detail Sheet - Period 2 - 10RFO (4/8/96) through 11RFO (5/17/98)

2.4 Trend / Analysis Detail - 10RFO through 11RFO




2.2.5 Audits, Surveillance, Evaluations Detail - 10RFO through 11RFO



Functional Tool Analysis Chart - Detail Sheet - Period 2 - 10RFO (4/8/96) through 11RFO (5/17/98)

2.6 Culture / Values Detail - 10RFO through 11RFO



Functional Tool Analysis Chart - Summary Sheet - Period 3 - 11RFO (5/17/98) through End of Mid-Cycle (5/10/99)

3.1 Corrective Action Process

- Oversight ineffective in achieving significant improvement in CAP
- HOK Management Expectations and Worker Accountability
- Oversight was not sufficiently critical to resolve underlying problems, including the CAP

3.2 Root Cause Analysis

- The station continues to miss the mark on CAP and oversight
- HOK Supervisory Methods
- Failure of line management to address CAP weaknesses identified by oversight

3.3 Operating Experience Process

- Oversight did not connect OE with Internal Plant Events
- Q04: Industry Reviews, Q05: In-House Experiences
- Expectations for OEAP in terms of oversight requirement and responsibilities are not being met

3.4 Trend / Analysis

- Trending ineffective, equipment issues long term trends
- Q06: Program/Process Weaknesses
- Q07: Program/Process Weaknesses
- Q08: Program/Process Weaknesses
- Q09: Program/Process Weaknesses
- Q10: Program/Process Weaknesses
- Q11: Program/Process Weaknesses
- Q12: Program/Process Weaknesses
- Q13: Program/Process Weaknesses
- Q14: Program/Process Weaknesses
- Q15: Program/Process Weaknesses
- Q16: Program/Process Weaknesses
- Q17: Program/Process Weaknesses
- Q18: Program/Process Weaknesses
- Q19: Program/Process Weaknesses
- Q20: Program/Process Weaknesses
- Q21: Program/Process Weaknesses
- Q22: Program/Process Weaknesses
- Q23: Program/Process Weaknesses
- Q24: Program/Process Weaknesses
- Q25: Program/Process Weaknesses
- Q26: Program/Process Weaknesses
- Q27: Program/Process Weaknesses
- Q28: Program/Process Weaknesses
- Q29: Program/Process Weaknesses
- Q30: Program/Process Weaknesses
- Q31: Program/Process Weaknesses
- Q32: Program/Process Weaknesses
- Q33: Program/Process Weaknesses
- Q34: Program/Process Weaknesses
- Q35: Program/Process Weaknesses
- Q36: Program/Process Weaknesses
- Q37: Program/Process Weaknesses
- Q38: Program/Process Weaknesses
- Q39: Program/Process Weaknesses
- Q40: Program/Process Weaknesses
- Q41: Program/Process Weaknesses
- Q42: Program/Process Weaknesses
- Q43: Program/Process Weaknesses
- Q44: Program/Process Weaknesses
- Q45: Program/Process Weaknesses
- Q46: Program/Process Weaknesses
- Q47: Program/Process Weaknesses
- Q48: Program/Process Weaknesses
- Q49: Program/Process Weaknesses
- Q50: Program/Process Weaknesses
- Q51: Program/Process Weaknesses
- Q52: Program/Process Weaknesses
- Q53: Program/Process Weaknesses
- Q54: Program/Process Weaknesses
- Q55: Program/Process Weaknesses
- Q56: Program/Process Weaknesses
- Q57: Program/Process Weaknesses
- Q58: Program/Process Weaknesses
- Q59: Program/Process Weaknesses
- Q60: Program/Process Weaknesses
- Q61: Program/Process Weaknesses
- Q62: Program/Process Weaknesses
- Q63: Program/Process Weaknesses
- Q64: Program/Process Weaknesses
- Q65: Program/Process Weaknesses
- Q66: Program/Process Weaknesses
- Q67: Program/Process Weaknesses
- Q68: Program/Process Weaknesses
- Q69: Program/Process Weaknesses
- Q70: Program/Process Weaknesses
- Q71: Program/Process Weaknesses
- Q72: Program/Process Weaknesses
- Q73: Program/Process Weaknesses
- Q74: Program/Process Weaknesses
- Q75: Program/Process Weaknesses
- Q76: Program/Process Weaknesses
- Q77: Program/Process Weaknesses
- Q78: Program/Process Weaknesses
- Q79: Program/Process Weaknesses
- Q80: Program/Process Weaknesses
- Q81: Program/Process Weaknesses
- Q82: Program/Process Weaknesses
- Q83: Program/Process Weaknesses
- Q84: Program/Process Weaknesses
- Q85: Program/Process Weaknesses
- Q86: Program/Process Weaknesses
- Q87: Program/Process Weaknesses
- Q88: Program/Process Weaknesses
- Q89: Program/Process Weaknesses
- Q90: Program/Process Weaknesses
- Q91: Program/Process Weaknesses
- Q92: Program/Process Weaknesses
- Q93: Program/Process Weaknesses
- Q94: Program/Process Weaknesses
- Q95: Program/Process Weaknesses
- Q96: Program/Process Weaknesses
- Q97: Program/Process Weaknesses
- Q98: Program/Process Weaknesses
- Q99: Program/Process Weaknesses
- Q100: Program/Process Weaknesses

3.5 Audits, Surveillance, Evaluations

- Mixed Message may have precluded a more aggressive audit program
- It is unlikely that AS would identify an Engineering error of judgment in the RV Head
- AS is compliance based, does not require functional assessment
- Q06: Program/Process Weaknesses
- Q07: Program/Process Weaknesses
- Q08: Program/Process Weaknesses
- Q09: Program/Process Weaknesses
- Q10: Program/Process Weaknesses
- Q11: Program/Process Weaknesses
- Q12: Program/Process Weaknesses
- Q13: Program/Process Weaknesses
- Q14: Program/Process Weaknesses
- Q15: Program/Process Weaknesses
- Q16: Program/Process Weaknesses
- Q17: Program/Process Weaknesses
- Q18: Program/Process Weaknesses
- Q19: Program/Process Weaknesses
- Q20: Program/Process Weaknesses
- Q21: Program/Process Weaknesses
- Q22: Program/Process Weaknesses
- Q23: Program/Process Weaknesses
- Q24: Program/Process Weaknesses
- Q25: Program/Process Weaknesses
- Q26: Program/Process Weaknesses
- Q27: Program/Process Weaknesses
- Q28: Program/Process Weaknesses
- Q29: Program/Process Weaknesses
- Q30: Program/Process Weaknesses
- Q31: Program/Process Weaknesses
- Q32: Program/Process Weaknesses
- Q33: Program/Process Weaknesses
- Q34: Program/Process Weaknesses
- Q35: Program/Process Weaknesses
- Q36: Program/Process Weaknesses
- Q37: Program/Process Weaknesses
- Q38: Program/Process Weaknesses
- Q39: Program/Process Weaknesses
- Q40: Program/Process Weaknesses
- Q41: Program/Process Weaknesses
- Q42: Program/Process Weaknesses
- Q43: Program/Process Weaknesses
- Q44: Program/Process Weaknesses
- Q45: Program/Process Weaknesses
- Q46: Program/Process Weaknesses
- Q47: Program/Process Weaknesses
- Q48: Program/Process Weaknesses
- Q49: Program/Process Weaknesses
- Q50: Program/Process Weaknesses
- Q51: Program/Process Weaknesses
- Q52: Program/Process Weaknesses
- Q53: Program/Process Weaknesses
- Q54: Program/Process Weaknesses
- Q55: Program/Process Weaknesses
- Q56: Program/Process Weaknesses
- Q57: Program/Process Weaknesses
- Q58: Program/Process Weaknesses
- Q59: Program/Process Weaknesses
- Q60: Program/Process Weaknesses
- Q61: Program/Process Weaknesses
- Q62: Program/Process Weaknesses
- Q63: Program/Process Weaknesses
- Q64: Program/Process Weaknesses
- Q65: Program/Process Weaknesses
- Q66: Program/Process Weaknesses
- Q67: Program/Process Weaknesses
- Q68: Program/Process Weaknesses
- Q69: Program/Process Weaknesses
- Q70: Program/Process Weaknesses
- Q71: Program/Process Weaknesses
- Q72: Program/Process Weaknesses
- Q73: Program/Process Weaknesses
- Q74: Program/Process Weaknesses
- Q75: Program/Process Weaknesses
- Q76: Program/Process Weaknesses
- Q77: Program/Process Weaknesses
- Q78: Program/Process Weaknesses
- Q79: Program/Process Weaknesses
- Q80: Program/Process Weaknesses
- Q81: Program/Process Weaknesses
- Q82: Program/Process Weaknesses
- Q83: Program/Process Weaknesses
- Q84: Program/Process Weaknesses
- Q85: Program/Process Weaknesses
- Q86: Program/Process Weaknesses
- Q87: Program/Process Weaknesses
- Q88: Program/Process Weaknesses
- Q89: Program/Process Weaknesses
- Q90: Program/Process Weaknesses
- Q91: Program/Process Weaknesses
- Q92: Program/Process Weaknesses
- Q93: Program/Process Weaknesses
- Q94: Program/Process Weaknesses
- Q95: Program/Process Weaknesses
- Q96: Program/Process Weaknesses
- Q97: Program/Process Weaknesses
- Q98: Program/Process Weaknesses
- Q99: Program/Process Weaknesses
- Q100: Program/Process Weaknesses

3.6 Culture / Values

- Oversight was not adjusted to compensate for lack of PWR Experience
- CRDM Flange leakage continues as an accepted condition
- Mixed Message may have precluded a more aggressive audit program
- It is unlikely that AS would identify an Engineering error of judgment in the RV Head
- AS is compliance based, does not require functional assessment
- Q06: Program/Process Weaknesses
- Q07: Program/Process Weaknesses
- Q08: Program/Process Weaknesses
- Q09: Program/Process Weaknesses
- Q10: Program/Process Weaknesses
- Q11: Program/Process Weaknesses
- Q12: Program/Process Weaknesses
- Q13: Program/Process Weaknesses
- Q14: Program/Process Weaknesses
- Q15: Program/Process Weaknesses
- Q16: Program/Process Weaknesses
- Q17: Program/Process Weaknesses
- Q18: Program/Process Weaknesses
- Q19: Program/Process Weaknesses
- Q20: Program/Process Weaknesses
- Q21: Program/Process Weaknesses
- Q22: Program/Process Weaknesses
- Q23: Program/Process Weaknesses
- Q24: Program/Process Weaknesses
- Q25: Program/Process Weaknesses
- Q26: Program/Process Weaknesses
- Q27: Program/Process Weaknesses
- Q28: Program/Process Weaknesses
- Q29: Program/Process Weaknesses
- Q30: Program/Process Weaknesses
- Q31: Program/Process Weaknesses
- Q32: Program/Process Weaknesses
- Q33: Program/Process Weaknesses
- Q34: Program/Process Weaknesses
- Q35: Program/Process Weaknesses
- Q36: Program/Process Weaknesses
- Q37: Program/Process Weaknesses
- Q38: Program/Process Weaknesses
- Q39: Program/Process Weaknesses
- Q40: Program/Process Weaknesses
- Q41: Program/Process Weaknesses
- Q42: Program/Process Weaknesses
- Q43: Program/Process Weaknesses
- Q44: Program/Process Weaknesses
- Q45: Program/Process Weaknesses
- Q46: Program/Process Weaknesses
- Q47: Program/Process Weaknesses
- Q48: Program/Process Weaknesses
- Q49: Program/Process Weaknesses
- Q50: Program/Process Weaknesses
- Q51: Program/Process Weaknesses
- Q52: Program/Process Weaknesses
- Q53: Program/Process Weaknesses
- Q54: Program/Process Weaknesses
- Q55: Program/Process Weaknesses
- Q56: Program/Process Weaknesses
- Q57: Program/Process Weaknesses
- Q58: Program/Process Weaknesses
- Q59: Program/Process Weaknesses
- Q60: Program/Process Weaknesses
- Q61: Program/Process Weaknesses
- Q62: Program/Process Weaknesses
- Q63: Program/Process Weaknesses
- Q64: Program/Process Weaknesses
- Q65: Program/Process Weaknesses
- Q66: Program/Process Weaknesses
- Q67: Program/Process Weaknesses
- Q68: Program/Process Weaknesses
- Q69: Program/Process Weaknesses
- Q70: Program/Process Weaknesses
- Q71: Program/Process Weaknesses
- Q72: Program/Process Weaknesses
- Q73: Program/Process Weaknesses
- Q74: Program/Process Weaknesses
- Q75: Program/Process Weaknesses
- Q76: Program/Process Weaknesses
- Q77: Program/Process Weaknesses
- Q78: Program/Process Weaknesses
- Q79: Program/Process Weaknesses
- Q80: Program/Process Weaknesses
- Q81: Program/Process Weaknesses
- Q82: Program/Process Weaknesses
- Q83: Program/Process Weaknesses
- Q84: Program/Process Weaknesses
- Q85: Program/Process Weaknesses
- Q86: Program/Process Weaknesses
- Q87: Program/Process Weaknesses
- Q88: Program/Process Weaknesses
- Q89: Program/Process Weaknesses
- Q90: Program/Process Weaknesses
- Q91: Program/Process Weaknesses
- Q92: Program/Process Weaknesses
- Q93: Program/Process Weaknesses
- Q94: Program/Process Weaknesses
- Q95: Program/Process Weaknesses
- Q96: Program/Process Weaknesses
- Q97: Program/Process Weaknesses
- Q98: Program/Process Weaknesses
- Q99: Program/Process Weaknesses
- Q100: Program/Process Weaknesses

Assumption 3: The Oversight Rational Person had two distinct opportunities to significantly alter the ultimate outcome:

- Assure through proper oversight functions that the processes used by the Line Rational Person were sufficiently robust and effectively used to detect and mitigate the condition.
- Direct detection and action to mitigate the condition.

Assumption 3.a

Although QA did address CAP issues in their audits, the program did not significantly improve. Even if the line did not act on the findings, QA should have continued to press the issues until effective change occurred.

Assumption 3.b

Comprehensive assessment of the issues associated with RC-2 should have identified the significance of the ongoing boric acid issues with the head.

There were multiple examples of weaknesses in the RC-2 process that should have identified the weaknesses and effected improvement.

Had the oversight organization identified the weak OEAP and effected change, it would have contributed to the line identifying boric acid corrosion and Alloy 600 PWSCC as important to track as plant issues.

QA Summary Trend reports could have included equipment issues and accomplished meaningful trend analysis.

Sufficient information is now available to develop a meaningful trend related to boric acid. Plant information from RFO-11 and RC-2 along with available OE should have been connected.

With appropriate technical expertise conducting technical audits, it would have been more likely that the head issue would have been identified.

The station values that have formed regarding the boric acid on the head continue to be reinforced. The values of the oversight organization were closely aligned with the station. Therefore it is difficult to detect the degradation in the presence of these values.

Missed Opportunity Event

Station Oversight functions were not successful in identifying or affecting resolution of issues related to corrosion of Reactor Pressure Vessel Head End of RFO-11 through Mid-Cycle Outage of 1999


Overall conclusion for this time period: RFO-11 through Mid-Cycle more information became available to detect the head degradation, however some of the information was less direct, and may have even masked detecting that the leakage could be related to RPV. The CAP is not supporting effective resolution of the issues as evidenced by PWR-98-1804. Station values detracted from the ability of the CAP and oversight to be effective. An effective organization may have detected the head degradation in this time period.

3.1 Corrective Action Process Detail - End of 11RFO through Mid-Cycle




Functional Tool Analysis - Detail Sheet - Period 3 - End of 11RFO (5/17/98) through End of Mid-Cycle (5/10/99)

3.2 Root Cause Analysis Detail - End of 11RFO through Mid-Cycle



3.3 Operating Experience Process Detail - End of 11RFO through Mid-Cycle




Functional Tool Analysis - Detail Sheet - Period 3 - End of 11RFO (5/17/98) through End of Mid-Cycle (5/10/99)

3.4 Trend / Analysis Detail - End of 11RFO through Mid-Cycle

1. CAC Program / Process weaknesses. The Oversight did not require that a consistent and objective trending and analysis program be defined and documented in terms of methods, metrics, data sources, and responsibility, etc. Guidance was not provided on the expected use of the program.


Causal Factor → BOP Program / Process weaknesses. The content and format of the trend summary reports was changing continually. No written guidance was identified.

Human Perf. → Simple/effective process philosophy.



Functional Tool Analysis - Detail Sheet - Period 3 - End of 11RFO (5/17/98) through End of Mid-Cycle (5/10/99)

3.5 Audits, Surveillance, Evaluations Detail - End of 11RFO through Mid-Cycle



3.6 Culture / Values Detail - End of 11RFO through Mid-Cycle



Attachment 6 – Functional Tool Analysis Chart, End of Mid-Cycle Outage of 1999 through End of 12RFO

Functional Tool Analysis - Summary Sheet - Period 4 - End of Mid-Cycle (5/10/99) through 12RFO (5/18/00)

4.1 Corrective Action Process

QA failed to get adequate management action on CAP

CAP input data was sufficient to support detection of RPV head condition

QA Management Expectations and Program/Process Weaknesses:
Oversight was not sufficiently critical to capture underlying problems, indicating the need for more robust CAP data by the end of the period.

4.2 Root Cause Analysis

RPV continue to experience CAP

QA Supervisory Methods were ineffective. Failure of the management to address CAP weaknesses identified by oversight.

4.3 Operating Experience Process

Oversight did not connect CAP with the Event

QA Industry Philosophy:
CAPS In-Process Expectations:
Expectations for CAP in terms of oversight requirements are not being met.

4.4 Trend / Analysis

Effective Corrective Action in RPV head condition was not completed

QA not ISEG did not adequately analyze plant condition to identify the likely condition of RPV head

QA Management Expectations:
Individual Process Weaknesses:
Oversight did not require that a consistent level of analysis be documented in terms of content, degree of analysis, format, and timing. CAPS were not consistently completed. CAPS were not consistently completed. CAPS were not consistently completed.

4.5 Audits, Surveillance, Evaluations

RPV head condition not consistent to QA

QA Management Expectations:
The audit program was structured in terms of organization, however the expectations of oversight were still not met. The audit did not make a concern when reviewing CR-00-0782 despite the training from RFO-12.

4.6 Culture / Values

RPV head condition not consistent to QA

QA Management Expectations:
The audit program was structured in terms of organization, however the expectations of oversight were still not met. The audit did not make a concern when reviewing CR-00-0782 despite the training from RFO-12.

Missed Opportunity Event

Station Oversight functions were not successful in identifying or affecting resolution of issues related to corrosion of Reactor Pressure Vessel Head End of Mid-Cycle Outage of 1999 through RFO-12

Overall conclusion for this time period: Mid-Cycle through RFO-12: Sufficient information was available to detect the problem. The CAP is not supporting effective resolution of the issues as evidenced by CR 89-1300 on Rad Monitor filter clogging, & CR 00-0782. Station values detracted from the ability of the CAP and oversight to be effective. An effective organization would have detected the head degradation in this time period. Oversight had multiple opportunities in this period. Trend and analysis of plant events & conditions, as well as oversight of the BACCP during RFO-12 were clearly opportunities for detection.

Assumption 3: The Oversight Rational Person had two distinct opportunities to significantly alter the ultimate outcome:
a. Assume through proper oversight functions that the processes used by the Line Rational Person were sufficiently robust and effectively used to detect and mitigate the condition.
b. Direct decision and action to mitigate the condition.

Assumption 3.a Assumption 3.b

QA identified issues associated with the CAP, however, the line did not take effective corrective action. QA should have escalated the issues until resolution was achieved.	Sufficient data was available in the CAP for QA to have detected the issue.
There were multiple examples of weaknesses in the RPA process. QA should have identified the weaknesses and effected improvement.	If an assessment of the RPA process with the boric acid issues was done, it likely could have led to identifying the issue with the head.
Had the oversight organization identified the weak OEAP and effected change, it would have contributed to the line identifying boric acid corrosion and Alloy 600 PWSCC as important to track as plant issues.	For the majority of this period, ISEG was responsible for the overall effectiveness of the OEAP. They could have identified boric acid corrosion and Alloy 600 PWSCC as important to track as plant issues.
Summary Trend reports could have included equipment issues and accomplished meaningful trend analysis. QA could have escalated the need for corrective action in the trending and analysis program.	Sufficient information is now available to develop a meaningful trend related to boric acid including Rad Monitor filter clogging, RCS leak rates still elevated, and change in CAC fouling frequency.
The audit/surveillance program had been structured with functional areas however the process change was in its infancy and more time is needed before the change could have measurable effect.	Sufficient expertise was provided. Audits were tracked on RA, however opportunities were missed in the oversight of BACCP as it applied to CR-00-0782.
Management changes, which occurred immediately prior to or during the period, did change the way the organization approached the problem. In the area of oversight, the attitude toward BACCP on RPV head, also, the degree of change in value of CAP and oversight was not measurably reliable. Hence, oversight did not make changes sufficient to cause detection.	The values of the oversight organization were closely aligned with the station. The value of the oversight organization's performance was inadequate. QA should have been more aggressive in oversight due to excessive concern for ALARA goals. These values may have contributed to the RPV head degradation not being detected.


Functional Tool Analysis Chart - Detail Sheet - Period 4 - End of Mid-Cycle (5/10/99) through 12RFO (5/18/00)

4.1 Corrective Action Process Detail - End of Mid-Cycle through 12RFO

- HQ's Management Expectations and Worker Accountability
- DOE Program Process Weaknesses
- Oversight ineffective in identifying and resolving underlying problems, including line CAP. Ineffective use of CAP data by line and oversight.


Causal Factor → HQ's Management Expectations and Worker Accountability
management follow-up or monitoring of activities did not identify problem.
DOE Program / Process Weaknesses

Human Perf. → Corrective action
Communication (of problem)




Functional Tool Analysis Chart - Detail Sheet - Period 4 - End of Mid-Cycle through 12RFO (5/18/00)

4.2 Root Cause Analysis Detail - End of Mid-Cycle through 12RFO




4.3 Operating Experience Process Detail - End of Mid-Cycle through 12RFO



Functional Tool Analysis Chart - Detail Sheet - Period 4 - End of Mid-Cycle (5/10/99) through 12RFO (5/18/00)

4.4 Trend / Analysis Detail - End of Mid-Cycle through 12RFO




4.4.5 Audits, Surveillance, Evaluations Detail - End of Mid-Cycle through 12RFO



Functional Tool Analysis Chart - Detail Sheet (5/10/99) through 12RFO (5/18/00)

4.6 Culture / Values Detail - End of Mid-Cycle through 12RFO



Attachment 7 – Functional Tool Analysis Chart, Post 12RFO

Functional Tool Analysis - Summary Sheet - Period 5 - Post 12RFO (5/18/00)

5.1 Corrective Action Process

<p>HM: Management Expectations</p> <p>BSC: Management Process Weakness</p> <p>Overight was not sufficiently critical to receive underlying problems. Including the CHC, the management team was not sufficiently. Neither line nor QA are effectively using CAP data.</p>	<p>QM: Ineffective in getting the management action on CAP effectiveness.</p>	<p>CAP: Poor data was sufficient to support detection of RPT+ hazard condition</p>	<p>Station is receiving mixed message re health of CAP</p>
---	---	---	---

5.2 Root Cause Analysis

RCA continues to contribute to ineffective CAP

- HQ's Supervisory Methods
- Failure of line management to address CAP weaknesses identified by oversight.

5.3 Operating Experience Process

[illegible]

5.4 Trend / Analysis

[illegible]

5.5.5 Audits, Surveillance, Evaluations

<p>Hand Message may have anywhere and program</p>	<p>Overseas of CIA experiences outside the requirements of App B II not permitted</p>	<p>Reply Head conditions not dictated by CIA</p>	<p>CIA receives no opportunity to provide information policy info or answer</p>	<p>The adult program was restructured in CIA receives no information and not sufficiently defined and/or communicated; referring CTR 00-0712 requires the training from RQ-2.</p>
---	---	--	---	---

5.6 Culture / Values

[illegible]

Assumption 3: The Oversight Rational Person had two distinct opportunities to significantly alter the ultimate outcome:

- a. Assure through proper oversight functions that the processes used by the Line Rational Person were sufficiently robust and effectively used to detect and mitigate the condition.
- b. Direct detection and action to mitigate the condition.

Assumption 3.a

QA identified issues associated with the CAP, however, the line did not take effective corrective action. Even though QA increased the level of concern, they should have escalated the issues until resolution was achieved.

Sufficient data was available in the CAP for QA to have detected the issue.

Assumption 3.b

Missed Opportunity Event

Station Oversight functions were not successful in identifying or affecting resolution of issues related to corrosion of Reactor Pressure Vessel Head after RFO-12

Overall conclusion for this time period: Post RFO-12: Sufficient information and opportunity were available to detect the head degradation. Plant events and external operating experience should have led to the conclusion that O-B may well have had through wall leakage on CROMs. Oversight had opportunities in this period through trend and analysis of plant events & conditions to raise questions.

Although the oversight organization identified the weak OEAP it was too late to effect change for this time period. Failure to use the existing process contributed to the line not identifying boric acid corrosion and Alloy 600 PWSCC as an important plant issues.

They could and should have identified boric acid corrosion and Alloy 600 PWSCC as an important plant issues.

Summary Trend reports could have included equipment issues and accomplished meaningful trend analysis. QA could have escalated the need for corrective action in the trending and analysis program.

Sufficient information is now available to develop a meaningful trend related to boric acid including Rad Monitor filter clogging, RCS leak rates erratic, and iodine levels and change in CAC fouling frequency.

The audit/surveillance program had been structured with functional areas, and later with DPID. Audit/surveillance were becoming more critical, however escalation of issues had not occurred. Line management's use of the products was also largely unchanged.


There appears to be little opportunity for a direct QDA detection of the RPV condition during the period prior to RFO-13.

In spite of changes in both the Station and Oversight groups, the oversight organization was ineffective in causing a change in attitude toward BA on RPV head.


The values of the oversight organization were closely aligned with the station. The Value of attending & analysis of plant performance was inadequate. CA failed to perform some field oversight due to excessive concern for ALARA goals. These values may have contributed to the RPV selected degradation not being

Functional Tool Analysis - Detail Sheet - Period 5 - Post 12RFO (5/18/00)

5.1 Corrective Action Process Detail - Post 12RFO 12




5.2 Root Cause Analysis Detail - Post 12RFO



Functional Tool Analysis - Detail Sheet - Period 5 - Post 12RFO (5/18/00)


5.3 Operating Experience Process Detail - Post 12RFO



5.4 Trend / Analysis Detail - Post 12RFO



5.6 Culture / Values Detail - Post 12RFO



Attachment 8 – Standard Interview Questions for Oversight Personnel

1. What are the factors for selection of activities for oversight? Who has input to go beyond Appendix B requirements; was internal/external OE used for input? How were these factors documented or communicated in Business Plans, site policies or management expectations?
2. Were the above QA expectations consistently applied through various organizational and management changes?
3. Was oversight activity performed by review of paperwork / historical records, or by actual field observation, or both? How does QA consider work not performed as a part of the evaluation process? Apply same to follow-up to corrective action? Do you feel you have the required technical skills when dealing with hardware / design issues?
4. Are all problems and issues required, by expectations or procedures, to be addressed by entry into the CAP? What is QA's response to any failures to meet such expectations.
5. Regarding interactions with the Line Organization . . .
 - What levels of the line organization do/did you regularly interact with?
 - What is the frequency of that interaction?
 - Would you characterize the interaction as cooperative or contentious / adversarial? Were there any parts of the organization that were consistent in their response, regardless of the issues discussed?
 - Did the level of justification required result in any reluctance to document issues?
 - Do you encounter resistance to use of the CAP to address issues? If so, from whom?
 - What level of intervention, if any, was necessary to resolve conflicts? If intervention by upper management was necessary, was that perceived as a failure of, or as part of, the normal conflict resolution processes?
 - Were the documented responses an accurate reflection of actions taken for a particular issue? Was this consistent, and was it dependent on organization or individuals? How did this result in changes to QA approach to oversight?
6. Over the last two cycles, how was QA viewed by JUMA, INPO and the NRC? How was this perception transmitted to the QA staff and the line organization? What effect did the feedback have on both the QA approach and reception by the line organization?
7. Do collateral assignments affect organizational independence, either individually or organizationally?
8. Historically, what behaviors by QA evaluators have been rewarded by line and QA management?
9. To what degree are the perceptions of line management factored into performance reviews? Did this affect willingness to aggressively pursue issues or problem resolution?
10. Have QA findings been modified / softened to accommodate management desires (either QA or line)? Talked out of writing CRs? If modified, was there a change to the intent or a re-characterization without change to intent?

11. To what degree does management approval determine the outcome of Root Cause Evaluation? Is the evaluation of qualified root cause evaluators changed through the approval process, or are the professional opinions preserved in CAP documentation? Has this ever been evaluated by QA or by outside reviews of the CAP?
12. What is your confidence level in the integrity of the organization when challenged with significant technical or operational issues? Do you have any concerns with the ethics of the organization under these circumstances? What is the level of confidence that the management decisions will not be adversely affected by economic, schedule, or production pressures? If at all, to what degree is it necessary to modify your approach to oversight to compensate for these concerns?
13. Historically, what has been the role of QA (both organizationally and individually) in the restart readiness process? Was QA's role viewed as that of participant or evaluator? Was this role consistent with expectations of line management? Has this been effective in affecting restart priorities or assuring problems were resolved before plant startup?
14. Regarding the RC-2 event . . .
 - Did QA provide in-process oversight of repair activities?
 - If so, were any problems identified, documented, and followed-up by QA?
 - Did NQA evaluate the effectiveness of Corrective Actions for the event?
 - Was NQA included in the population of personnel given follow-up training regarding Boric Acid?
 - Was the RC-2 event perceived by QA/line as a failure of oversight?
 - Did the RC-2 experience change the perception of QA's role in plant activities? What changes to oversight approach and reception occurred, if any?
15. What changes do you see that are appropriate for QA?
16. Any additional comments of any type?

Attachment 9 – List of Oversight Personnel Interviewed

The following individual were in the D-B Oversight Organization at the time of the interview, or were in it during key times associated with events related to the RPV head corrosion issue.

Charles Ackerman, Davis-Besse
Timothy Chambers, Davis-Besse
Edward Chimahusky, former Davis-Besse RCS System Engineer
Clarence DeTray, Davis-Besse
Priscilla Faris, Davis-Besse
Eric Grindahl, Davis-Besse
Mark Koziel, Davis-Besse
Mark Levering, FENOC Collective Assessment Engineer
Mark Pavlick, Davis-Besse
James Ratchen, Davis-Besse
John Reddington, Davis-Besse Quality Assessment Supervisor
Charles Rider, Davis-Besse
H. Kent Rhubright, Davis-Besse
Henry Stevens, FENOC Manager Quality Assurance, Davis-Besse
James Vetter, Davis-Besse Quality Assessment Supervisor
William Wagner, Davis-Besse

Attachment 10 – Standard Interview Questions for Selected Line Management

1. From your perspective as an organization subject to QA oversight, what are the factors for selection of activities for oversight? Who has input to go beyond Appendix B requirements; was internal/external OE used for input? How were these factors consistent with and communicated by Business Plans, site policies or other advertised management expectations?
2. Were the above QA oversight expectations consistently applied through various organizational and management changes?
3. Are oversight activity performed by review of paperwork / historical records, or by actual field observation, or both? (discuss in terms of history and now) In your area is QA involved in evaluation of work not performed as a part of the oversight process? Apply same to follow-up to corrective action (both initiated by QA and those initiated by others)? Do you feel QA organization has the required technical skills or expertise when dealing with hardware / design issues?
4. Are all problems and issues required, by expectations or procedures, to be addressed by entry into the CAP? What is QA's response if they identify any failures to meet such expectations.
5. Regarding interactions with your organization . . .
 - What levels of the line organization do/did QA personnel regularly interact with?
 - What is the frequency of that interaction?
 - Would you characterize the interaction as cooperative or contentious / adversarial? Are there any parts of the QA organization that are/were consistent in their response, regardless of the issues discussed? Are there any parts of your organization that are/were consistent in their response, regardless of the issues discussed?
 - Do the level of justification presented by QA result in any reluctance to accept issues?
 - Do you encounter resistance to use of the CAP to address issues? If so, from whom?
 - What level of intervention, if any, was necessary to resolve conflicts? If intervention by upper management was necessary, was that perceived as a failure of, or as part of, the normal conflict resolution processes?
 - Within your organization, are the documented responses to a CR an accurate reflection of actions taken for a particular issue? Is this consistent, or is it dependent on organization or individuals? Has this resulted in changes to QA approach to oversight of your organization?
6. Over the last two cycles, how was QA viewed by JUMA, INPO and the NRC? How was this perception transmitted to the line organization? What effect did the feedback have on both the oversight approach used by QA and reception by your organization?
7. Do collateral assignments affect QA's organizational independence, either individually or organizationally?
8. Historically, what behaviors by QA evaluators have been rewarded by line and QA management?

9. To what degree are the perceptions of line management factored into QA performance reviews? Did this affect willingness to aggressively pursue issues or problem resolution?
10. Have QA findings been modified / softened to accommodate management desires (either QA or line)? Have QA assessors been talked out of writing CRs? If modified, was there a change to the intent or a re-characterization without change to intent?
11. To what degree does management approval determine the outcome of Root Cause Evaluation? Is the evaluation of qualified root cause evaluators changed through the approval process, or are the professional opinions preserved in CAP documentation? Has this ever been evaluated by QA or by outside reviews of the CAP?
12. What is your confidence level in the integrity of the organization when challenged with significant technical or operational issues? Do you have any concerns with the ethics of the organization under these circumstances? What is the level of confidence that the management decisions will not be adversely affected by economic, schedule, or production pressures? If at all, to what degree is it necessary to modify your approach to oversight to compensate for these concerns?
13. Historically, what has been the role of QA (both organizationally and individually) in the restart readiness process? Was QA's role viewed as that of participant or evaluator? Was this role consistent with expectations of line management? Has this been effective in affecting restart priorities or assuring problems were resolved before plant startup?
14. Regarding the RC-2 event . . .
 - Did QA provide in-process oversight of repair activities?
 - If so, were any problems identified, documented, and followed-up by QA?
 - Did NQA evaluate the effectiveness of Corrective Actions for the event?
 - Was your organization included in the population of personnel given follow-up training regarding Boric Acid?
 - Was the RC-2 event perceived by as a failure of QA oversight?
 - Did the RC-2 experience change the perception of QA's role in plant activities? What changes to oversight approach and reception occurred, if any?
15. What changes do you see that are appropriate for QA?
16. Any additional comments of any type?

Attachment 11 – List of Selected Line Management Personnel Interviewed

The following individuals were in line management positions and interfaced with the Oversight Organization. They were interviewed for their perspective on the functioning of the Oversight Organization during key events related to the RPV head corrosion issue. Mr. Zellers was with the NRC at Davis-Besse during key times.

Howard Bergendahl, former Vice-President, Davis-Besse
David Geisen, Davis-Besse Design Basis Engineering Manager
Mark Haskins, Davis-Besse Supervisor Self-Evaluation Program
William Mugge, Davis-Besse Training Manager
Robert Pell, former Davis-Besse Operations Manager
Michael Stevens, former Davis-Besse Maintenance Manager
Kevin Zellers, Davis-Besse Engineer, Design Basis Engineering

Attachment 12 – List of Personnel Interviewed by the NQA Team

Guy Campbell, former Davis-Besse Vice President
Edward Chimahusky, former Davis-Besse RCS System Engineer
Robert Coad, former Davis-Besse Operations and Radiation Protection Manger
Scott Coakley, Davis-Besse Outage Director
Robert Donnellon, former Davis-Besse Director Engineering and Services
David Eshelman, former Davis-Besse Plant Engineering Manager
James Freels, former Davis-Besse Licensing Manager
David Geisen, Davis-Besse Design Basis Engineering Manager
Prasoon Goyal, Davis-Besse B&WOG Material Committee Representative
Daniel Haley, former Davis-Besse RCS System Engineer
John Hartigan, Davis-Besse Mechanical Engineering
Robert Hovland, former Davis-Besse Radiation Monitor System Engineer
John Johnson, former Davis-Besse Corrective Action Program Lead
James Lash, former Davis-Besse Plant Manager
Peter Mainhardt, performed Davis-Besse Reactor Vessel Head Inspections
Eugene Matranga, Davis-Besse System Engineering
Glenn McIntyre, former Davis-Besse Mechanical Systems Engineer
Kevin McLain, former Davis-Besse Reactor Operator
Steven Moffitt, Davis-Besse Director Technical Services
John O'Neill, former Davis-Besse PCAQRB Chairman
Randy Patrick, Davis-Besse Shift Engineer
Terry Ploeger, Davis-Besse Shift Manager
Michael Roder, former Davis-Besse Shift Manager
Joseph W. Rogers, Davis-Besse Outage Director
Dennis Schreiner, former Davis-Besse Independent Safety Engineering Supervisor
Andrew Siemaszko, current Davis-Besse RCS System Engineer
Rebecca Slyker, Davis-Besse Regulatory Affairs
Dennis Snyder, Davis-Besse Maintenance
Henry Stevens, FENOC Manager Quality Assurance
Lou Storz, former Davis-Besse Vice President Nuclear
Joseph Sturdavant, Davis-Besse Regulatory Affairs
Theo Swim, Davis-Besse Design Basis Engineering
Andrew Wilson, Davis-Besse Maintenance
John Wood, former FENOC Vice President Engineering Services

Enclosure 2

Root Cause Analysis of Operations

Root Cause Analysis Report

Lack of Operations Centrality in Maintaining, Assuring, and
Communicating the Operational Safety Focus of Davis-Besse
and

Lack of Accountability of Other Groups to
Operations in Fulfilling that Role

CR 02-2581

DATE: November 22, 2002

Prepared by: _____

Valerie Barnes

Valerie E. Barnes, PhD
Root Cause Lead

Davis-Besse Sponsor: _____

Mike Roder

Michael J. Roder
Operations Manager

Approved by: _____

J. Randel Fast

J. Randel Fast
Plant Manager

Approved by: _____

Lew W. Myers

Lew W. Myers
Chief Operating Officer

Table of Contents

<u>Title</u>	<u>Page</u>
1.0 Executive Summary	4
1.1 Overall Conclusions	4
1.2 Problem Statement	4
1.3 Event Narrative	4
1.4 Data Analysis	5
1.5 Root Cause Determination	5
1.6 Extent of Condition	5
1.7 Corrective Actions	6
1.8 Experience Review	9
2.0 Problem Statement	11
2.1 Reason for the Investigation	11
2.2 Consequences of the Condition	11
2.3 Actions Already Taken	12
3.0 Event Narrative	13
3.1 Background	13
3.2 Event Narrative	14
4.0 Data Collection and Analysis	17
4.1 Input	17
4.2 Methodology	18
4.3 Results	19
5.0 Root Cause Determination	37
5.1 Root Cause	37
5.2 Contributing Causes	37
5.3 Related Observations	38
6.0 Extent of Condition	40
7.0 Corrective Actions	41
7.1 Corrective Actions for the Root Cause	41
7.2 Corrective Actions for Contributing Causes	42
7.3 Corrective Actions and Proposed Enhancements for Observations	44
8.0 Experience Review	46
8.1 Recent Assessments of Davis-Besse Related to Operations	46
8.2 Related Industry Experience	50
8.3 Differences between Previous and Proposed Actions	54

Table of Contents

<u>Title</u>	<u>Page</u>
9.0 Root Cause Analysis Team	55
10.0 References	57
10.1 Davis-Besse References	57
10.2 NRC References	59
10.3 INPO References	60
10.4 Other References	61

Acronyms

ALARA	As Low As Reasonably Achievable
CAC	Containment Air Coolers
CARB	Corrective Action Review Board
CR	Condition Report
FENOC	FirstEnergy Nuclear Operating Company
GL	NRC Generic Letter
HPEP	Human Performance Evaluation Process
IN	NRC Information Notice
INPO	Institute of Nuclear Power Operations
NRC	Nuclear Regulatory Commission
RFO	Refueling Outage
RO	Reactor Operator
RPV	Reactor Pressure Vessel
RP	Radiation Protection
SRB	Station Review Board
SRO	Senior Reactor Operator
SVP	Site Vice President
VT	Visual Examination
WANO	World Association of Nuclear Operators

1.0 Executive Summary

1.1 Overall Conclusions

Licensed operators' leadership role in station activities at Davis-Besse began to erode in the 1990's and reached its lowest point in the three years preceding the discovery of the Reactor Pressure Vessel (RPV) head degradation in March, 2002. Over the past decade, Operations personnel believe that the "keys to the plant" were taken away from them. The Team concurs with this perception. It appears to the Team that management decisions with unintended consequences and, in some cases, management behavior that demonstrated an active disregard for the authorities and responsibilities of licensed personnel over a period of years, diminished Operations' ability and willingness to lead the site in assuring safe operations. The Team also concludes that the most significant barriers to Operations' leadership have been eliminated and that the corrective actions underway to strengthen Operations' role at the site are likely to be effective.

1.2 Problem Statement

This report may be different from typical analyses of events at Davis-Besse because it focuses on the underlying reasons for an adverse organizational condition that developed over a period of years, rather than a single event. The purpose of this effort was to identify the root and contributing causes of the previous lack of Operations' centrality in maintaining, assuring, and communicating the operational safety focus of Davis-Besse and the lack of accountability of other groups to Operations in fulfilling that leadership role.

1.3 Event Narrative

The Management and Human Performance Root Cause Analysis Report (Condition Report [CR] 2002-0891, August 21, 2002), which addressed organizational factors that contributed to the RPV head degradation, stated:

The Davis-Besse Plant had a significant outage in 1985. Since that time the plant has been a top performer, but starting in the mid-1990s a flattening or decrease in performance can be seen. The managers brought in during the 1980s event are gone and many of the managers developed during that period left the company and are now in key positions throughout the industry. Several of the plant evaluations both in-house and by outside organizations have noted this issue over the past three years. Actions were taken to improve this performance but not as promptly as needed.

The Management and Human Performance Root Cause Analysis Team noted that a significant barrier to declining plant performance should be licensed operators who promptly identify degrading conditions and aggressively pursue problem resolutions. In the case of the RPV head degradation, however, that Team found that the Operations Department at Davis-Besse was not provided with important information about conditions on the head and missed a number of opportunities to demonstrate leadership in resolving the developing problem.

1.4 Data Analysis

This Root Cause Analysis Team (Team) used change analysis, barrier analysis, and the Human Performance Evaluation Process (HPEP) to determine the root and contributing causes of the apparent absence of Operations leadership in assuring the safe operation of Davis-Besse Nuclear Power Station.

1.5 Root Cause Determination

Based upon its analysis, the Team identified one root cause and three contributing causes for the erosion of Operations' leadership in station activities.

Root Cause

1. Senior management support for Operations' leadership role in assuring plant safety was lacking.

Contributing Causes

1. Staffing was inadequate to perform the tasks assigned.
2. Senior management failed to ensure that regulatory expectations for licensed personnel were effectively communicated and reinforced.
3. Senior management failed to assure that a safety conscious work environment was established and maintained in Operations.

1.6 Extent of Condition

Based upon the information considered by this Root Cause Analysis Team and the information documented in the Management and Human Performance Root Cause Report, the Team believes that other station departments were also adversely affected by some of the same factors identified in this analysis. In response to the Management and Human Performance Root Cause Analysis Report, a Management and Human Performance Excellence Plan was developed and is being implemented. The Management and Human Performance Excellence Plan includes a series of reviews of selected station organizations that include, for example, checks of whether there are clear lines of authority and responsibility within the organization; whether

staffing levels and resources are sufficient to handle assigned responsibilities; whether individuals have a clear description of their assigned responsibilities; and whether interfaces with other organizations are clearly defined. In addition, a number of actions are being implemented to strengthen the safety conscious work environment across the site. The Team concludes that these efforts should identify needed corrective actions in other station organizations for adverse conditions that were created by the same causal factors that affected Operations.

1.7 Corrective Actions

The key corrective actions are described below, arranged by causal factor:

1.7.1 Senior management support for Operations' leadership role in assuring plant safety was lacking.

- a. Extensive changes have been made in the officers, directors, and managers responsible for Operations, including changes in the Site Vice President, Plant Manager, Operations Manager, Operations Superintendent, and Operations Support Superintendent. These individuals value strong Operations' leadership.
- b. Senior management is demonstrating support for Operations' leadership role by being visible and active in Operations' activities, such as shift turnover meetings, by appropriately mentoring and coaching Operations' personnel in resuming the leadership role, and by ensuring that Operations' priorities are addressed and supported in station decision-making. The Nuclear Quality Assurance organization will periodically assess the implementation and success of these activities.
- c. A declaration from the chief executives will be issued and communicated to site personnel delineating Operations' leadership role.
- d. The Operations leadership team will disseminate the results of this Root Cause Analysis and the corrective actions to other station managers, will ensure that other station organizations dedicate the time required to internalize the impact of Operations resuming the leadership role on their activities, and will resolve any issues identified in implementing the change.
- e. Senior management will assure that no uneasiness remains among Operations personnel regarding the station's ability to operate safely prior to restart. Shift Managers will be charged with eliciting any outstanding safety concerns from their crews and for ensuring that the concerns are resolved. Davis-Besse will not restart until each Shift Manager is willing to state that he and his crew know that the plant is ready to restart, that Operations has regained and is performing the site leadership role, and that the plant will operate safely.

1.7.2 Staffing was inadequate to perform the tasks assigned.

Corrective Actions:

- a. Continue hiring new personnel to be trained as equipment operators and continue training of RO and SRO candidates. Continue implementing current plans for additional licensing classes to replenish and maintain a sufficient number of licensed personnel for the tasks assigned, as well as to populate other departments with personnel who maintain active licenses.
- b. Analyze the tasks currently assigned to Operations. Identify additional activities that Operations must perform to continue re-establishing and to maintain leadership. Determine the number of personnel and the qualifications required to perform the activities identified. Develop and implement short-term compensatory measures for staffing shortfalls that are identified.
- c. Address Operations' compensation, as necessary, to ensure retention of current staff. Improve the station's competitive position in attracting desirable applicants. Continue current activities to develop and implement professional development plans for Operations personnel to ensure that career paths are identified and that future site leaders will be available and prepared to assume leadership roles.
- d. Implement corrective actions for staffing needs identified in other station organizations to ensure staff capabilities exist to support Operations' priorities.

1.7.3 Senior management failed to ensure that regulatory expectations for licensed personnel were effectively communicated and reinforced.

- a. Prior to restart, Operations and management personnel from other station organizations will receive corporate training regarding the roles, responsibilities and authorities of licensed personnel. This training course will be added to the core continuing training program for Operations and management personnel.
- b. The Site Vice President will continue to make himself available to the Duty Shift Manager to assist in ensuring that personnel in other station organizations understand his expectation that they are accountable to the Duty Shift Manager and to Operations personnel and must support Operations' leadership role.
- c. Management will ensure that an invitation is extended to NRC representatives to address newly licensed or upgraded operators when they are awarded their licenses, and to address Operations Department

personnel periodically to communicate and reinforce NRC expectations, as appropriate.

- d. An Operations Standards and Expectations document has been issued to address, in detail, expectations, job standards, and responsibilities of Operations Department personnel. Knowledge of these standards and expectations will be reinforced by training and testing prior to restart.
- e. A memo signed at the highest level defining the Shift Manager's role, responsibilities and authorities will be issued and conspicuously posted in selected areas throughout the site. This memo will be revised and reissued on an annual basis.
- f. The Operations Leadership Plan will be reviewed and approved by senior management.
- g. As part of the Management and Human Performance Excellence Plan, policies, procedures, program and job descriptions, and organizational interfaces are being reviewed for consistency with management expectations. As part of these reviews, opportunities to strengthen Operations' leadership role will be identified and incorporated. For example,
 - i. Requirements will be added to the corrective action process to ensure that Operations' concerns are adequately addressed in the prioritization, scheduling and resolution of condition reports.
 - ii. Operations' involvement in station decision-making processes will be strengthened. Operations' representation will be required at Management Review Board, Corrective Action Review Board, Station Review Board, and Project Review Committee meetings, and that Operations input will be sought in other station decision-making processes, as appropriate. These important decision-making meetings will not occur unless a designated Operations representative is present.
- h. Licensed personnel will fully commit to resuming the leadership role.

1.7.4 Senior management failed to assure that a safety conscious work environment was established and maintained in Operations.

- a. The Operations Standards and Expectations document will address the chilling effect in Operations by including expectations for Operations personnel to raise any operational concerns. It also contains the requirement for Operations personnel to demonstrate leadership in resolving concerns by continuing to escalate them through their management chain up to and including the President of FENOC until

resolution is obtained. Davis-Besse and FENOC senior management expect Operations personnel to inform the NRC of their concerns, if management does not address the concerns to their satisfaction.

- b. Licensed operators will be delegated management authority for addressing and resolving safety concerns that are identified to them by other station personnel.
- c. Consistent with their leadership role, Operations personnel at all levels will be given training in maintaining a safety conscious work environment to ensure that their leadership and oversight of station activities performed by personnel in other departments is conducted in accordance with management expectations.
- d. Individuals appointed to the open Site Vice President and Operations Superintendent positions will be thoroughly screened prior to appointment to ensure that their management styles will support a safety conscious work environment in Operations.
- e. Operations personnel and managers in all station organizations will comply with senior management requirements and NRC expectations for ensuring that a safety conscious work environment is maintained. 210 of 250 site supervisors have recently completed safety conscious work environment training for supervisors, and the remainder will complete training by December 4, 2002.
- f. Reports from site-wide surveys and assessments of the safety conscious work environment in Operations will be provided to the Plant and Operations Managers, and any weaknesses identified will be promptly addressed and resolved.
- g. Davis-Besse will complete implementation of the Safety Conscious Work Environment Action Plan as part of the Management and Human Performance Improvement Plan.

1.8 Experience Review

The results of the experience review indicated that evidence of the decline in Operations' leadership role was identified prior to this Root Cause Analysis and that similar events have been identified across the nuclear industry. Some corrective actions were developed and implemented to address specific symptoms of the decline of Operations' leadership at the site, but it does not appear to the Team that the potential consequences for nuclear safety of the management and organizational issues occurring in Operations were previously considered. Changes in FENOC and Davis-Besse managers, as well as the managers within Operations, have been made and the new management team brings an operational focus and values a safety conscious work environment. In addition, an Operations Leadership Plan has been

developed and is being implemented that addresses the steps necessary to strengthen Operations as well as Operations' relationships with other site organizations. These actions are substantially broader and more comprehensive than the corrective actions taken for CR 01-2989 and previous assessments of Operations. Davis-Besse should perform reviews to ensure that the corrective actions specified in this report are effective.

2.0 Problem Statement

2.1 Reason for the Investigation

As documented in Condition Report (CR) 2002-0891, through-wall cracking was identified during thirteenth refueling outage (13RFO) in some of the CRDM nozzles on the Davis-Besse reactor pressure vessel (RPV) head. Further investigation of this condition in March of 2002 led to the identification of significant degradation of the RPV head base metal at nozzle 3 and additional corrosion at nozzle 2.

In April of 2002, a Root Cause Analysis Report was issued on the technical causes of the degradation of the Davis-Besse RPV head (CR 2002-0891 Technical Root Cause Analysis Report). That Report identified a number of management issues that were contributing causes to the degradation, and concluded that station personnel had failed to identify corrosion of the base metal of the RPV head over a period of years despite multiple opportunities to do so.

In August of 2002, a Management and Human Performance Root Cause Analysis Report was issued that stated that the Davis-Besse Operations Department did not take an active role in advocating actions to improve plant conditions. Condition Report 2002-02581, originated in June of 2002 by a member of the Management and Human Performance Root Cause Analysis Team, listed six occasions on which Operations personnel missed opportunities to demonstrate leadership in preventing the significant head degradation. The author of the CR stated, "This has raised the question of the centrality of Operations in maintaining, assuring, and communicating the operational safety focus for the site, as well as the accountability of other groups to Operations in fulfilling that role."

Although the information in this Report provides insights regarding the factors that caused or contributed to Operations' failure to prevent the RPV head degradation, the purpose of this Root Cause investigation and analysis was broader. The purpose of the current effort was to identify the root and contributing causes of the apparent absence of Operations leadership in assuring the safe operation of Davis-Besse Nuclear Power Station.

2.2 Consequences of the Condition

Licensed operators hold a unique position within the commercial nuclear power industry. They are employees of the corporations that operate the nuclear power plants, but are also the only individuals within the industry who are licensed by the U.S. Nuclear Regulatory Commission (NRC). As individual licensees of the NRC, operators hold the special trust and confidence of the public. If the licensed personnel at a plant do not demonstrate leadership in maintaining nuclear safety as the highest operational priority, public health and safety are at increased risk.

2.3 Actions Already Taken

The Operations Department has developed and is implementing an Operations Leadership Plan. Accomplishments to-date include:

- The administrative duties assigned to Shift Managers have been reduced, so that they are more available to provide leadership and oversight of activities in the field. In addition, the Shift Managers' work area was moved from the work control center counter area into an office.
- An independent assessment of the potential and leadership skills of management personnel within the Operations Department has been completed to provide the basis for professional development plans.
- Licensed SROs are assigned to the Fix-It-Now Team and to the Radiation Protection Department to ensure that an operational perspective is brought to those areas.
- Benchmarking visits to three other stations reputed to have a strong operational focus have been completed and the results compiled for future improvements in Operations' work activities.
- The Institute of Nuclear Power Operations (INPO) Operations First Line Supervisor course has been completed by the Unit Shift Supervisors and Shift Engineers to strengthen their leadership skills and enhance teamwork. All but two Shift Managers have attended the INPO Shift Managers course and the remaining two will attend within the next six months.
- Aggressive hiring plans for Operations have been implemented and licensing classes have continued, despite outage demands, to ensure that sufficient and appropriately qualified personnel are available to sustain Operations' leadership role and to provide future leaders with a strong operational focus to other site organizations.
- An Operations Standards and Expectations Directive has been completed.

3.0 Event Narrative

3.1 Background

Davis-Besse achieved initial criticality on August 12, 1977. In its 25 years of operation, the organization has demonstrated cyclical safety performance.

Following the June 9, 1985 auxiliary feedwater event and extended shutdown, Davis-Besse began to improve its performance significantly. The managers who were brought onto the site following the event focused on repairing equipment that had been allowed to degrade or had not worked properly since the plant began operations. A strong Operations department was emphasized by senior management, and the number of licensed personnel was reported to have increased from 45 in 1985 to 100 by 1990.

In 1991, the plant manager published the following memorandum addressed to the Davis-Besse Operations Shift Supervisors:

Nuclear generating facilities have the potential to significantly impact the health and safety of the public. This potential impact places a special burden and responsibility on those who manage and command operations at the Davis-Besse Nuclear Power Station.

The first line of defense in protecting and assuring the health and safety of the public and the safety of personnel within the plant is the safe, conservative operation of the plant.

The Duty Shift Supervisor (SS) has the primary management responsibility, until properly relieved, for the safe, conservative operation of the plant. Accordingly, the Duty SS is directly charged with both the responsibility and the command authority of all shift operations, maintenance activities, and implementation of radiological controls under normal and abnormal conditions. Both the supervisor coming on shift and the supervisor being relieved shall make certain they review, convey, and understand plant status and on-going activities and that the activities are deemed to be in accordance with safety requirements.

You must constantly maintain the broadest perspective of operational conditions potentially affecting the general public, plant personnel, and the safety of the plant. Maintenance of this broad perspective shall be your highest priority.

Interviewees who worked at the plant before the 1985 event report that, in the period from approximately 1986 through 1990, the professionalism and expertise of Operations Department personnel increased. Before the 1985 event, operators were perceived as "arrogant," making it difficult to communicate with them to solve problems. An influx of new personnel who brought new attitudes, improvements to operator training, and a change in management expectations regarding professionalism allowed Operations to become more effective leaders at the site. The increased number of licensed operators available also allowed them to be more involved in on-going work activities at the plant and enhanced the site's safety focus. The majority of operators interviewed who were at the plant at the time also report clear senior management support for Operations' central role in decision-making.

It was the unanimous perception of the interviewees, both within and outside of the Operations Department, that Operations' leadership role at Davis-Besse began to erode in the early 1990's and reached its lowest point in the three years preceding the discovery of the RPV head degradation in March, 2002. The interviewees' common belief is that between the years of 1993 to the present, the "keys to the plant" were taken away from them.

3.2 Event Narrative

The originator of CR 2002-02581 listed the following events and conditions as indicating a lack of safety leadership from Operations at Davis-Besse.

- The initial review of a condition report (PCAQR 96-0551) was accepted by Operations as an administrative issue, although the wording of the PCAQR indicated potential degradation mechanisms on the RPV head.
- Operations had minimal involvement in the identification of the leakage source responsible for iron oxide deposits documented in CR 1999-1300. Additionally, there was a lack of accountability to assure this source was definitively identified.
- Operations demonstrated tolerance for long-standing issues, such as: the need to clean Containment Air Coolers (CACs), boric acid dispersion on equipment in containment, and high unidentified leakage.
- Operations demonstrated a willingness to accept RC-2 leakage in re-starting the plant following 11RFO.
- Engineering did not communicate trending parameters regarding unidentified leakage and RP (gaseous activity) to operators to ensure their awareness.

- A mode restraint was removed prior to the performance of work (CR 2000-1037) with words that the designated work "will be" performed. This faith was unrealized as the expectation of the mode restraint was only fulfilled in part.

As indicated in CR 2002-02581, the Operations personnel interviewed were not aware of some of the key information related to the RPV head degradation until that information was first presented to them in the recent Case Study sessions, conducted during the weeks of October 11 through 24, 2002. For example, operators did not see videotapes that had been made of boric acid found on the RPV head during 12RFO in 2000 and were unaware that it was a dark red, rusty color. Those interviewed were also not aware of the November, 1999, Sargent & Lundy report suggesting there was a steam leak high in containment that was causing boric acid corrosion and was responsible for the iron oxide mixed in with the boric acid deposits. They were also unaware that the cleaning of the RPV head during past outages was not fully successful and that significant boric acid deposits were left on the RPV head. Responsibility for the Boric Acid Corrosion Control program was assigned to Engineering and Operations did not provide oversight of the job. During 12RFO, a Shift Manager who wanted to view the progress on the job was prevented from doing so by Operations management on the basis of dose concerns.

Observations made by radiation protection (RP) technicians who entered containment for the repeated cleanings of the Containment Air Coolers (CACs) and the frequent filter changes for the radiation monitors were routinely provided to Operations, but Operations personnel did not possess the technical information necessary to interpret correctly the changing conditions in containment. They had received some limited training in the potential consequences of boric acid corrosion following a 1998 event in which two carbon steel nuts had corroded away on the RC-2 spray valve. Some may have known from previous industry events at Salem and Turkey Point that crystalline boric acid from CRDM nozzle leakage left on the carbon steel RPV head would cause limited corrosion. However, the corrosion mechanism that was generally known at that point from industry operating experience was not the same aggressive attack that occurred at Davis Besse. Known corrosion rates were very slow and should not have resulted in wastage to this degree. More importantly, operators were repeatedly assured by engineering and senior management personnel that the boric acid on the RVP head could not result in significant corrosion, because the temperatures were so high that the boric acid would remain in a non-reactive, crystalline form.

If the operators had understood that aggressive corrosion on the RVP head was occurring, they were required by technical specifications to shutdown, cooldown and depressurize the reactor. However, they were told, and believed, that the boric acid was being removed from the RVP head in each refueling outage. When asked why Operations did not require that the plant be shutdown due to unidentified leakage in containment that was below technical specification limits and the presence of boric acid on the RVP head that they did not believe represented an immediate threat, a Shift Manager summarized his understanding of containment conditions at the time by replying, "Based on what?"

4.0 Data Collection and Analysis

4.1 Input

Leadership is a concept that exists in the human mind and arises from social interaction. Although organizational researchers have attempted to measure leadership objectively over the years, it is fundamentally a subjective phenomenon. Understanding it requires access to the perceptions, interpretations and beliefs of those who are leading and are led. Subjective assessments associated with leadership, or any social interaction, may be based on inaccurate, incomplete, or distorted information. However, it the perceptions and interpretations of events that often best explain behavior.

Therefore, the primary information-gathering method used by the Root Cause Analysis Team was interviews. Many Davis-Besse personnel have worked at the station since the 1970's and three of the individuals interviewed were involved in plant construction and start-up. The long tenure of many of those interviewed made change analysis the root cause analysis technique of choice.

The passage of time distorts memory, however. Within 48 hours of an event, the accuracy of an eyewitness' memories for the event decreases by 50%. As time passes, people seek to explain and interpret their own behavior in an event, and the explanations they create may unintentionally come to replace or distort the information they stored in memory. Further, people talk with others about significant events, and so one person's memories may become "contaminated" by others' over time. Because this investigation was not initiated until long after many of the events described here occurred, it is likely that some of the interview data collected are questionable.

A set of discussion topics was developed to guide the formal interviews, but the conversations were wide-ranging. The interviewer began by describing the statements in the Management and Human Performance Root Cause Analysis Report regarding the apparent erosion of Operations' leadership role at the site and asked the interviewees whether they agreed or disagreed with the statements. Given that all of the interviewees agreed that erosion had occurred, they were then asked to describe the bases for their conclusion and to provide specific examples of decreased Operations' leadership. They were also asked for their views on the reasons that the erosion had occurred. For each of the examples provided, interviewees were also asked whether the situation had changed and how it had changed. Therefore, when reading this Report, it is important to note that the "complaints" offered by the interviewees were intentionally sought by the Team.

Interviewing began with equipment operators and proceeded vertically within Operations, with a minimum of 30% of the personnel in each job category contacted. To the extent possible, information provided by an interviewee about another person was verified by contacting the other person. Reports of activities that would have involved several individuals, such as briefings and meetings, were verified by contacting at least one other individual who had been present. When available, copies of documentation related to the interview data were obtained or reviewed to validate the interviewees' recollections. The documentation included memoranda, e-mail messages, meeting minutes, standing orders, procedures, and CRs. In addition, a small sample of individuals from departments outside of Operations was interviewed. In the interests of readability, the percentage of interviewees who endorsed or disagreed with a particular interview item is not presented in this report. Instead, except where noted, the information presented represents a summary of the interviewees' views and recollections, illustrated with some of the anecdotes provided.

Several other sources of information were also used. The Root Cause Analysis Team observed (1) meetings in which Operations personnel had the opportunity to demonstrate leadership, (2) crews in training perform in the simulator, and (3) turnover activities and conduct of operations in the control room. The Team also relied on data gathered by the CR 2002-0891 Management and Human Performance Root Cause Analysis Team.

4.2 Methodology

The Team used the following methods to guide data collection and perform the root cause analysis:

- Change Analysis
- Barrier Analysis
- Human Performance Evaluation Process Cause Tree and Modules

4.2.1 Change Analysis

Change analysis consists of comparing an event-free, prior, or ideal situation to the situation existing at the time an event (or adverse condition) is identified. The differences between the prior situation and the situation at the time of the event are then evaluated to determine their effect on the event (or adverse condition). The prior condition used for comparison in this analysis was the early 1990's, when Operations held a site leadership role. The current state of Operations' leadership, as described in CR 02-02581 and by interviewees, was the adverse condition analyzed.

4.2.2 Barrier Analysis

In a barrier analysis, management systems and physical barriers that could protect a target from hazards are identified and analyzed. An evaluation is then conducted to determine whether the barriers did not exist for the event or adverse condition in question, or if they did exist, why they failed to prevent it.

4.2.3 Human Performance Evaluation Process

The *Human Performance Evaluation Process* (HPEP; NUREG/CR-6751, April 5, 2002) was developed for the NRC and is intended for use by NRC inspectors to assist in the review of nuclear utility licensees' problem identification and resolution processes related to human errors. The HPEP can also be adapted for use in conducting investigations and causal analyses of human performance problems. The HPEP Cause Tree may be used as a screening tool for identifying the range of possible causes for a human performance problem or as a checklist at the end of an investigation to ensure the breadth of issues considered was adequate. The Cause Modules discuss typical causes of human errors in nuclear licensee facilities and provide examples, based upon the research literature and industry experience.

As information was gathered, the Team used the HPEP Cause Tree and Modules to identify promising lines of inquiry and to rule out others. The following Modules were determined to be relevant to this Root Cause investigation:

- Module 10: Attention and Motivation (Motivation only)
- Module 13: Staffing
- Module 14: Supervision
- Module 18: Coordination and Control

4.3 Results

4.3.1 Change Analysis Results

A significant amount of change occurred at Davis-Besse in the past decade. Interviewees perceived that there was a decreasing corporate willingness to invest in the staff and material condition of Davis-Besse during the 1990's. The interviewees believed that the corporate owners of Davis-Besse suffered financial pressure in the 1990's. Various explanations were offered, including the expectation that deregulation would cause increased economic competition, the assumption of significant debt, or several poor investments. Others reported being told that, because of the limited time left on the license to operate the plant, which limits the return on any investment, it was important to minimize capital improvements, and to maintain operations and maintenance costs as low as possible, in order to avoid plant shutdown.

The Management and Human Performance Root Cause Report for CR 2002-0891 suggested that the perceived unwillingness to invest in Davis-Besse may have been due to individual corporate and site management's response to monetary incentive rewards based primarily on production, as follows:

The FENOC management monetary incentive program rewards production more than safety at senior levels of the organization. For example, the Nuclear Incentive Compensation Plan for 2002 provides for incentive compensation for various factors related to safety and production, and FENOC officers and plant directors are to receive most of their incentive compensation based upon production. This supports misalignment of the organizational priorities, and inhibits the transition of the organization to a safety-first philosophy.

Whether the cost-control measures implemented in the past decade represent a corporate response to financial pressures, the actions of managers motivated by financial incentives, or other factors, these measures appear to have had a significant adverse impact on Operations' leadership role, as follows.

4.3.1.1 Staffing

Like many nuclear utilities at the time, a staffing study was performed for Davis-Besse in the early 1990's and the results were described as showing that the plant was over-staffed compared to other best-performing stations across the industry. Downsizing began and continued throughout the decade through layoffs, early retirement programs, and attrition. The number of permanent employees decreased from 1,134 at the beginning of 1993 to 717 at the end of 1997. As of January 1, 2002, the number of full-time, permanent employees at the site was 677.

One engineer interviewed stated that, as a result of the staffing study, engineers heard that layoffs were coming and left the site "in droves." He reported that so many left voluntarily that it was unnecessary to lay off anyone in Engineering. He also indicated that Engineering lost its most qualified and dedicated people first.

Operators commented that the substantial loss of experienced engineers meant that in-depth knowledge and understanding of plant systems and design was also lost. After the exodus, interviewees reported instances of having to locate past employees in order to obtain needed engineering information. In addition, system engineers were often assigned responsibility for multiple systems, whereas engineers in the past were able to focus on a single system. The consequence for Operations was not only that engineering responses to requests for analyses and assistance were delayed, but also that the quality of the information they received declined. Initially, when senior reactor operators (SROs) would request more thorough or detailed information, they found that some engineers were willing to provide it. Others would take the issue to their management, who would then discuss it with Operations management, and the SROs sometimes found themselves told to accept the information provided.

Interviewees reported that, in response to the staffing study, senior management determined that Davis-Besse had more than enough licensed personnel and stopped hiring new non-licensed operators to be trained for eventual licensing. No new hires of non-licensed operators were reported to have occurred for a period of six years.

Attrition also affected Operations. Towards the end of the 1990's, the number of licensed operators fell below the 1985 head-count of 45. In 1998, shift crews fell to technical specification minimums. The SRO ranks were depleted by transfers of a number of SROs into other departments and the resignations of several SROs who left Davis-Besse for opportunities at other sites. No new SROs were licensed until 1998. Further, within a seven-month period in 2000-2001, prior to discovery of the RPV head degradation, two Shift Managers left Operations and one left the site altogether.

Compensation issues within Operations have contributed to the staffing problems. Some data suggest that salaries within the Operations Department are below industry averages, including operator compensation at plants located in economically comparable areas. The perception of lower wages has adversely affected operator morale for several years and appears to have served as a distraction. During contract negotiations for the reactor operators (ROs) and non-licensed operators in the late 1999/2001 period, management attempted to rectify the problem. The operators' union, however, blocked the effort to increase compensation for operators without offering the same increase to others at the site, so salaries continue to be perceived as lower than industry averages. In addition to the impact on morale, a less attractive compensation package was reported to have made it more difficult to recruit top candidates at the non-licensed operator level. In 1998, management authorized Operations to recruit two non-licensed operators from a local fossil plant that is also operated by the corporation. Recruiting efforts for non-licensed operators outside of the corporation, undertaken in 1999, were only partially successful in that all of the open positions could not be filled.

Compensation packages for more senior operations personnel are also perceived to be lower than industry averages and progression through salary grades has been slower than for other plant personnel. The "standard rate" for a position is defined at Davis-Besse as the salary level for a job incumbent who is fully qualified and, typically, has been in the position for four to five years. Interviewees reported that no SROs or Shift Managers appear currently to be paid at the standard rate for their job classifications. Several individuals reported that some senior Instrumentation and Control Technicians were paid more than the highest-paid Shift Manager, based on an informal survey conducted by Operations personnel. Opportunities for better compensation, combined with other organizational factors, have contributed to the loss of a number of SROs to other plants over the past several years.

At the same time the number of licensed personnel was decreasing, Operations assumed additional responsibilities. For example, the Procedures group at the site was disbanded and Operations was required to take on responsibility for the development and revision of all operating procedures. In addition, Operations assumed full responsibility for staffing the fire brigade when Security and Maintenance personnel were re-assigned to other duties because of staff shortages in those departments. Audits and self-assessment responsibilities increased. These activities were added to on-going administrative tasks required by regulation and plant procedures, such as CR reviews, work order reviews, clearances and tagging, and operability evaluations.

There were several consequences of the reduced number of licensed personnel on-site, particularly SROs. Overtime hours for all Operations personnel were reported to have increased. Shift scheduling was changed to 12-hour rotating shifts when a new Operations Manager was brought in, late in 2000. The staff prefers 12-hour shifts because of the increased number of consecutive days off. However, the research literature predicts that the longer shifts and shift rotations, combined with the continuing need for overtime, increase fatigue levels and so increase the likelihood of operator errors. The SROs began taking paperwork home with them in order to address the growing backlog and to avoid recordable overtime hours in excess of regulatory limits.

Task-shedding also occurred. For example, SROs stopped attending many decision-making meetings, because they were needed on-shift or were under schedule pressure to complete administrative tasks. Licensed personnel, particularly the Shift Managers, spent increasingly more time processing paperwork, and less time in making field observations, in training observations, or coaching and communicating with the crews. The SROs were reported to be discouraged from taking rotational assignments in other departments to broaden their experience, and promotions out of Operations were rare, because the staffing needs in Operations were too great. Operations' leadership and an operational perspective on other plant activities have been significantly diminished as a result.

4.3.1.2 Decreased Operations Involvement In Station Decision-Making

In the past decade, Operations has had a decreasing involvement in station decision-making. Some programs and processes for which Operations was responsible were assigned to other departments to attempt to reduce the administrative burden on licensed personnel. In other cases, organizational and process changes were made as improvements, but had unintended consequences for Operations' leadership.

For example, in the past, the Corrective Action Program (CAP) was accountable to Operations and Operations played a significant role in its design and operation. Operators and others interviewed perceive that the CAP, as currently designed and implemented, detracts from Operations' leadership role.

Interviewees perceive that Operations has limited ability to track CRs or affect the corrective actions that are developed. The perception is that SROs see the CRs when they perform their required reviews for operability or technical specification concerns, for example, or operators generate CRs, but the CRs then "disappear" into the CAP process. One equipment operator stated that he had attempted to check on the status of several CRs he initiated. He said he was unable to retrieve them by searching in the CREST system because he had not retained the CR numbers, which appears to indicate a training need. Feedback to CR originators is not currently required by CAP procedures. Interviewees also noted that the owner assigned to a CR is able to extend due dates without consulting with the CR originator or the SRO who performed the review. Further, non-licensed personnel are able to routinely assign and clear mode-hold restrictions from CRs without authorization by a licensed operator. In fact, a design engineer cleared the Mode 4 hold restriction on CR 2000-1037 that required the RPV to be cleaned of all boric acid deposits during RFO12.

Operations' input to the prioritization and disposition of CRs is perceived as diluted by the multi-disciplinary team approach to these activities. Categorization of CR significance is performed by a Management Review Board (MRB), using a consensus-based decision-making process. Root cause analyses and corrective actions are evaluated by the Corrective Action Review Board (CARB), also based upon a consensus decision-making style. CAP procedures mandate that a quorum be present for these meetings, but do not require an Operations representative to be present at either the MRB or CARB meetings. Further, CAP procedures do not provide a mechanism for Operations to challenge MRB or CARB decisions that may be adverse to safe operations.

Participation by licensed personnel in other key decision-making activities also decreased over the past decade. Maintenance personnel interviewed stated that maintenance project review meetings typically occur without Operations involvement. Operations representatives are invited to participate, but the perception is that they have been too overwhelmed to do so. In addition, the meetings are often scheduled when the SRO who is assigned to a system is on backshifts or is taking his days off. Another interviewee reported that the Station Review Board functioned for 1.5 years without an Operations representative appointed. An Operations representative to the Station Review Board is not a procedural requirement. The Operations Manager was also previously not expected to attend senior management meetings. The current Operations Manager has invited himself to these meetings, however, and reinforces the present senior management team's operational focus.

4.3.1.3 Failure to Support Operations' Leadership Role In Maintaining Plant Material Conditions

Beginning in the mid-1990's, operators reported they had a decreasing ability to ensure equipment modifications and repairs were completed. The interviewees noted that the Shift Manager is authorized to initiate "Immediate Action Maintenance," but the criteria under which it will be implemented are stringent (e.g., imminent plant trip, power reduction, or shutdown; forced entry into a Technical Specification action statement which requires specific actions within 24 hours or less).

A senior equipment operator left Operations about 2.5 years ago, in part due to concerns about degrading material conditions in the plant. In a memorandum submitted to the union steward, he wrote:

Material condition of the plant...is becoming a bigger issue as of late... Main Steam Piping that is vibrating so bad as to damage insulation and cause a ½ in valve to shake itself apart... When I am in the plant I don't get a sense of safety... Too many leaks with nothing done or a Band-Aid attached to 'show progress.'

Another example of Operations' decreased ability to effect repairs is the Operator Workaround list. Although these items are now being addressed, the operators reported that many of the workarounds have been on the list for years. They described a former senior management attitude that many of the items were not a high priority, because they represented "only operator convenience."

Interviewees within and outside of Operations described a decreasing influence of Operations' on the prioritization of work requests during the 1990's. They perceived that the threshold for initiating work was raised, and that repairs and modifications that could not be justified in terms of a narrow interpretation of regulatory requirements were often denied or deferred. In addition, the Work Management Department was moved out of the production organization that includes Operations and RP/Chemistry. Work Management now reports to the Site Vice President (SVP) rather than to the Plant Manager, which appears to have negatively affected coordination between the two groups.

Interviewees reported an incident that occurred within the past two years in which a maintenance manager instructed his staff not to take direction from operators on-shift, if it would interfere with completing scheduled work. This manager told his staff that, if an operator approached a maintenance technician with a request for an immediate repair, the maintenance technician was to call the manager at home to obtain permission. The instruction was not incorporated into plant procedures and was generally not implemented, but was described as indicative of existing barriers to Operations' leadership in ensuring equipment is fixed. Operators reported that it is still sometimes necessary to rely on long-term, personal relationships with some older maintenance personnel, who retain a "respect for Operations," in order to

accomplish timely repairs. The recent permanent assignment of a SRO to the Fix-It-Now Team has improved responsiveness to Operations' priorities.

One interviewee outside of Operations also attributed some of the resistance to performing the repairs or enhancements requested by Operations to personnel shortages in the Maintenance and Engineering Departments, and indicated that those organizations were simply unable to respond timely to the workload. In his view, and that of others interviewed, Operations documented the items requiring maintenance, but eventually stopped pushing the formal work prioritization system for needed repairs other than the most safety significant. Their experience was that the resources did not exist and the work would not be performed.

4.3.1.4 Limited Support for Operations Command and Control Authority

Operations' command and control authority over station activities that may affect plant safety while on-shift was also described as having been reduced over the past decade. Operations' responsibility for the safety of activities performed by other departments continues to exist in some policy statements, directives, and memoranda, and was occasionally mentioned by managers in the past decade, but the interviewees perceived that this responsibility was not supported by management nor reinforced in training.

Interviewees reported that, in the early years of Davis-Besse operations, the Shift Manager was authorized to make decisions on-shift and "inform Operations management later." Over the past decade, the interviewees' perceive that the autonomous decisions the Shift Managers were authorized to make dwindled. Some Shift Managers stated that there were few actions they could take, other than those involved in immediately responding to plant upsets, without first discussing the issue with management.

Those interviewed indicated that the plant departments run as "silos." They stated that there are four different directors with four different, and often competing, agendas. Interviewees reported that personnel in other departments are generally more responsive to the requirements of their senior managers, rather than to Operations, and that supporting Operations has not been a senior management expectation. In addition, when a cross-functional issue arose in the past several years, senior managers with responsibility for Operations were perceived as frequently acceding to the wishes of other managers in the interests of "teamwork," rather than supporting the operator. Over time, the expectation that operators would lead or provide oversight of activities performed by personnel in the other functional areas disappeared.

As an example, operators stated that their access to contaminated areas in the plant was increasingly limited by more stringent ALARA policies. Operators were required to provide a justification for entering contaminated areas. Entries for the purpose of making field observations were increasingly determined to be unjustified by RP and Operations management. As a result, RP technicians, who continued to routinely enter contaminated areas, had more direct knowledge of existing material conditions and the progress of work activities in the plant than the operators. Since the RPV head degradation was discovered and a SRO was assigned to the RP Department, however, operators report that ALARA barriers to their field observations have been eliminated.

The SRO's command and control authority and other licensed operator responsibilities for providing oversight of all plant activities potentially affecting public health and safety also have not been emphasized by Operations management or in operator training. Several SROs and ROs indicated that they were not aware of this authority and were surprised when it was communicated in a recent meeting called by the NRC's Director of the Office Nuclear Reactor Regulation and the Region III Administrator on October 9, 2002. Most of those who attended the meeting responded positively to the message. When questioned about what he had been told in training regarding the responsibilities and authorities of a SRO, however, one SRO interviewed cynically replied, "Sure I can order it shutdown under the law. But, in times past, if we said 'the leak rate is increasing, shut it down,' we'd be outside the fence that night, looking in."

4.3.1.5 Management Styles

As the foregoing quote suggests, the management styles of some managers above the Shift Manager level over the past decade did not support the leadership role of licensed operators. Some managers described appear to have confused the reinforcement of individual accountability with blaming. Interviewees also described managers who held them accountable to a different standard than the manager demonstrated with his own behavior.

Numerous examples were provided by the interviewees of senior site managers as well as managerial personnel within Operations using public humiliation and verbal abuse as methods to "promote accountability." Over the past decade, this type of behavior was described as being characteristic of one or more managers in Operations' management chain at all times, including some Site Vice Presidents, Plant Managers, Operations Managers, and Operations Superintendents.

It appeared to those interviewed that some managers during this period were more interested in finding an individual to blame for problems than in solving them. For example, interviewees reported that a senior manager's first response upon hearing that two body-to-bonnet nuts were found missing on RC-2 in 1998 was to state that he wanted to find and discipline the mechanic who had not replaced them. They found it significant that he immediately assumed that the missing nuts were due to a personnel error, when it was soon identified that the nuts had dissolved from boric acid corrosion. In another instance described, a valve stem came off during startup following 12RFO and delayed the restart. Again, a senior manager's first question when told of the situation was to ask "Which operator closed that valve?" It was later identified that there was a stress cracking fracture in the valve stem that caused it to break.

A "shoot the messenger" approach to problems was also described. Another incident repeatedly mentioned was related to a root cause investigation regarding the unidentified leakage in containment. A systems engineer was publicly berated by a senior manager for reporting that the Team was unable to identify the source of the leakage while the plant remained at power.

In another incident, a reactor operator who had been told he was selected to attend the next SRO class, stated that he reviewed a Hot Topics list of "Warning Flags about Industry Operations Performance," published by INPO on the internet. He highlighted nine of the items on the list, such as "Management focus on production values overwhelms messages related to safety and conservatism" and "Large amounts of overtime are required for normal operations," and gave the list to a superior for possible discussion at a turnover meeting. The manager's response was, "I thought you were going to become a SRO..." which the operator interpreted as a threat. Within the next two-three weeks, the individual found that he, in fact, would not be starting the class at that time. The individual did not believe he could prove that the decision was retaliatory and chose not to initiate a grievance or an employee concern. He is also not interested in pursuing the matter now, and believes that a similar situation would not occur under the current Operations managers. He described his interpretation of the incident, however, as an example of the climate in Operations at the time.

Previous managers were also described as sometimes directing personnel to take actions that violated procedures or conservative operating practices. Interviewees indicated that when staff would question a management decision or inform the manager that the actions directed were in violation of the procedures and that the procedures had to be changed to implement the actions, the questions were either not answered or the individual was chastised.

One example given was an operator questioning why the plant was re-starting after a short outage in the late 1990's with continuing unidentified leakage in containment. He stated that the manager he questioned gave him a "dirty look" and ended the meeting without answering the question. The unidentified leak rate was below regulatory limits and so plant start-up may have been non-conservative, but was

allowable under the regulations. However, the operator's questioning attitude was clearly not reinforced.

The interviewees' also perceived that some managers were not interested in following procedures or conservative operating practices, if they were "in the way" of what the managers wanted to have done. One incident occurred during the 1998 event in which two body-to-bonnet nuts on RC-2 were discovered to be missing. According to this report, when the mechanics who had entered containment discovered that two nuts were missing, they left containment and informed a maintenance supervisor, who then called a senior manager. The senior manager, who was not a licensed individual, directed them to re-enter containment and replace the missing nuts. The Shift Manager was not informed of the problem until the nuts had been replaced and a condition report was brought to the control room for his review. He stated that he "went ballistic" when he realized the containment re-entries had been made without his knowledge. In addition, no operability evaluation was performed prior to the replacement. The individual who described the incident stated that, if an operability evaluation had been done as soon as the absence of the nuts was identified, the evaluation method that would have been used would have shown that the valve was inoperable, and the plant would have to be shutdown. A later finite analysis showed that operating the valve without the two nuts was acceptable. However, the Shift Manager's authority was circumvented, the required operability evaluation was not performed at the appropriate time, and the repeat entries of mechanics into the containment at-power to replace the nuts had the potential to cause a loss of coolant accident as well as catastrophic personal injuries to the mechanics, had their actions on the valve caused it to come apart while the plant was operating.

In a later discussion of the incident with another senior manager, this same individual questioned why an investigation was not conducted to determine whether nuts on other valves had similarly corroded. The question arose because it had been discovered that the missing nuts should not have been used in containment. They were made of carbon steel rather than stainless steel and so were subject to boric acid corrosion. The senior manager to whom this question was raised responded incredulously by saying, "What would you have us do? Shutdown?"

Although the individual was not a member of Operations and did not have the licensed authority to cause a shutdown, during a forced outage approximately one month later, this individual exhibited the type of leadership expected of Operations in ensuring that potential safety problems are thoroughly investigated and resolved. Without taking credit for it, it was clear to the Team that the individual had created an opportunity to tour the area near RC-2 in order to ask for a demonstration of the method used to identify carbon versus stainless steel nuts. During the demonstration, another carbon steel nut was found. At this point, a complete investigation of the extent of the condition was performed and additional carbon steel nuts were found and replaced. This type of subterfuge should not have been necessary to ensure that the full extent of the condition was assessed, but is another example, among several reported, of the informal means employed by some plant

personnel to promote operational safety despite the existing organizational and management barriers. This individual is now in licensing class, which the Team believes bodes well for the future effectiveness of Operations' leadership.

The effect of the previous management behaviors described was demonstrated in several additional comments made by Operations personnel regarding the previous climate in Operations. One operator noted, "Operations management goes as far as it can, but senior management over-rides them. They can tell you that the Shift Manager has the keys to the plant, but when the Plant Manager gives you a direct order, what can you do?" Another stated, "The NRC licenses me, not the plant. We're not afraid to raise concerns; there was just no point in it." Anger and frustration were apparent when the operators described their inability to resolve degrading equipment conditions, problems in plant programs, personnel matters and other areas in which they believed Operations should be playing the leadership role. Most of them reported a growing sense of "uneasiness" about the safety of operations. But, with limited authority and support, and repeated experiences of abusiveness from senior management over a period of 10 years, operators' willingness to aggressively pursue operational problems that, to the best of their knowledge, did not violate regulatory requirements, appears to have been diminished.

4.3.1.6 Management Changes

In the period from 1993 through March, 2002, management changes within Operations and at more senior levels were relatively frequent. There have been three Site Vice Presidents since 1993 and the current Site Vice President is acting, so an additional change is anticipated. Three individuals have held the Plant Manager position, which is the director-level position to which Operations reports. There have been seven Operations Managers during this period, and nine individuals have held the Operations Superintendent position. The individual currently filling the Operations Superintendent position is assigned to the position in an acting capacity and has not volunteered to accept the position permanently. One equipment operator, who has been at Davis-Besse for 2.5 years, reported that he has had four Operations Superintendents in that time. A licensed operator stated that he has had 17 different superintendents and managers in the 20 years he has worked at the plant. Under these changing circumstances, consistency in the communication of management expectations has been lacking. Further, given the management behaviors described above, Operations personnel have had reason to believe that communications such as "You are the six most important men in the plant," as stated by a former senior manager to the Shift Managers, lacked sincerity.

Operations personnel interviewed range from cautiously optimistic to enthusiastic about the individuals in their current management chain above the Shift Manager level. In comparing the new managers to previous managers, interviewees stated that the new managers are visible in the field, ask questions and listen to the answers, explain their decisions, come to the support of the operators' leadership role in interactions with other plant personnel, seem to want them to learn and

improve, and follow up on commitments. Several equipment operators indicated that this is the first time that Operations management has taken an interest in them and makes them feel they are an important part of the Department. The current managers were often described by the operators as a "dream team."

Because of the new management, Shift Managers and other Operations personnel at all levels expressed a willingness to pursue the leadership role at Davis-Besse, but some wariness remains. Poor choices in permanently filling the Operations Superintendent and Site Vice President positions, or further changes in those holding the Operations Manager and Plant Manager positions, could delay or stop the progress that has been made. Operations personnel may not be willing to fully commit to resuming the leadership role until it is clear that they will have consistent senior management support in doing so.

Senior management faces a significant challenge in filling the Operations Superintendent position permanently, however. In the past several years, few SROs who were asked to accept the Operations Superintendent position have been willing to do so. The primary reason described by interviewees was the perceived lack of management support for Operations and observations that previous Operations Superintendents were ineffective in the role. The lack of opportunities for advancement and a clear career path were also identified.

4.3.2 Barrier Analysis Results

The barrier analysis focused on management practices and systems that could have prevented the erosion of Operations' leadership role at Davis-Besse. A management system consists of the policies, procedures and work processes that are defined by management to identify the goals and objectives of work and to control how work is accomplished in an organization. The causal factors identified in the barrier analysis are as follows:

4.3.2.1 Management expectations regarding the roles, responsibilities, and authorities of Operations were not appropriately defined or incorporated into policies, procedures, position descriptions and performance evaluation criteria.

A review of station documentation indicated that legacy documents contain management expectations regarding Operations' leadership role but more recent documents are incomplete and some do not support it. For example:

- A number of Standing Orders continue to exist and policy memoranda were published in the past several years that were not incorporated into procedures or the Our Conduct for Excellence: "Leading the Way" pocket manual.
- A position description for senior equipment operators does not list responsibilities for assuming a leadership role with regard to activities in

the plant areas to which they are assigned and supervisory training was not provided to them.

- Job performance evaluation criteria for supervisors, managers, and executives do not mention safety, whereas "safety consciousness" is a rating dimension for personnel at the individual contributor level.
- Operating procedures include requirements for obtaining Operations Manager approval for actions that were more appropriately assigned to the Shift Manager.
- As noted above, the CARB, Project Review Committee, and Station Review Board Charters do not mandate Operations representation at meetings.
- The manner and specific types of situations in which Operations personnel should demonstrate leadership in setting high standards for station activities involving personnel from other departments are not documented.

Consistent and complete documentation could not have assured Operations' leadership role without management support for it. However, the fact that some plant policies, procedures and other forms of documentation have institutionalized a decreased role for Operations in maintaining safety is evidence of the erosion and appears to have contributed to Operations' declining leadership role at the site.

4.3.2.2 Management failed to ensure that regulatory expectations for licensed personnel were effectively communicated and reinforced.

NRC expectations for licensed personnel were identified and evaluated, because the NRC issues the licenses to individual operators. Management at Davis-Besse is responsible for communicating and implementing these expectations.

Paragraph (m)(2)(ii) of 10 CFR 50.54 states that "Each licensee shall have at its site a person holding a senior operator license for all fueled units at the site who is assigned responsibility for overall plant operation at all times there is any fuel in any unit." Over the years, the NRC has published policy statements and guidance regarding implementation of this requirement.

For example, following the Three Mile Island Accident in 1979, the NRC issued several requirements based on lessons learned from the accident. One requirement specifically addressed the Shift Supervisor's responsibilities (this position is now commonly referred to as the Shift Manager) and was later incorporated into TMI Action Plan Item I.C.E of NUREG-0694. In the Introduction to the original short-term recommendation 2.2.1.a, the NRC stated:

The ability of Shift Supervisors to carry out their responsibility for safe operation of the plant may be impaired by actions of utility management or by the individuals themselves. For example, management can impair a Shift Supervisor's command function by requiring a significant portion of his time to be devoted to administrative functions. The Shift Supervisor's command function can also be impaired by failure to recognize his leadership and decision-making responsibilities which go beyond those of the operators. If neither management nor the individual Shift Supervisors treat the Shift Supervisor position as that of a "manager" or "commander" of shift operations, the benefits to safety of clear delineation of a responsible individual in charge of plant operations may be reduced.

These expectations were further communicated by the NRC in Inspection and Enforcement Circular No. 81-02: Performance of NRC-Licensed Individuals While on Duty. In this circular, the staff stated:

NRC believes that a relationship exists between the professional attitude of a nuclear plant's operating and management personnel and the degree to which the health and safety of the public is protected... Factors making up this professional attitude include knowledge of all aspects of plant status by licensed control room operators, maintaining an orderly and clean working environment, aggressiveness of the operating staff to prevent operational problems, and correcting observed deficiencies... All on-duty NRC-licensed operators and operating supervisors must be aware of and responsible for the plant status at all times. This includes supervisors being responsible for the performance of all personnel assigned to their shift who could affect plant safety, regardless of specialty affiliation...

In 1989, similar principles were reiterated in the NRC's Policy Statement on the Conduct of Nuclear Power Plant Operations:

It is essential that management at each nuclear power reactor facility establish and maintain a professional working environment in which the licensed operator may be fully successful in discharging his or her safety responsibilities...

Each individual licensed by the NRC to operate the controls of a nuclear power reactor must be keenly aware that he or she holds the special trust and confidence of the American people, conferred through the NRC license, and that his first responsibility is to assure that the reactor is in a safe condition at all times.

These NRC expectations for licensee management and licensed operators do not appear to have been consistently communicated to Davis-Besse personnel, as indicated by the operators expressing surprise at the statements made by senior NRC managers during the October 9, 2002 meeting. The operators were surprised that NRC management views licensed personnel as "agents of the NRC" in performing its mission to protect public health and safety.

Training to address regulatory requirements and expectations was available from FENOC legal counsel and has been provided at other FENOC sites, but was not incorporated into Davis-Besse operator training. This training has also has not been provided to site managers.

If these NRC expectations for licensed personnel had been effectively communicated and reinforced, operators at Davis-Besse may have been more successful in retaining a leadership role.

4.3.2.3 Management failed to assure that a safety conscious work environment was established and maintained in Operations.

A key aspect of licensed operators' ability to maintain a leadership role in assuring plant safety at a site is a safety conscious work environment. A safety conscious work environment is defined by the NRC as a working environment in which employees are encouraged to report safety concerns without fear of criticism or retaliation from their supervisors and are empowered to ensure that safety concerns are promptly resolved.

Within the NRC's Reactor Oversight Process, a safety conscious work environment is identified as a cross-cutting area. A cross-cutting area is defined by the NRC as a nuclear plant activity that affects most or all of the safety cornerstones that have been defined by the NRC and are assessed through NRC inspections and other oversight activities. Indicators of deficiencies in a safety conscious work environment that have been identified by the NRC include:

...the lack of effective evaluation, follow-up, or corrective action for concerns raised to the ECP or findings made by the licensee's QA organization; overall licensee ineffectiveness in identifying safety issues; the occurrence of repetitive or willful violations; a licensee emphasis on cost-cutting measures at the expense of safety considerations; and/or poor communication mechanisms within or among licensee groups.

Although the NRC has published expectations that nuclear utility licensees will establish and maintain a safety conscious work environment, these expectations were not fully implemented at Davis-Besse, as follows:

- Expectations were not established that assign responsibility to managers at all levels for maintaining a safety conscious work environment, in which personnel are encouraged to raise safety concerns without fear of ridicule or retaliation and managers are obligated to work to resolve the concerns appropriately.
- Training was not provided to managers to ensure they possessed the knowledge, skills, and abilities required to establish and maintain a safety conscious work environment.
- Management behavior discouraged, and sometimes appeared to punish, a questioning attitude.

If a safety conscious work environment had been established and maintained in Operations, licensed operators may have been able to more aggressively pursue resolution of their growing sense of "uneasiness," even without conclusive evidence of a technical specification violation or other information to support an operability concern.

4.3.3 HPEP Results

The HPEP Cause Tree and Modules are a variation of several root cause analysis techniques based on repeatedly asking the question, "Why?", with regard to the circumstances surrounding an event or adverse condition. Questioning is stopped when answers are obtained that are outside of management's control.

4.3.3.1 Direct and Programmatic Causal Factors

Two types of causal factors are described in the HPEP Modules: direct and programmatic causes. A direct cause of an event is the actions or conditions immediately preceding or surrounding the event that caused or allowed it to occur. Programmatic causes are management and organizational conditions that allowed the direct causes to exist, and, hence, the event to occur.

Evaluation of the information gathered during the investigation using the HPEP Cause Tree and Modules identified the following direct causes (descriptions quoted from the HPEP):

- Reward structure – The desired behaviors with regard to safety, productivity, and quality workmanship were not appropriately rewarded.

- Insufficient staff available – Performance failed because adequate numbers of appropriate personnel were not available to perform the assigned work.
- Resources not provided – Performance failed because supervision did not ensure that workers had the resources required to perform the task, including information, procedures, guidance or assistance in solving problems that arise.
- Wrong goals – Performance failed because supervision communicated, directly or indirectly, an emphasis on production or cost goals over safety.
- Questioning attitude discouraged – Performance failed because supervision, directly or indirectly, discouraged workers from questioning work practices or instructions.

Two programmatic causes that accounted for the direct causes were identified:

- Supervision and Management – Supervision communicates and reinforces management expectations and establishes goals and requirements for performance. Supervisory oversight may increase motivation to perform in accordance with expectations as well as detect and correct any errors that occur. Weaknesses in supervision, for example, may cause staff to choose production over safety goals in their work or to tolerate workarounds that may lead to errors. (Reward structure, resources not provided, wrong goal, questioning attitude discouraged)
- Human Resources Planning – Most licensees develop some form of a business plan that defines organizational goals and objectives. Business plans are often used to estimate the resources required to achieve the goals and run the business. Business plans may be used to determine staffing levels for the various parts of the corporate organization, sometimes without manpower planning and analyses of anticipated workload levels. As a result, there may be insufficient staff or staff may not have the required expertise. (Insufficient staff available)

4.3.3.2 Root and Contributing Causes

The HPEP was also used to analyze the causal factors that were identified from the change, barrier and HPEP Modules analyses. The purpose of this analysis was to identify root and contributing cause(s) of the loss of Operations' leadership role at Davis-Besse.

The HPEP defines root and contributing causes as follows:

A root cause is the actions or set of conditions that, if eliminated or modified, would keep the event or adverse condition from recurring as well as prevent similar events or adverse events from occurring. A root cause is often responsible for multiple human errors or hardware failures, rather than single problems or faults. Root causes are more fundamental causes than direct causes, and are typically programmatic or management weaknesses.

A contributing cause is an action or condition that sets the stage for the event or adverse condition to occur. A contributing cause may be a long-standing condition or a series of prior events that, while unimportant in themselves, increase the probability that the event or adverse condition would occur.

The results of this analysis are reported in the next section.

5.0 Root Cause Determination

Based upon the analyses described in Section 5.0, the Root Cause Analysis Team identified one root cause and three contributing causes for the lack of Operations' centrality in maintaining, assuring, and communicating the operational safety focus of Davis-Besse and for the lack of accountability of other groups to Operations in fulfilling that role. These causes are discussed in the following sections. Related observations made by the Team are also presented.

5.1 Root Cause

Senior management support for Operations' leadership role in assuring nuclear safety was lacking.

The Management and Human Performance Root Cause Analysis Report concluded that a less than adequate nuclear safety focus (a production focus combined with taking minimum actions to meet regulatory requirements) was a root cause of the RPV head degradation. The current Root Cause Analysis Team concurs and concludes that the less than adequate nuclear safety focus was also a key contributor to the decline in Operations' leadership role in station activities. In fact, strong Operations' leadership should serve as a check on a growing production focus in management. Operations' leadership, however, requires that senior managers are willing to respect the authority and responsibilities of licensed personnel and to support and act upon Operations' concerns that the margin of safety is decreasing -- before regulatory requirements are breached and safety is compromised. Therefore, the Team concluded that a lack of senior management support for Operations' leadership role was the root cause of this adverse condition.

5.2 Contributing Causes

Three contributing causes were identified. Although none of these factors alone caused the erosion of Operations' leadership role, each of them contributed to it.

1. Staffing was inadequate to perform the tasks assigned. There was an inadequate number of licensed personnel to complete assigned work without excessive overtime hours, to participate in station decision-making, and to provide leadership in the activities of other station organizations. In addition, resources in other site organizations were insufficient to support Operations' priorities in assuring sustained safe operations.

2.

Senior management failed to ensure that regulatory expectations for licensed personnel were effectively communicated and reinforced. Senior management did not ensure that station personnel at all levels understood the command and control authority of licensed operators on-shift. Appropriate roles, responsibilities and authorities were not documented in policies, procedures, and other documentation, expectations were not communicated and reinforced through training, and management behavior was inconsistent with the expectation that Operations would lead the site. Further, changes in management personnel resulted in the communication of inconsistent expectations regarding Operations' leadership role.

3.

Senior management failed to assure that a safety conscious work environment was established and maintained in Operations. Management engaged in behaviors that created a chilling effect in Operations by failing to encourage, and sometimes appearing to punish, a questioning attitude and the raising of safety concerns. Aggressiveness in pursuing the resolution of operational problems was discouraged by repeated failures.

5.3 Related Observations

The Team made three additional observations regarding factors affecting Operations' leadership role, as follows:

1. Operations personnel have not been provided all of the necessary tools and equipment to perform their tasks efficiently. Recent remodeling efforts have resulted in a lack of access to desks, computers, filing cabinets, and permanent telephones for some Operations personnel. For example, Assistant Shift Managers and other SROs struggle to locate workspace for performing CR reviews, completing procedure changes and reviews, and other administrative tasks. Further, not all of the station databases and software required for Operations activities are accessible from every computer used by Operations personnel and some personnel require additional training in computer skills.

2. Communication across shifts is a challenge. Communication across shifts within Operations, and between Operations and other station work groups is a challenge under any circumstances. The lack of consistent access to e-mail for all Operations personnel contributes to communication difficulties. A Monday evening telephone conference has been instituted that includes the Operations Manager, the Superintendents, and Shift Managers and appears to have improved cross-shift communications. Additional technologies, such as the assignment of cell phones to all Operations personnel, and implementation of additional processes to enhance communications appear to be warranted to ensure that necessary information is communicated among all Operations personnel to support their leadership role.

6.0 Extent of Condition

Based upon the information considered by the Root Cause Analysis Team and the information documented in the Management and Human Performance Root Cause Report in response to CR 2002-0891, the Team believes that other station departments were also adversely affected by some of the same factors identified in Section 6. In response to the Management and Human Performance Root Cause Report, a Management and Human Performance Excellence Plan was developed and is being implemented. The Management and Human Performance Excellence Plan includes a series of reviews of selected station organizations that include, for example, checks of whether there are clear lines of authority and responsibility within the organization; whether staffing levels and resources are sufficient to handle assigned responsibilities; whether individuals have a clear description of their assigned responsibilities; and whether interfaces with other organizations are clearly defined. In addition, a number of actions are being implemented to strengthen the safety conscious work environment across the site. The Team concludes that these efforts should identify needed corrective actions for similar problems to those identified with regard to Operations' leadership role at Davis-Besse.

7.0 Corrective Actions

This section repeats each of the root and contributing causes in Section 6, and then identifies applicable corrective actions.

7.1 Corrective Actions for the Root Cause

Senior management support for Operations' leadership role was missing.

Corrective Actions:

- a. Extensive changes have been made in the officers, directors, and managers responsible for Operations, including changes in the Site Vice President, Plant Manager, Operations Manager, Operations Superintendent, and Operations Support Superintendent. These individuals value strong Operations' leadership.
- b. Senior management is demonstrating support for Operations' leadership role by being visible and active in Operations' activities, such as shift turnover meetings, by appropriately mentoring and coaching Operations' personnel in resuming the leadership role, and by ensuring that Operations' priorities are addressed and supported in station decision-making. The Nuclear Quality Assurance organization will periodically assess the implementation and success of these activities.
- c. A declaration from the chief executives will be issued and communicated to site personnel delineating Operations' leadership role.
- d. The Operations leadership team will disseminate the results of this Root Cause Analysis and the corrective actions to other station managers, will ensure that other station organizations dedicate the time required to internalize the impact of Operations resuming the leadership role on their activities, and will resolve any issues identified in implementing the change.
- e. Senior management will assure that no uneasiness remains among Operations personnel regarding the station's ability to operate safely prior to restart. Shift Managers will be charged with eliciting any outstanding safety concerns from their crews and for ensuring that the concerns are resolved. Davis-Besse will not restart until each Shift Manager is willing to state that he and his crew know that the plant is ready to restart, that Operations has regained and is performing the site leadership role, and that the plant will operate safely.

7.2 Corrective Actions for Contributing Causes

7.2.1 Staffing was inadequate to perform the tasks assigned.

Corrective Actions:

- a. Continue hiring new personnel to be trained as equipment operators and continue training of RO and SRO candidates. Continue implementing current plans for additional licensing classes to replenish and maintain a sufficient number of licensed personnel for the tasks assigned, as well as to populate other departments with personnel who maintain active licenses.
- b. Analyze the tasks currently assigned to Operations. Identify additional activities that Operations must perform to continue re-establishing and to maintain leadership. Determine the number of personnel and the qualifications required to perform the activities identified. Develop and implement short-term compensatory measures for staffing shortfalls that are identified.
- c. Address Operations' compensation, as necessary, to ensure retention of current staff. Improve the station's competitive position in attracting desirable applicants. Continue current activities to develop and implement professional development plans for Operations personnel to ensure that career paths are identified and that future site leaders will be available and prepared to assume leadership roles.
- d. Implement corrective actions for staffing needs identified in other station organizations to ensure staff capabilities exist to support Operations' priorities.

7.2.2 Senior management failed to ensure that regulatory expectations for licensed personnel were effectively communicated and reinforced.

- a. Prior to restart, Operations and management personnel from other station organizations will receive corporate training regarding the roles, responsibilities and authorities of licensed personnel. This training course will be added to the core continuing training program for Operations and management personnel.
- b. The Site Vice President will continue to make himself available to the Duty Shift Manager to assist in ensuring that personnel in other station organizations understand his expectation that they are accountable to the Duty Shift Manager and to Operations personnel and must support Operations' leadership role.
- c. Management will ensure that an invitation is extended to NRC representatives to address newly licensed or upgraded operators when

they are awarded their licenses, and to address Operations Department personnel periodically to communicate and reinforce NRC expectations, as appropriate.

- ☒ d. An Operations Standards and Expectations document has been issued to address, in detail, expectations, job standards, and responsibilities of Operations Department personnel. Knowledge of these standards and expectations will be reinforced by training and testing prior to restart.
- ☒ e. A memo signed at the highest level defining the Shift Manager's role, responsibilities and authorities will be issued and conspicuously posted in selected areas throughout the site. This memo will be revised and reissued on an annual basis.
- ☒ f. The Operations Leadership Plan will be reviewed and approved by senior management.
- ☒ g. As part of the Management and Human Performance Excellence Plan, policies, procedures, program and job descriptions, and organizational interfaces are being reviewed for consistency with management expectations. As part of these reviews, opportunities to strengthen Operations' leadership role will be identified and incorporated. For example,
 - i. Requirements will be added to the corrective action process to ensure that Operations' concerns are adequately addressed in the prioritization, scheduling and resolution of condition reports.
 - ii. Operations' involvement in station decision-making processes will be strengthened. Operations' representation will be required at Management Review Board, Corrective Action Review Board, Station Review Board, and Project Review Committee meetings, and that Operations input will be sought in other station decision-making processes, as appropriate. These important decision-making meetings will not occur unless a designated Operations representative is present.
- ☒ h. Licensed personnel will fully commit to resuming the leadership role.

7.2.3 Senior management failed to assure that a safety conscious work environment was established and maintained in Operations.

- ☒ a. The Operations Standards and Expectations document will address the chilling effect in Operations by including expectations for Operations personnel to raise any operational concerns. It also contains the requirement for Operations personnel to demonstrate leadership in resolving concerns by continuing to escalate them through their management chain up to and including the President of FENOC until

resolution is obtained. Davis-Besse and FENOC senior management expect Operations personnel to inform the NRC of their concerns, if management does not address the concerns to their satisfaction.

- b. Licensed operators will be delegated management authority for addressing and resolving safety concerns that are identified to them by other station personnel.
- c. Consistent with their leadership role, Operations personnel at all levels will be given training in maintaining a safety conscious work environment to ensure that their leadership and oversight of station activities performed by personnel in other departments is conducted in accordance with management expectations.
- d. Individuals appointed to the open Site Vice President and Operations Superintendent positions will be thoroughly screened prior to appointment to ensure that their management styles will support a safety conscious work environment in Operations.
- e. Operations personnel and managers in all station organizations will comply with senior management requirements and NRC expectations for ensuring that a safety conscious work environment is maintained. 210 of 250 site managers have recently completed safety conscious work environment training for supervisors, and the remainder will complete training by December 4, 2002.
- f. Reports from site-wide surveys and assessments of the safety conscious work environment in Operations will be provided to the Plant and Operations Managers, and any weaknesses identified will be promptly addressed and resolved.
- g. Davis-Besse will complete implementation of the Safety Conscious Work Environment Action Plan as part of the Management and Human Performance Improvement Plan.

7.3 Corrective Actions and Proposed Enhancements for Observations

Operations personnel have not been provided all of the necessary tools and equipment to perform their tasks and communicate efficiently.

Corrective Actions:

- a. Provide permanent workspaces for Operations personnel.
- b. Consider increasing the use of additional technologies and practices to support communication, such as the assignment of cell phones to all

Operations personnel that can be used for individual communication as well as group distribution messages.

8.0 Experience Review

Section 7 of the Root Cause Analysis Reference Guide and Attachment 11 of the Programmatic Guideline for the Davis-Besse Condition Report Process state that a review of similar experiences at the plant and across the nuclear industry should be conducted to determine:

- whether past occurrences of similar problems indicate a generic or broader scope issue,
- why prior corrective actions for similar problems were not effective, and
- whether the currently proposed preventive actions are different so as to be more effective.

This section also discusses why the currently proposed corrective actions are different from those taken in response to previous Davis-Besse and industry experience, and why the proposed actions should be more effective.

To identify relevant past experience, keyword searches of several databases were performed. The INPO Operations Experiences Database and Davis-Besse's CATS and CREST databases were searched. Search terms included: safety conscious work environment, safety focus, command and control, leadership role, management expectations, regulatory expectations, questioning attitude, command function, involvement, and accountability.

8.1 Recent Assessments of Davis-Besse Related to Operations

Symptoms of the decline in Operations' leadership role at Davis-Besse were identified in four previous assessments. These assessments were performed within the past three years.

8.1.1 1999 RHR Organizational Assessment

An organizational assessment was conducted by RHR International in June-July, 1999. The assessment identified many of the conditions that were described to the current Team regarding past organizational problems at the site, as follows:

- Headcount and cost-cutting
- The site had a pure operating orientation until the 1990s and a business planning mentality did not exist
- Reliability and cost have become critical success areas
- Many want to return to the basics

- Perception is the site got behind
- Silos exist among the different units
- A gulf exists between the Directors and other levels
- Many managers avoid raising bad news
- Directors rely on command-and-control
- Key people were drained off
- Little attention goes to attracting and developing talent
- Managers avoid rocking each others' boats
- Criticism can be personal and blaming
- Decisions are made within silos
- Little emphasis exists on safety and performance at all costs
- Management rarely scans for subtle problems

The results of the assessment were communicated to senior site management, but the current Team was unable to verify that corrective actions were taken at the time. Senior management personnel at the site who received the information are no longer in those positions and were not contacted.

8.1.2 June, 2001 Operations Self-Assessment

Prior to a scheduled INPO audit, Operations completed a self-assessment in June, 2001 (CR 2001-1458) to identify strengths and weaknesses in the following INPO performance areas:

- Operations
- Safety Culture
- Plant Status Control

The self-assessment identified only one weakness in Operations regarding the failure to include the Shift Manager as a member of upper management. Several corrective actions were developed and some were implemented at the time.

One corrective action that was implemented was holding an offsite meeting on October 29th, 2001, for teambuilding purposes and to address needed steps for enhancing the Shift Manager's leadership position at the site. Minutes from that meeting show that the following items were discussed:

- Insufficient staffing to accomplish the tasks assigned.
- The need for an Operations Succession Plan.
- The need for Shift Managers to be informed of personnel decisions made by the Operations managers that affected the individuals on their crews.
- A plan to address pay issues for the SROs, Shift Manager professional development plans, and rotational assignment possibilities.
- The unwillingness of Shift Managers to take the Operations Superintendent position because they believed that the management team would not support the Operations Superintendent and that the position was powerless.
- The Shift Managers' desire to avoid attendance at the morning Managers Communication and Teamwork meetings because the meetings were perceived as "demoralizing."

Another corrective action to CR 01-1458 was to identify meetings and projects in which Shift Managers could participate to be more involved in management decision-making. This action was determined to be "not a priority at this time, but may be revisited at a later date as part of continuing Shift Manager development."

8.1.3 September, 2001 INPO Audit

Results of an evaluation conducted by INPO representatives during September of 2001 provided several additional indications of Operations' declining leadership role (CR 2001-2989). These included:

- Operations management had missed opportunities since 1998 to take clear ownership of safety tagging problems. Operations had not taken ownership of those aspects of the process that crossed disciplinary boundaries, such as ensuring that the work scope planned was completely covered by the clearance requested.
- Revised expectations for some work activities were not clearly established and communicated, and so were not being consistently implemented. Operators did not communicate to management that some of the standards and expectations could not be implemented as written.

- In some instances, shift management did not thoroughly question or challenge initial Engineering recommendations about the status of important equipment deficiencies.
- Expectations for Shift Manager and Field Supervisor oversight of normal day-to-day plant operations were not established. The Shift Manager, Shift Engineer, and Field Supervisor were observed to spend most of their time in administrative duties.
- A misalignment within Operations was identified in that expectations were not clearly and consistently reinforced, due, in part, to recent changes that had occurred in Operations management.

A number of corrective actions were implemented in response to CR 2001-2989 and some are still on-going. The effectiveness of the actions will be evaluated by December 22, 2002. The current Operations Leadership Plan includes additional items to address the results of the INPO audit. Corrective actions to CR 2001-2989 that have been implemented to-date include:

- Benchmarking trips to identify opportunities to enhance performance have been conducted;
- The safety tagging procedure has been revised and staff within Operations have been assigned as owners;
- Weekly telephone conferences and monthly meetings among Shift Managers and Operations management personnel have been institutionalized to enhance inter-shift communication; and
- A revision to the Operations Standards and Expectations Directive has been completed.

8.1.4 2001 Nuclear Quality Assessment Audit

A Nuclear Quality Assessment audit of Operations was performed during the period of August 13 through November 7, 2001. The audit team concluded that the Operations Program was effectively implemented and overall performance was rated as satisfactory. The audit team also noted, however, that Shift Engineers and SROs appeared to be overburdened by administrative duties while on-shift, there was a low number of staff available to perform procedure reviews and other administrative work, performance expectations in policies and procedures had not been updated, and that workspace for performing administrative duties was insufficient. The auditors noted that actions were being taken to address staffing shortages, but that the efforts had not been effectively communicated to Operations personnel. The audit did not address Operations' interfaces with other station organizations nor the effects of management styles on the Department.

8.1.5 Conclusions

The results of these assessments indicate that evidence of the decline in Operations' leadership role was identified prior to this Root Cause Analysis. Some corrective actions were developed and implemented, but it does not appear to the Team that the potential consequences for nuclear safety of the management and organizational issues occurring in Operations were previously considered. Again, however, in the absence of senior site management support for addressing the "chilling effect" in Operations or for resolving the types of organizational issues that were identified in the RHR report and subsequent assessments, it is unlikely that corrective actions that Operations might have considered taking would be effective.

8.2 Related Industry Experience

Numerous examples of industry events that shared at least one characteristic with the adverse conditions found by this Team were identified in the INPO databases. The four incidents that best matched the causal factors described in this Report are discussed in this section.

8.2.1 SER 93-28, Increased Leakage from an Unsolvable Reactor Coolant Leak after Repeated Sealant Injections

In 1993, Millstone Unit 2, then operated by Northeast Utilities, was shut down from 100 percent power when reactor coolant leakage from a manual isolation valve inside the reactor containment building exceeded technical specification limits. The leak was first discovered after a reactor scram in May, 1993, and corrective actions were taken, but they were ineffective. The leakage did not exceed regulatory limits, so the reactor was returned to 100 percent power. Repeated attempts at on-line leak repairs were made over the next 2.5 months. During the final repair attempt on August 5, the leak rate suddenly increased to an unacceptable level and the reactor was manually shut down.

Station personnel who were involved in the repairs raised questions several times regarding the possible consequences for valve integrity of the repair attempts. A through-wall crack in the body of the valve was suspected at one point, and a recommendation was made to shut down the plant. The recommendation was not implemented.

Extensive analyses of the causal factors for this event have been published elsewhere and indicated that an emphasis on production over nuclear safety at corporate and senior management levels, and chilling effects, were root causes for the event. The INPO SER also noted the following:

- Because senior management did not question the repeated attempts at repairing the valve, plant personnel saw this as implicit approval for continuing to repair the valve at-power.

- Station management recognized that permanent repair required a unit shutdown to replace or rebuild the valve. However, it was decided to continue attempts to repair the valve at power to maintain production goals.
- The decisions to continue attempts to repair the valve were based on engineering analysis of the structural integrity of the valve design. Safety evaluations to assess the potential impact and consequences of catastrophic valve failure were not performed.
- Station management justified continued operation because the overall leak rate was within technical specifications. This focus and mind set affected the judgment of many even when there was evidence of another potential problem with the valve.

Among other recommended corrective actions, the SER states:

Senior nuclear managers should periodically emphasize to nuclear organization personnel that nuclear safety considerations always take priority over production goals and that station personnel are expected to conduct nuclear-related activities to the highest standards. Examples of both proper and improper decisions affecting nuclear safety should be communicated to promote improved understanding of these management expectations. Plant staff periodically should receive reinforcement, through training and management coaching regarding their unique responsibilities for the safe operation of their nuclear units. To meet these demanding responsibilities, plant personnel must hold themselves and each other accountable to the highest standards of performance. As nuclear professionals, nuclear plant staff members must make decisions that reflect an overriding emphasis on protecting the reactor core.

The Davis-Besse response to the Millstone event focused on the technical issues involved in the event, rather than the organizational issues. At the time, Davis-Besse was one of the few nuclear stations in the country that had already established an Ombudsman. The program had been in existence since the mid-1980s. Because the number of employee concerns brought to the Ombudsman was low, additional actions to respond to the safety conscious work environment aspects of the Millstone event did not appear to be necessary.

8.2.2 SER 1-97, Nonconservative Operations During Isolation of a Reactor Recirculation Pump Seal Leak

In September of 1996, Clinton Power Station personnel continued operations for approximately 16 hours with reactor coolant system pressure boundary leakage in excess of technical specification limits. The SER noted:

- Operators and line managers were focused on decreasing a reactor recirculation pump seal leak to allow continued plant operation. As a result, operators did not take conservative actions to deal with this potential threat to reactor coolant system pressure boundary integrity.
- Participation of line management personnel in the evolution, without clearly defined roles and responsibilities, resulted in confusion regarding the ultimate responsibility for making decisions affecting nuclear safety.
- Lessons learned from industry operating experience were not used effectively to provide operator and line management focus on nuclear safety over production goals.

This event was reviewed by Davis-Besse Operations personnel and several actions were taken in response, including:

- A simulator scenario was developed that included "pressure" from individuals outside the normal control room crew who were advocating that the plant should be kept on-line. The scenario was used as an introduction to a presentation on the event at Clinton and a discussion of management expectations regarding control room roles and responsibilities at Davis-Besse. All crews chose to conduct the plant shutdown required by Davis-Besse procedures and technical specifications.
- Davis-Besse guidance documents were also reviewed and it was determined that existing guidance and procedures were sufficient to ensure clarity of roles and responsibilities.

Although Davis-Besse's response to this SER was aggressive and the crews performed well, the scope of the corrective actions was limited to control room roles and responsibilities. Operations' leadership in plant support activities, such as Engineering, Maintenance, and decision-making processes, was not similarly emphasized. However, as the RPV head degradation event and others have repeatedly demonstrated, Operations' leadership in plant support activities is as important as leadership in the control room to ensure that nuclear safety is maintained.

8.2.3 OE 9944, Lack of Operator Awareness of Plant Equipment Status

A Quality Assurance Assessment at Clinton Power Station performed in 1999 identified several examples of Operations personnel lacking awareness of plant equipment status and failing to take ownership. For example, during shift turnover, complete information was not provided to the on-coming shift and on-coming ROs accepted incomplete answers to their questions. In one instance, control room equipment was released for operations for eight days before the information was communicated to the shift crews. Causal factors identified included the failure of shift and Operations management to consistently communicate, reinforce and hold personnel accountable, and shift managers and other shift personnel not fully internalizing the values of accountability and ownership. The Clinton Shift Managers noted that they allowed themselves to become involved in staff functions, such as tagout reviews, work order authorization reviews, and CR reviews in order to help others, rather than maintaining their management and oversight role.

Extensive corrective actions were implemented at Clinton to enhance Operations' awareness and ownership of plant equipment status. These included:

- The Plant Manager developed a Model for Plant Operational Focus. The model depicts organizational focus areas for Operations, Engineering, Maintenance, and Work Management, and their interrelationships. The Director of Operations reinforced these focus areas with the Shift Managers and their crews. The need for Shift Managers to take a leadership role in interfacing with other organizations was also communicated.
- Communications between crews was enhanced by setting up a central voice mailbox for discussion of emerging items, safety issues, new CRs and other information. Access to the mailbox ensured that Shift Managers had the same information as soon as it was available to communicate to their crews.
- Mentors for each Shift Manager were assigned to observe, coach and reinforce positive behaviors on the shift crews. Control room activities were monitored and personnel coached on appropriate responses to indicate ownership and accountability for understanding plant status and configuration.

This event report was disseminated to Davis-Besse Operations personnel for review, but it was not analyzed for applicability and no actions were taken to implement lessons learned at the site.

8.3 Differences between Previous and Proposed Actions

There are a number of differences between the previous corrective actions that were implemented in response to the findings of the internal assessments of Operations and the reviews of external operating events and those proposed in this Report. The most important difference is that, since December of 2001, the entire top tiers of management at Davis-Besse have changed. In particular, a new position of Chief Operating Officer has been created and filled, a new Plant Manager from outside of Davis-Besse has been appointed, every Director has been newly appointed (several from outside of Davis-Besse), and all of the managers within Operations have been replaced. Additionally, a new Vice President of Oversight position has been created and filled, and this individual is charged with strengthening the safety conscious work environment at Davis-Besse.

At the same time, an Operations Leadership Plan has been developed that integrates the findings of previous assessments of Operations, industry experience, and the results of this Root Cause Analysis. The Leadership Plan represents an integrated response to strengthening Operations' leadership role at the site, and addresses necessary changes both within Operations as well as changes in the relationships between Operations and other site organizations.

These actions are substantially broader and more comprehensive than previous corrective actions. Davis-Besse should perform reviews to ensure that the corrective actions specified in this report are effective.

9.0 Root Cause Analysis Team

The Root Cause Analysis Team consisted of two independent consultants who specialize in conducting root cause analyses and assessments of nuclear power plant organizational performance and a senior member of the Operations Department at Davis-Besse. The Team members were:

Valerie E. Barnes, PhD, Performance, Safety and Health Associates, Inc. (President and Senior Research Associate), Team Lead – Valerie Barnes received her PhD in Social/Organizational Psychology from the University of Washington in 1985. She has managed or played a key technical role in numerous research and technical assistance projects for the U.S. Department of Energy (DOE), the U.S. Nuclear Regulatory Commission (NRC), and other private sector and government sponsors undertaken to enhance the reliability of human performance. She has assisted in developing and delivering training for DOE accident investigators and Board Chairpersons since 1995, assisted the U.S. Chemical Safety and Hazard Investigation Board to develop its investigation procedures and protocols, and recently published a guidance document to assist NRC inspectors in evaluating licensee investigations and root cause analyses for human performance problems. Dr. Barnes has applied her expertise in more than 100 audits, inspections and event investigations that have addressed a variety of human performance issues.

Brian C. Haagensen, Performance, Safety and Health Associates, Inc. (Managing Director and Executive Vice President) – Brian Haagensen is a senior management consultant with 30 years of experience in the nuclear industry. He has worked at 75% of the nuclear power plants in the country today. He was the project manager and lead expert for management and organization support to all NRC Diagnostic Evaluations Team Inspections from 1991 to 1995. He personally participated in three NRC Diagnostic Evaluations as the lead management and organization consultant (South Texas Project, Palisades and Maine Yankee). He was a certified NRC Operator Licensing Examiner from 1986 until 1995 and participated in over 75 exams throughout the country. He also supported numerous NRC inspections including emergency operating procedures inspections, Augmented Inspection Teams, Emergency Preparedness Inspections, Exercise Evaluations, Part 21 vendor audits and training inspections. He has an extensive background in corrective actions including support of the Indian Point corrective action program self assessment and preparations for the NRC's 95003 multiple degraded cornerstone inspection. He has received formal training in root cause assessment techniques including MORT, Kepner-Tregoe, and HPIP. He was the lead operations representative on the NRC's shift staffing study conducted by Brookhaven National Laboratory. He co-authored the NRC's Human Performance Evaluation Process (HPEP) NUREG/CR-6251. He has a Masters of Science degree in physics and was a nuclear submarine officer from 1974 to 1982.

Douglas Ricci – FENOC (Davis-Besse, Operations Supervisor) - Douglas Ricci has worked in the field of nuclear energy for 36 years and for the Toledo Edison/Centerior Energy/First Energy organization for more than 31 years. Doug was licensed as a Reactor Operator for almost 2 years and as a Senior Reactor Operator for over 22 years. Doug has held the positions of Reactor Operator, Assistant Shift Supervisor, Shift Supervisor, and Supervisor – Operations while at Davis-Besse Nuclear Power Station. He is trained as an INPO Root Cause Coordinator, an INPO Human Performance Fundamentals Course facilitator, and is a qualified Root Cause Evaluator.

10.0 References

The following is a list of references reviewed in preparation of this Report.

10.1 Davis-Besse References

Procedures

- DB-OP-00000, Conduct of Operations
- DB-DP-00022, Station Review Board
- DB-FP-000005, Fire Brigade
- GP-01, Conservative Operations
- GP-25, Shift Expectations
- DSP-90-00016, Command Responsibilities
- NT-OT-07007, Fire Brigade Training
- NG-DB-00302, Davis-Besse Nuclear Power Station Fire Protection
- NOP-OP-1001, Clearance/Tagging Program
- NOP-LP-2001, Condition Report Process
- Operations Standing Order 00-006, Configuration Control Action Plan
- Operations Standing Order 00-011, Interim Operations Performance Requirements
- Operations Standing Order 01-008, Failure to Perform DB-SC-03023 when EDG #2 Paralleled to D1 Bus
- Operations Standing Order 02-006, Interim Safety Tagging Guidance
- Corrective Action Program Reference Guide Rev 5
- Nuclear Operations Admin-1 Rev 17
- Delegation of Authority Admin-9 Rev 20
- Corrective Action Tech-3 Rev 18
- Root Cause Analysis Tech-26 Rev 1
- Condition Report Process – Programmatic Guideline
- Charter - Corrective Action Review Board
- Charter - Davis-Besse Project Review Committee
- Davis-Besse Project Review Group Charter Rev 3 and Rev 4
- Duty Shift Supervisor Duties and responsibilities Tech-19 Rev 19
- FENOC – Root Cause Analysis Reference Guide Rev 3
- Corrective Action Policy, Tech-3 Rev 0 and Rev 15 thru Rev17

Potential Condition Adverse to Quality Reports

- 1998-0020, RC-2 with Root Cause Analysis Report
- 1998-0046, Insulation for RC-2 Removed for Inspection and Not Reinstalled
- 1998-0649, Inspection Results of Reactor Vessel Head

- 1998-0650, Video Inspection Results CRDM Nozzle/Head Interface
- 1998-0767, Reactor Vessel Head Inspection Results
- 1998-0824, CAC's 2 and 3 Have Accumulated Boric Acid
- 1998-0915, Yoke on RC-2 is Corroded
- 1998-1642, Apparent Missing Nut
- 1998-1681, Missing Body to Bonnet Stud Nut
- 1998-1716, Functional Evaluation of RC-2 for Past Operability
- 1998-1797, Operations Accreditation Team Findings
- 1998-1799, RC-2 MWO Package Discrepancies
- 1998-1885, RC-2 Carbon Steel Nuts
- 1998-1887, Nut in Containment
- 1998-1904, 1998 Collective Significance Review
- 1998-1924, Functionality of RC-2 as a RCS Pressure Boundary
- 1998-1980, Containment Cooler Plenum Pressure Decreasing
- 1998-1981, HP-0057 Body to Bonnet Bolting
- 1998-1988, RC-2
- 1998-0020, Multiple Problems with RC-2

Condition Reports

- 1999-1614, LER 1998-009
- 2000-1001, RC-2 Spray Valve Problems
- 2001-1747, CARB Charter Compliance
- 2001-1748, Corrective Action Review Board Recommendations
- 2001-2862, Potential Adverse Trend in Unidentified RCS Leakage
- 2001-3025, RCS Leakage
- 2002-02584, Implementation of Corrective Action Program By Site Personnel
- 2002-02585, Management and Supervisory Oversight and Ownership of Plant Activities

Audits

- Audit Report AR-00-ONF-01
- Quality Assessment Audit Report AR-02-OUTAG-01

Job Descriptions

- Plant Manager Davis-Besse Plant Operations
- Manager - Operations Davis-Besse Plant Operations
- Manager – Maintenance Davis-Besse Plant Operations
- Manager – Plant Engineering Davis-Besse Plant Operations
- Manager – Design Basis Engineering Davis-Besse Engineering and Services
- Manager – Quality Assessment Davis-Besse Nuclear Assurance

- Manager – Radiation Protection Davis-Besse Plant Operations
- Director – Engineering and Services Davis-Besse Engineering and Services
- Open Position Announcement – Manager, Nuclear Outage
- Open Position Announcement – Manager, Nuclear Environmental and Chemistry

Other Station Documents

- Human Resources Performance Management ownership for Excellence Guideline Forms: Executive level Competency/Behavior Forms
- Human Resources Performance Management ownership for Excellence Guideline Forms: Manager level Competency/Behavior Forms
- Human Resources Performance Management ownership for Excellence Guideline Forms: Supervisor level Competency/Behavior Forms
- Human Resources Performance Management ownership for Excellence Guideline Forms: Individual Level Competency/Behavior Forms
- Root Cause Analysis Report Significant Degradation of the Reactor Pressure Vessel Head, CR 2002 -891 (Management and Human Performance Root Cause Analysis Report)
- Management and Human Performance Excellence Plan, September 5, 2002
- Minutes of the October 29, 2001 Shift Manager Team Meeting
- Minutes of the October 26, 2002 Shift Manager's Meeting
- FENOC Nuclear Market Survey, Operations 2002
- E-mail from Dee Laberdee Haskins to Doug Ricci, 11/12/02, Compensation Matrix
- MPO-00-013, Operations' On-Shift Staffing, 6/9/99
- Nuclear Group Staffing Report, 1991-1997
- Operations Overtime Call-Out Reports (1998-2002)

10.2 NRC References

1. RC-2 NRC Special Inspection Report 350-346/98021
2. SEN 190, Pressurizer Spray Valve Bonnet Nuts Dissolved by Boric Acid Leak
3. Baker, T. (1995). *Alertness, performance and off-duty sleep on 8-hour and 12-hour night shifts in a simulated continuous operations control room setting* (NUREG/CR-6046). Washington, DC: U.S. Nuclear Regulatory Commission.
4. Haber et al. (1995). *Nuclear Power Plant Shift Staffing Levels: Site Data Collection Report* (Accession No. 9510030160). Upton, NY: Brookhaven National Laboratory.
5. Information Notice 79-20, NRC Enforcement Policy – NRC Licensed Individuals

6. IE Circular 81-02, Performance of NRC-Licensed Individuals While on Duty
7. Information Notice 85-53, Performance of NRC-Licensed Individuals While on Duty
8. Information Notice 91-77, Shift Staffing at Nuclear Power Plants
9. Information Notice 95-23, Control Room Staffing Below Minimum Regulatory Requirements
10. Inspection Manual, Inspection Procedure 71707, Plant Operations
11. Inspection Report 50-346/02-03, NRC Augmented Inspection Team – Degradation of the Reactor Pressure Vessel Head
12. Policy Statement on the Conduct of Nuclear Power Plant Operations (rec'd 1/23/89)
13. Regulatory Guide 1.114, Guidance to Operators at the Controls and to Senior Operators in the Control Room of a Nuclear Power Unit (May, 1989, Rev. 2)
14. Regulatory Guide 1.8, Qualification and Training of Personnel for Nuclear Power Plants (May, 2000, Rev. 3)
15. Shurberg, D et al. (1994). *Identification of Issues Associated with Nuclear Power Plant Shift Staffing Levels, Task 1 Letter Report* (Accession No. 951003074). Upton, NY: Brookhaven National Laboratory.
16. 10 CFR 55, Operators' Licenses
17. 10 CFR 50.54, Conditions of Licenses
18. NUREG-0800, Chapter 13, Operating Organization

10.3 INPO References

1. ACAD 97-004 Guidelines for Shift Manager Selection, Training and Qualification, and Professional Development
2. INPO Excellence in Human Performance (draft, August, 1997)
3. INPO 01-002 Guidelines for the Conduct of Operations at Nuclear Power Stations
4. OE 9944 Lack of Operator Awareness of Plant Equipment Status
5. SOER 81-12 Reactor Coolant Pump Closure Stud Corrosion
6. SOER 84-5 Bolt Degradation or Failure in Nuclear Power Plants
7. SOER 98-1 Safety System Status Control
8. SER 1-97 Nonconservative Operations during Isolation of a Reactor Recirculation Pump Seal Leak
9. SER 93-28 Increased Leakage from an Unisolable Reactor Coolant Leak after Repeated Sealant Injections
10. SER 46-80 Reactor Coolant Pump Closure Stud Corrosion
11. SER 35-81 Corrosion of Reactor Coolant System Piping
12. SER 11-82 Reactor Coolant Pump Closure Flange Stud Corrosion
13. SER 57-83 Cracking in Stagnant Boric Acid Piping
14. SER 72-83 Damage to Carbon Steel Bolts and Studs on Valves in Small Diameter Piping Caused by Leakage of Borated Water

10.4 Other References

1. RHR International Davis-Besse Phase 2 Organization Study Results June – July 1999
2. Baker, K., Olson, J. and Morisseau, D. (1994). Work practices, fatigue, and nuclear power plant safety performance. *Human Factors*, 36, 244-257.
3. Fiedler, F.E. (1967). *A theory of leadership effectiveness*. New York: McGraw-Hill, 1967.
4. Howlett, H.C. (1995). *The industrial operator's handbook: A systematic approach to industrial operations*. Pocatello, ID: Techstar.
5. Landy, F. and Trumbo, D. (1976). *Psychology of work behavior*. Homewood, IL: The Dorsey Press .
6. Loftus, E. (1996). *Eyewitness testimony*. Harvard University Press.
7. Merritt, A.C. and Helmreich, R.L. (1996). *Creating and sustaining a safety culture*. *CRM Advocate*, 1, 8-12.
8. Muschara, T. (2000). INPO Human Performance Evaluations and Other Developments. In *Proceedings of the 2000 Human Performance Root Cause Trending Workshop*. Philadelphia, PA: June 12-15, 2000.
9. R.C. Brown and Associates, Management Consultants (December 31, 1996). Final Report of the Focused Audit of the CL&P Nuclear Operations, R. C. Brown and Associates, prepared for the Connecticut DPUC.
10. Reason, J.T. (1990). *Human error*. Cambridge: Cambridge University Press.
11. Reason, J.T. (1997). *Managing risks of organizational accidents*. Burlington, VT: Ashgate Publishing.

Enclosure 3

Assessment of Company Nuclear Review Board

**ASSESSMENT OF THE FENOC
COMPANY NUCLEAR REVIEW BOARD**

Prepared for
First Energy Nuclear Operating Company

Prepared by
Darrell G. Eisenhut

August 13, 2002

Assessment of the FENOC Company Nuclear Review Board

1.0 Purpose and Approach

This Report summarizes the results of an assessment, conducted during July-August 2002, of the FENOC Company Nuclear Review Board. The Purpose of this Assessment was stated to be:

Assess the Company Nuclear Review Board's (CNRB) past and going forward oversight role as it relates to the missed opportunity for identifying the reactor vessel head issue. Provide recommendations for improving the safety focus of the CNRB.

A large amount of material was collected and reviewed to better understand the FENOC requirements for the CNRB, and how the CNRB presently functions. These addressed its structure, composition, expertise of members, attendance, reporting, etc. *A listing of documents reviewed is attached to this Assessment.* A meeting of the CNRB (at Beaver Valley on July 16-17, 2002) was attended to observe the functioning of the CNRB. Meetings, discussions, and interviews of CNRB members, management and staff were conducted, both at Beaver Valley, and also at Davis-Besse during the week of July 22, 2002.

In addition, considerable information relating to the actual Davis-Besse reactor head degradation issue was reviewed including the sequence of events, selected Condition Reports, the Root Cause Report, the Return to Service Plan, and numerous other supporting documents. Also reviewed were several memoranda of a FENOC staff member (J Hultz) who was on distribution for CNRB information and who provided his reaction to that information to FENOC management. While this review of information provided a broad-based perspective on the history of the reactor vessel head issue, the scope of this assessment was limited and focused on understanding information provided to the CNRB, the information available to the CNRB, and the CNRB's response to that information.

2.0 FENOC Requirements for CNRB

The requirements for the Davis Besse CNRB are contained in Section 13.4.2 of the plant's Updated Safety Analysis Report (USAR). The USAR (Rev. 22, dated 11/2000) states that the CNRB "*shall function to provide independent review and audit of designated activities...*"

The USAR further states that the Company Nuclear Review Board shall review a number of technical areas, including:

- f. Significant operating abnormalities or deviations from normal and expected performance of plant equipment that affect nuclear safety*
and,
- h. All recognized indications of an unanticipated deficiency in some aspect of design or operation of safety related structures, systems, or components.*

The FENOC Policies and Practices (Rev 14, effective 05/06/2002) for the Company Nuclear Review Board support, and elaborate on, the basic charter. It specifically notes:

- Section 2.0 – "*The CNRB shall function to provide an independent audit and review of plant activities to assure itself*" that the stations are "*being safely operated and maintained.*"
- Section 4.2.1 indicates that the CNRB is responsible for "*Informing the FENOC President Nuclear on any CNRB issue relative to the safe operation of the Davis-Besse, Perry or Beaver Valley*" plants, and
- Section 9.1 states that "*CNRB members individually performing review of an activity or action shall not have been responsible for that activity or action under review.*"

The FENOC Quality Assurance Program manual contains similar requirements.

3.0 Implementation of the CNRB function

The implementation of the FENOC CNRB function generally follows the guidance in the company's USAR and Policies and Procedures document. For example:

- The CNRB is composed of both internal and external individuals having the required expertise,
- CNRB members routinely receive a wide variety of plant specific information for review in advance of meetings,
- CNRB meetings are held on a periodic basis at each station to review safety issues and to discuss overall performance (currently six times per year; twice at each station; for a minimum of three days each),
- CNRB meetings are reasonably well attended by both internal and external membership, and minutes indicate that a quorum was present,
- External consultant members periodically travel to the plants to observe activities and have discussions,
- External members review materials while "offsite" in preparation for discussions,
- The CNRB currently has one industry peer advisor as a member,
- In 2001, each external member devoted a significant amount of time (on the average about 480 hours) to the review of materials to support the CNRB review function, and
- There is no readily available means to estimate internal member's efforts.

4.0 Information Available to the CNRB

The CNRB did not identify the severely degraded reactor vessel head condition present at Davis-Besse. Records also suggest that the CNRB did not inform senior company management of the issue, nor provide any specific recommendation regarding it to FENOC management.

A review of CNRB materials, including meeting minutes, 'hand-out' and presentation materials, and Subcommittee minutes, indicates there were several discussions at CNRB meetings that suggested a primary system degradation issue existed at Davis-Besse. Examples of information provided to CNRB members and discussion topics at CNRB meetings included:

- Boric acid plating out on containment air coolers (1-99),
- Updates on reactor coolant system unidentified leakage (5-99, 3-01),
- Frequent required change out of radiation filters (7-99),
- Presence of iron deposits on filters and a requested SRI analysis (7-99), and
- Information that all nozzles were not inspected in previous outages (11-01).

Other supporting information that was available in review documents was more specific:

- Indications of rust or brown stained boron on the head (4-96),
- A finding of 'fist size clumps' of boric acid (4-98),
- A Southwest Research report noting iron oxide and corrosion (7-99),
- Red/brown boric acid leakage being noted (4-00),
- A discussion of accumulation of boron on the head (4-00), and
- A discussion of the need for a Project Plan for J-groove cracking (5-01).

(A more detailed listing of selected information that was made available to CNRB members is set forth in Attachment A.)

The availability of this information must be viewed in perspective. The CNRB received information on these Davis-Besse plant-specific issues during the same time period that the industry (including the CNRB members) was receiving operating experience reports of boric acid corrosion problems in the industry, and receiving several communications from the NRC identifying concerns regarding boric acid corrosion of carbon steel in PWRs. While this occurred over a long period of time dating from the 1980s, it was particularly focused on cracking of PWR vessel head penetration nozzles beginning in about 1997 and continuing through 2001. In fact, the NRC Information Notices, Bulletins, and Generic Letters were issued to call particular attention to the potential problems, and Davis-Besse was identified as a plant susceptible to the issue.

While this information was made available to the CNRB, no specific questioning or follow-up on the issue appears to have occurred by CNRB members. While there was limited discussion of the plant's reactor coolant leakage, the collective significance of the many indicators of problems appears to not have received appropriate safety focus. It should also be noted that plant management did not identify the collective significance of these indicators regarding boric acid on the reactor vessel head, or at least did not so inform the CNRB.

In summary, it is apparent that CNRB members received plant-specific information (and that additional relevant information was available if requested) and that considerable industry communication was provided regarding this issue, that should have suggested an ongoing degradation issue or concern related to the integrity of the reactor primary coolant system. Given the several specific alerts received from other nuclear industry organizations and those received formally from the NRC, it is reasonable to expect that the CNRB should have raised questions regarding the boric acid corrosion issue.

5.0 Conclusions and Recommendations

The following summarizes the conclusions of the assessment and any associated recommendations.

- The CNRB failed to identify the reactor vessel head degradation issue. While the CNRB is an important safety review function for the station, it is but one of the several levels of safety protection that failed. The CNRB process failed and as such the issue should be viewed as broader than one “missed opportunity.”

Senior management should ensure that all CNRB members recognize that the CNRB function failed to provide the expected level of safety protection at the station. Management should guard against any defensive reaction (e.g., “no one told us of the problem”) and focus on the need to ensure that steps are taken to improve the chances of identifying such a concern if one were to occur in the future.

- Based on an observation of a CNRB meeting, the “Expectations” for the CNRB appear to not be clear. An observer has some difficulty in determining whether the CNRB meeting is more typical of a management review committee meeting, or a meeting whose primary purpose is to focus on technical/safety topics at the plants. In the CNRB meeting attended, there was generally too much attention directed at how better to manage the station, on reviews of technical matters of limited significance, and on somewhat administrative matters. There was less focus on technical and operational issues, and on potential safety issues.

It is recommended that senior management review the functioning, the structure, and membership of this important safety review entity for the station. Management should establish, or reiterate, the expectations for the CNRB particularly clarifying that its role is primarily a safety-focused organization and not a management unit of the station.

- The CNRB meeting and the information presented and reviewed, had little focus on operational, technical, and safety topics. A review of presentations and meetings minutes from recent meetings indicates that they are generally superficial and not focused on specific operational or technical challenges for the station. They instead focus on general, more production-oriented indicators, with little emphasis on technical/safety oriented performance indicators.

Senior management should ensure that the CNRB's focus is primarily on "safety, or matters that could directly affect safety." Production-oriented presentations should be avoided. Briefings should be re-directed towards operational, technical, or safety "issues" challenging the station. Specific factual information to support such issues should be presented, including better use of appropriate performance indicators.

- The CNRB may not be meeting its charter to provide an independent safety audit function. It was indicated that certain of the "external" CNRB members are providing both "consulting services" to Davis-Besse, as well as serving in the "independent auditor" capacity. Such an intertwined dual consulting and independent auditing approach for some members may have led to a situation where the external members have lost their ability to objectively view information and avoid the "group-thinking" results. Members may have grown to be too close to the plant, its condition, and its management, and may now even "own" an aspect of performance problems. Certain plant conditions may not be as "obvious" to them as they could be for an "independent" auditor. It was not possible to determine the extent to which this may have compromised the "independent audit" function as required by the USAR and procedures.

It is recommended that senior management clarify the roles and responsibilities for all CNRB members to ensure the integrity of the CNRB process. This should ensure that all members strictly adhere to the “arms-length” independence requirement to better enable them to identify indicators of plant or performance deficiencies. CNRB members, including external members, should not even have an appearance of a conflict, and should be able to review various performance reports, including Condition Reports, apparent and root cause reports, plant operating experience and deficiency reports without having any prior involvement in the preparation of those reports.

- **A major source of “input” information for CNRB review should be the Nuclear Quality Assurance (QA) organization, and the supporting Corrective Action Program (CAP). It is recognized that separate internal assessments of each of these programs is underway within FENOC. Based on the review of several years of CNRB information, it does not appear that the CNRB effectively utilized this information and did not adequately review the health or effectiveness of either the QA or CAP program. In addition, it was not apparent that CNRB was effectively overseeing the QA Audits that are to be “performed under the cognizance of the CNRB.”**

It is recommended that the CNRB be specifically required to review the effectiveness of the QA and CAP programs on an ongoing basis at every meeting. QA should be required to inform the CNRB of the issues that QA has highlighted as major focus areas or concerns. Information regarding “what the CAP is telling the station” should routinely be provided to the CNRB. This information should help the CNRB define areas requiring attention. Management should establish clear guidelines to ensure that the CNRB conducts a rigorous, open review of the adequacy of the implementation of these programs, particularly since the CNRB has the responsibility to oversee and review the QA process.

- The present Chairman of the CNRB also has Nuclear Quality Assurance (QA) line management responsibilities. Since this approach has inherent conflicts, extreme care should be taken to ensure the proper relationship between nuclear QA and the CNRB.

Since the CNRB has the responsibility to oversee and review the QA function, appropriate information of QA findings, including audits, assessments, and field observations should routinely be provided to the CNRB members. Because QA in effect is "Chairing" the CNRB (a group charged with overseeing QA) the full CNRB must maintain additional focus on the effectiveness of the QA program.

- The unique, important role of the Operations department in guiding and directing overall station safety performance at the station was not apparent in CNRB discussions.

The emphasis on Operations (and supporting functions) by the CNRB should be strengthened. Consideration should be given to having attendees from Operations at meetings, the inclusion of Operational issues in meeting briefings, and a stronger role for Operations in Subcommittee meetings.

- Recognizing the present status of the FENOC stations, particularly Davis-Besse, the structure, meeting format, subcommittee structure and membership, and meeting frequency do not appear to be effective and efficient, and not optimal for conducting a rigorous safety review of performance at the stations. While it was concluded that certain of the approaches (e.g., using subcommittees) are similar in concept to those used throughout the nuclear industry, it was concluded that adjustments should be considered to improve the effectiveness of this safety review function.

It is recommended that FENOC management consider several adjustments to the CNRB as it now functions:

- 1. Clearly communicate management's view of the importance of the CNRB function, including the expectation that all members are expected to attend all meetings.**
- 2. Reinforce that the principal focus of the CNRB is on maintaining personnel and worker safety, and then conduct the CNRB meetings in that manner. Ensure that all full CNRB meetings and Subcommittee meetings are conducted in a professional manner, all people are treated with respect, and that all views are presented.**
- 3. The Full CNRB meeting agenda should be revised to allow adequate time for the key areas requiring focus. This should include additional emphasis on issues/findings within Operations.**
- 4. The role of QA in supporting the CNRB should be clarified and integrated into the CNRB. The CNRB responsibility to review certain QA Audits conducted under its cognizance should be clarified.**
- 5. The Subcommittee structure should be realigned to focus on the major functions of the stations: Operations, Maintenance, Engineering, and Regulatory & Oversight. All other station functions, e.g., industrial safety, radiation protection, chemistry, etc. can be assigned to one of these Subcommittees.**
- 6. Strive to ensure that CNRB Subcommittee Chairman have prior actual plant experience in the key plant discipline where they serve (e.g., have a member with prior plant senior Operations experience serve as Chair of the Operations Subcommittee). The role of the Chair should be clearly defined and include being the "quarterback" of the subcommittee, the consensus builder, and should strive to encourage station personnel to identify, recognize, and develop solutions to their own issues.**

- 7. External members should specifically be required to remain independent of other station work activities.**
- 8. Expectations for Subcommittees should be clarified to require having membership from each of the other stations at every meeting.**
Subcommittees should focus significant attention at the worker through mid-management level to better understand activities at the station.
- 9. Subcommittee Chairman should be given the flexibility to establish the agenda for the Subcommittee day, that is, the one day before the Full CNRB meeting. That agenda should be established based on prior material that was provided, and issues suggested by the subcommittee members, by management, by QA, or other means. They should not be required to all focus on only one particular focus area topic, thereby precluding a more thorough review of station performance.**
- 10. Subcommittees should function as a "Team" and should be required to be "in the plant" for every meeting. As such, they should be able to provide their observations on issues of workers in the plant, material condition aspects, etc.**
- 11. Information routinely provided to CNRB members should be reviewed to ensure it is adequate to allow the CNRB to reach meaningful conclusions. Members should be requested to help with this re-evaluation.**
Information provided should include the principal findings of QA and from the CAP process. Condition Reports of some level of significance should be provided to the Subcommittees for their review and consideration prior to the meetings.
- 12. Presentations to the CNRB should more clearly be focused on technical, operational, and potential safety issues, and should provide enough information to allow the CNRB to reach meaningful conclusions.**

13. Management should attempt to increase the use of peer-to-peer support for the CNRB. While job responsibilities often make it difficult for such members to participate for more than one day of a meeting, it should be considered since it helps avoid becoming isolated, can provide valuable information, and can support personnel development.
14. Consideration should be given to increasing the number of meetings per year for each station. Many plants in the US now have four regular meetings per year, although some have recently begun to transition to three. Meetings are often of two days of total duration, the first day being subcommittees and the second the Full Meeting, although some plants have 2 ½ or 3 day meetings, or even longer. These are regularly scheduled meetings, and are regularly supplemented by telephone conference meetings to review technical specification changes. Plants in some form of difficulty (such as Davis-Besse) usually have additional meetings.
15. Consideration should be given to having the Full CNRB periodically review progress on the Davis-Besse Return to Service effort, and in particular, to conduct a formal review of the Readiness to Restart. The Charter of the CNRB should be carefully reviewed in this regard as one reading of the USAR would suggest that this is required. *(See Section 2.0)*
16. CNRB required reviews, e.g., technical specification changes, should not be allowed to be a major distraction to the technical or safety focus of the CNRB meeting. These required reviews can be accomplished by a variety of other means, including telephone conferences. Members could be encouraged to discuss questions or concerns with preparers prior to, and outside of, the full CNRB meeting. Large programmatic reviews (e.g., ITS, power uprate, license renewal) can be assigned to a subcommittee review with the full CNRB reviewing the Subcommittee performance. In all cases, the CNRB should follow its Charter and function as an "Audit" function, and not attempt to become a detailed review organization.

17. Several Administrative Processes used by the CNRB should be reexamined. These include:

- a. The process used by the CNRB to “approve” an item should be reconsidered and realigned to better follow current industry practice. For example, the present practice of “voting” raises administrative questions over just what is being voted on, whereas the emphasis should be on whether or not any concerns or potential safety questions were identified by even one person.
- b. The process of assigning “Actions” should not be allowed to become an administrative burden, since the stations already have a rigorous process for tracking actions, and the CNRB itself should certainly be able to establish its own follow-up actions. Subcommittees should not feel the need to assign administrative actions to themselves.
- c. Recent minutes of CNRB meetings have been from 30 to 50 pages in length. It is doubtful that many people read the minutes or find them of value. It is recommended that they be greatly reduced and written more focused on important issues from the meeting. In addition, it is recommended that an Executive Summary (of no more than about two-pages in length) be written for senior management.

Attachment A

Information Available to the CNRB: 1999 - present

Information was reviewed to determine whether or not the CNRB members had available sufficient information to permit them to recognize the existence of indicators of a potential problem at Davis-Besse.

CNRB members receive information from a number of sources. Internal members are involved in the day-to-day activities and as such continuously receive an extremely large amount of information. Typical sources for external members include formal briefings and presentation material provided to both the full CNRB meetings and at Subcommittee meetings; information received during discussions; tours of the plant, information requests based on material sent in routine "mailings" to each member, and input from discussions with "workers" and first-line supervisors. In addition, a very large amount of information including audits, inspection reports, operating experience reports, and plant Condition Reports is available for review and follow-up questions.

Members are also expected to stay current with other events within the nuclear industry, and as such should have been well aware of boric acid leakage issues in general, and particularly the more recent reactor vessel head leakage issues at other plants in the US. The industry has had historical problems with different types of boric acid leakage at plants, and significant problems were found at plants in the US. The NRC has kept plants (and experts) informed of these issues, and regarding the more recent concern regarding CRDM J-groove cracking, Davis-Besse was identified as one of the more susceptible plants..

While it probably does not present a complete picture of all information presented or discussed at the CNRB meetings, a review of formal meeting minutes, 'hand-out' presentation material, and plant update information was reviewed. In addition, other

information that was readily available to CNRB members at the time, for example, Audits and Condition Reports, was reviewed. In general, records from about 1999 to the present time were reviewed because they were more readily available.

The following summary highlights information available for CNRB review.

- **April 1, 1997, NRC Generic Letter 97-01, Degradation of Control Rod Drive Mechanism Nozzle and other Vessel Closure Head Penetrations**
- January 7, 1999 – The ‘hand-out’ material for the Davis-Besse CNRB meeting included a discussion of boric acid plating out on the containment air coolers. The Engineering/Licensing Subcommittee meeting summary notes that the CNRB had information that the reactor inventory leakage was currently higher than historical values, and that the upcoming May outage would provide an opportunity to identify sources of reactor coolant system leakage.
- May 27, 1999 – The update material provided to the CNRB again includes the discussion that the reactor coolant system leakage was about 0.3 gpm.
- July 21, 1999 – The minutes for the CNRB meeting states that the CNRB was *“provided an update of the Reactor Coolant (RC) leak status and problems being encountered with containment radiation monitors requiring frequent change out of their filters.”*

The minutes further indicate that *“Chemistry identified the presence of iron on the filters. Southwest Research has been contracted to perform an analysis.”* The ‘hand-out’ material for the meeting also notes that concern ‘still exists’ regarding the frequency of filter changes required for the containment radiation monitors. Containment entry was planned to pin-point problem areas.

[Note that while the CNRB was informed of “iron” on filters as early as 1999, the Southwest Research report was subsequently available for review and confirmed that Iron was an indicator of corrosion.]

In addition, CNRB Subcommittee minutes indicate that several important issues were all discussed: (1) an unidentified reactor coolant system leakage of 0.24 gpm, other identified leakage, and leakage over a long period of time; (2) a discussion of a build-up of boron on the containment air coolers and the belief that it was due to a water, not steam, leak; and (3) a discussion of radiation monitors and the need, coming out of the outage, to change filters every two days.

- June 1, 2000 – The minutes for the CRNB meeting include a simple statement that *“Outage efforts to fix RCS leakage have been successful.”* There does not appear to have been any additional information to support, or any questions about this conclusion.

- March 29, 2001 – The minutes for the CNRB meeting includes a specific discussion where plant management reviewed *“the Plant’s problems with Reactor Coolant unidentified leakage causing boric acid build-up on the Containment Coolers and the need to periodically enter containment to clean the coolers”* and that *“maintenance is looking at improving our cleaning efficiencies,”* There is one CNRB member response *“that the root cause is the leak and suggested that the focus needs to be on fixing the leak.”*

It is noted that this is the first time in the years of records reviewed, that there is a clear statement focusing on the safety issue, and it was nearly a year before the actual issue was identified, but there does not appear to have been any follow-up.

- **April 30, 2001, NRC Information Notice 2001-05, Through-Wall Circumferential Cracking of Reactor Pressure Vessel Head Control Rod Drive mechanism Penetration Nozzles at Oconee Nuclear Station, Unit 3.**
- **August 3, 2001, NRC Bulletin 2001-01, Circumferential Cracking of Reactor Pressure Vessel Head Penetration Nozzles**
- November 29, 2001 – The minutes for the CNRB meeting includes a discussion of the ongoing dialogue with the NRC regarding the drafting of a shutdown order to shutdown Davis-Besse before the end of the year. That summary notes a discussion on status, the comprehensive actions already taken by Davis-Besse, the need for contractor mobilization, and even a “political problem”.

That same summary does not note any probing, safety-oriented questions or concerns from any CNRB members. This is noteworthy since the ‘analysis section’ of those same minutes clearly indicates that the evaluation is based on visual inspections and that *“The inspection results afford us assurance that all but 4 nozzle penetrations were inspected in 1996. All but 19 penetrations were inspected in 1998. And all but 24 penetrations were inspected in 2000.”*

In addition, a number of Condition Reports (CR) were available for review as a follow-up to the discussions at the full CNRB and Subcommittee meetings. These CRs, also referred earlier to PCAQR reports, were rather specific in highlighting the issues. Examples include:

- PCAQR 96-551 (4/21/96) – Discusses the video tape of the CRDM nozzle inspection showing “several patches of boric acid accumulation on the RV head.” It also notes that the reactor head has “rust or brown stained boron.” The document discusses the walk-down inspection requirements and the write-up notes Davis-Besse deficiencies relative to other B&W plants.
- PCAQR 1998-0767 (4/24/98) – Discusses the results of the video inspection that “indicated several fist size clumps of boric acid.” It also noted “rust brown to white” lumps.

- CR 1999-0882 (7/9/99) – Discusses the Southwest Research report (included) analysis of Iron on filters of radiation monitors, and concludes “the iron oxide deposits are like corrosion products from an iron base compound within the system.” This is the result of analysis work discussed at the July 21, 1999 CNRB meeting.
- CR 2000-0782 (4/6/00) – Discussed the “red/brown” boric acid leakage from the weep holes, and included pictures. It further notes that Framatome completed the video inspection, and personnel from Framatome “examined the results of the inspection.”
- CR 2000-1037 (4/18/00) – This CR was a follow-up to CR 2000-0782 and discussed results of the Inspection of the Reactor head indicating “accumulation of boron in the area of the CRD nozzle penetrations through the head.” It discussed the process for removing the boron deposited between the reactor head and the thermal insulation.
- CR 01-1191 (5/2/01) – This identified the need to develop a Project Plan to prepare David-Besse for response to a cracked CRDM J-groove weld following experience from Oconee and ANO.

There were also documents that provided a “mixed” message regarding inspection, cleaning, and management of the boric acid issue. The along with the other material noted may well have been the cause for an increased questioning attitude.

- Toledo Edison Quality Assessment Audit AR-OO-OUTAG-01 (7/7/00) – The Audit notes as a Positive Attribute within Engineering the “Aggressive cleaning of boric acid accumulation from Rx head” and “engineering displayed noteworthy persistence in ensuring boric acid accumulation for the reactor head was thoroughly cleaned.”
- The Davis-Besse System Health Report, 4th Quarter 2001, includes information on several relevant issues. Sections on primary system leakage, containment coolers, and radiation monitors all mention the issue. It was noted that “J-groove weld failure can not be ruled out,” analysis indicate the “presence of Boron from an active leak,” and the need for frequent filter change-out in the radiation monitoring system.

Attachment B

Documents Reviewed

1. Company Nuclear Review Board Policies & Practices, Rev. 14, FENOC, effective May 6, 2002
2. FENOC Company Nuclear Review Board Value Assessment, 2001, approved April 8, 2002
3. Company Nuclear Review Board (CNRB) Value Assessment, 2000, approved in 2001, but not signed or dated
4. CNRB White Paper, Short Summary, undated, received from A. J. VanDenabele in June 2002
5. CNRB Self Critique, July 20, 1999
6. Company Nuclear Review Board, Meeting Minutes, Davis-Besse
 - Meeting of Sept. 3, 1998 (15 pages)
 - Meeting of January 7, 1999 (17 pages)
 - Meeting of July 22, 1999 (19 pages)
 - Meeting of Sept. 2, 1999 (13 pages)
 - Meeting of January 13, 2000 (20 pages)
 - Meeting of June 1, 2000 (22 pages)
 - Meeting of Oct 31, 2000 (33 pages)
 - Meeting of March 29, 2001 (51 pages)
 - Meeting of Nov 29, 2001 (45 pages)
 - Meeting of May 23, 2002 (40 pages)
7. Letter, dated April 18, 2002, from H. W. Bergendahl to US NRC; transmitting Root Cause Analysis Report, dated 4-15-2002.
8. US NRC Inspection Report 98-002, for Perry Nuclear Plant, dated 3-12-1998
9. US NRC Inspection Report 96-006, for Perry Nuclear Plant, dated 12-9-1996
10. US NRC Inspection Report 99-011, for Perry Nuclear Plant, dated 11-30-1999
11. FENOC Nuclear Quality Assessment – Perry, dated February 14, 2002
12. The Illuminating Company, Audit Report, Joint Utility Management Assessment, dated 3-2-1998
13. The Illuminating Company, Audit Report, Joint Utility Management Assessment, dated 2-14-2000
14. Letter, dated, June 26, 1997, Centenor Energy to the US NRC, Reply to Notice of Violation
15. CNRB Engineering & Licensing Subcommittee Minutes, meeting 99-001, January 9, 1999.
16. CNRB Engineering & Licensing Subcommittee Minutes, meeting 99-002, July 21, 1999.
17. Davis-Besse System Health Report, 4th Quarter 2001
18. Davis-Besse 11RFO Post Outage Report, dated September 9, 1998 and associated "Briefing Slides"
19. Davis-Besse 12RFO Post Outage Report (undated)
20. Davis-Besse CNRB Value Assessment for 2000, Attachment A details
21. Beaver Valley CNRB Value Assessment for 2000, Attachment A details
22. Perry CNRB Value Assessment for 2000, Attachment A details
23. Davis-Besse CNRB Value Assessment for 2001, Attachment A details

24. Beaver Valley CNRB Value Assessment for 2001, Attachment A details
25. Perry CNRB Value Assessment for 2000, Attachment A details
26. Davis-Besse Return to Service Plan (CD Version)
27. Handout of J. Martin, referenced in Davis-Besse CNRB Meeting Minutes of January 13, 2000 (page 13)
28. Davis-Besse CR 02-00846, "More Boron on Head than Expected," February 26, 2002
29. Davis-Besse CR 02-00685, "Boron Buildup on Reactor Vessel Head," February 21, 2002
30. Davis-Besse PCAQR 91-0353 regarding Boric Acid Corrosion Control, September 12, 1991
31. Davis-Besse PCAQR 96-551 regarding Boric Acid Accumulation, April 21, 1996
32. Davis-Besse PCAQR 98-0767 regarding several "fist-sized" clumps of Boric Acid, April 25, 1998
33. Davis-Besse CR 2000-1037 regarding Boron accumulation, April 18, 2000
34. Davis-Besse CR 2000-0782 regarding "Boric Acid leakage from the weep holes," April 16, 2000
35. Davis-Besse CR 1999-0861 regarding recurring problem, sample lines full of water, May 10, 1999
36. Davis-Besse CR 1999-0372 regarding Unit Log Entries of radiation levels and possible RCS Leakage, March 6, 1999
37. Davis-Besse PCAQR 90-221, CRDM Flange Inspection Results, March 22, 1990
38. Davis-Besse CR 1999-0882, Boron Build-up on Containment Air Filter, July 7, 1999
39. Davis-Besse CR 1999-1300 regarding SRI analysis: Iron Oxide from corrosion on containment radiator monitor filters, September 23, 1999
40. Davis-Besse CR 01-1191 regarding CRDM Nozzle J-Weld Cracking Project Plan, May 2, 2001
41. Administrative procedure, Boric Acid Corrosion Control, NG-EN-00324, rev 3, May 29, 2002
42. Davis-Besse Quality Trend Summary, 1st Quarter 2002 Condition Reports, June 3, 2002
43. Summary of External Expert Hours billed to CNRB, Jan 2001 to present
44. CNRB Competency/Experience Matrix, Jun2 12, 2002, including resumes.
45. Davis-Besse Safety Culture Survey, 2002 Employee Survey Results, March 8, 2002
46. Davis-Besse Plant Update Briefing materials for CNRB, February 25, 1998.
47. Davis-Besse Plant Update Briefing materials for CNRB, April 23, 1998
48. Davis-Besse Plant Update Briefing materials for CNRB, September 2, 1998
49. Davis-Besse Plant Update Briefing materials for CNRB, October 21, 1998
50. Davis-Besse Plant Update Briefing materials for CNRB, January 6, 1999
51. Davis-Besse Plant Update Briefing materials for CNRB, March 4, 1999
52. Davis-Besse Plant Update Briefing materials for CNRB, May 27, 1999

53. Davis-Besse Plant Update Briefing materials for CNRB, July 21, 1999
54. Davis-Besse Plant Update Briefing materials for CNRB, January 12, 2000
55. Davis-Besse Plant Update Briefing materials for CNRB, May 31, 2000
56. Davis-Besse Plant Update Briefing materials for CNRB, October 30, 2000
57. Davis-Besse Plant Update Briefing materials for CNRB, January 18, 2001
58. Davis-Besse Plant Update Briefing materials for CNRB, May 10, 2001
59. CNRB Presentation slides for Davis-Besse, March 27, 2001, H. Bergendahl
60. CNRB Presentation slides for Davis-Besse, July 20, 2001, H. Bergendahl
61. CNRB Presentation slides for Davis-Besse, October 4, 2001, L. Worley
62. CNRB Presentation slides for Davis-Besse, November 27, 2001, H. Bergendahl
63. CNRB Presentation slides for Davis-Besse, January 10, 2002, S. Moffitt
64. CNRB Presentation slides for Davis-Besse, February 28, 2002, J. Messina
65. CNRB Presentation slides for Davis-Besse, May 21, 2002, J. R. Fast
66. Toledo Edison QA Audit AR-00-OUTAG-01, July 7, 2000
67. Minutes of CNRB meeting at Perry, February 28, 2002
68. Davis-Besse CR 02-03272, Multiple Failures to Comply with Regulatory Requirements, July 17, 2002
69. NRC Information Notice 80-027, Degradation of Reactor Coolant Pump Studs, June 11, 1980
70. NRC Information Notice 82-006, Failure of Steam Generator Primary Side Manway Closure Studs, March 12, 1982
71. NRC Bulletin 82-002, Degradation of Threaded Fasteners in the Reactor Coolant Pressure Boundary of PWR Plants, June 2, 1982
72. NRC Information Notice 86-108, Supplement 1, Degradation of Reactor Coolant System Pressure boundary Resulting from Boric Acid Corrosion, April 20, 1987
73. NRC Information Notice 86-108, Supplement 2, Degradation of Reactor Coolant System Pressure Boundary Resulting from Boric Acid Corrosion, November 19, 1987
74. NRC Generic Letter 88-005, Boric Acid Corrosion of Carbon Steel Reactor Pressure Boundary Components in PWR Plants, March 17, 1988
75. NRC Information Notice 90-010, Primary Water Stress corrosion Cracking in INCONEL 600, February 23, 1990
76. NRC Information Notice 94-063, Boric Acid Corrosion of Charging Pump Casing Caused by cladding Cracks, August 30, 1994
77. NRC Information Notice 86-108, Supplement 3, Degradation of Reactor Coolant System Pressure Boundary Resulting from Boric Acid Corrosion, January 5, 1995
78. NRC Information Notice 96-011, Ingress of Demineralizer Resins Increases Potential for Stress corrosion Cracking of Control Rod Drive Mechanism Penetrations, February 14, 1996

79. NRC Generic Letter 97-001, Degradation of Control Rod Drive mechanism Nozzle and Other Vessel Closure head Penetrations, April 1, 1997
80. NRC Information Notice 2001-05, Through-Wall Circumferential Cracking of Reactor Pressure Vessel Head Control Rod Drive Mechanism Penetration Nozzles at Oconee Nuclear station, unit 3, April 30, 2001
81. NRC Bulletin 2001-01, Circumferential Cracking of Reactor Pressure Vessel Head Penetration Nozzles, August 3, 2001
82. NRC Information Notice 2002-11, Recent Experience with Degradation of Reactor Pressure Vessel Head, March 12, 2002
83. NRC Bulletin 2002-01, Reactor Pressure Vessel Head Degradation and Reactor Coolant Pressure Boundary Integrity, March 18, 2002
84. NRC Information Notice 2002-13, Possible Indicators of Ongoing Reactor Pressure Vessel Head Degradation, April 4, 2002
85. Reactor Pressure Vessel Head Degradation, presented at ANS 2002 Annual Meeting, June 11-14, 2002, by Brian Sheron, US NRC
86. Davis-Besse CR 02-00891, Reactor Vessel Head, February 27, 2002
87. Davis-Besse Procedure DB-DP-00022/R03, Station Review Board, effective March 2, 1998
88. Folder of Memoranda from Jay Hultz to Bill Kanda, regarding review of CNRB materials, October 2000-July 2001
89. First Energy Memorandum, Davis-Besse Employee Concerns Mid-Year Report for 2002, A.J. VanDenabeele to L.W. Pearce, dated July 24, 2002
90. Davis-Besse Approved CNRB Meeting Minutes, for May 23, 2002 meeting
91. Davis-Besse Nuclear Quality Assessment Surveillance Report, SR-02-OUTAG-01, approved June 24, 2002
92. Nuclear Quality Assessment Oversight of Davis-Besse Return to Service Plan, Rev. 1, July 22, 2002
93. Davis-Besse CNRB Action Item Status, July 24, 2002
94. Business Plan Monthly Performance Reports for Davis-Besse, Perry, and Beaver Valley Nuclear Stations, June 2002
95. Davis-Besse CR-02-02584, Implementation of Corrective Action Program by Site Personnel, June 13, 2002
96. Davis-Besse CR-02-02585, Management and Supervisory Oversight and Ownership of Plant Activities, June 13, 2002
97. Davis-Besse CR-02-00891, Control Rod Drive Nozzle Crack Indication, February 27, 2002
98. Davis-Besse CR-02-02363, Engineering Change Process Does Not Meet 10CFR 50 App B or ANSI 45.2.11 Requirements, May 31, 2002
99. Davis-Besse CR-02-02408, Collective Significance-Plant Modification Program Concerns, June 3, 2002
100. Davis-Besse CR-02-02419, Untimely Corrective Actions to Address Corrective Action Program Weaknesses, June 4, 2002
101. Davis-Besse CR-02-02434, Inadequate Engineering Rigor Applied to Activities, June 5, 2002
102. Davis-Besse CR-02-02606, Radiation Protection Corrective Action Program is Considered Unacceptable, June 14, 2002

103. Davis-Besse CR-02-02846, Containment Emergency SUMP Issues, June 27, 2002
104. Davis-Besse CR-02-02943, Containment Air Cooler Boric Acid Corrosion, July 2, 2002
105. Davis-Besse CR-02-02974, Past Operability and Reportability Reviews, July 3, 2002
106. Davis-Besse CR-02-03005, Operability Determination 02-2869 Rigor and Thoroughness, July 6, 2002
107. Letter, H. Bergendahl to US NRC, Supplemental Information Regarding LAR, June 4, 2002
108. Letter, US NRC to H. Bergendahl, RFI regarding Safety Significance Assessment of Reactor Pressure Vessel Head Degradation, June 24, 2002
109. Minutes of "Special" Station Review Board meeting, May 8, 2002
110. Memorandum, J.M. Vetter, to "Distribution", NQA Audit Notification DB-C-02-03, June 21, 2002
111. Davis-Besse LER 2002-001, Main Steam Safety Valve Setpoints Greater Than Allowable Values, April 11, 2002
112. Davis-Besse LER 2002-002-00, Reactor Coolant System Pressure Boundary Leakage..., April 29, 2002
113. Davis-Besse LER 2002-003, Fuel Movement in Spent Fuel Pool Without Required Door Attendant, May 9, 2002
114. Davis-Besse CR-02-03369, Quality Expectations, July 17, 2002
115. Davis-Besse CR-02-03404, Expectations for Program Reviews not Communicated, July 23, 2002
116. Davis-Besse CR-02-0286, Uncompensated Extra Hours, June 19, 2002